

ADDENDUM NO. 1

Date of Addendum: May 27, 2016

Project: Mercey Springs Sewer Line Replacement

Owner: City of Los Banos

Bid Date: May 27, 2016

To: Prospective Bidders

From: Gouveia Engineering
456 Sixth Street
Gustine, CA 95322

1. This Addendum forms a part of the Bidding Documents and will be incorporated into the Contract Documents, as applicable. All other conditions of the Contract Documents remain unchanged. The following changes, additions, or deletions as set forth herein shall apply to the Contract Documents and shall be made a part thereof and shall be subject to all the requirements thereof as though originally shown and/or specified.
2. The Technical Provisions are hereby modified to effect the following changes:
 - a) Section 6.5, Sanitary Sewer Pipelines-Testing
 1. Pressure testing requirements will be waived. City inspector will determine acceptance of pipeline installed.
3. The Plans are hereby modified to effect the following changes:
 - a) Sheet 18, Drawing C-118
 1. Proposed manhole SSMH 3324A shall be constructed at station 68+37.86 and referenced as SSMH 3324 (Attachment 1).
4. Bids shall be submitted in accordance with this Addendum. All Bidders MUST acknowledge receipt of this Addendum by signing and returning this Addendum with your Bid.

Gouveia Engineering


By: Mario B. Gouveia, PE


Firm Name: _____

By: _____

Title: _____


Date: _____

WATER LINE
(66+00 SEE SHEET 17)



MATCH LINE
(70+00 SEE SHEET 19)

ATTACHMENT 1



EX CBSN 3327
GRATE = 114.62
INV 18" SW Out = 111.19

EX SDMH 3325
RIM = 115.51
INV 18" NE In = 106.62
INV 18" NW In = 106.62
INV 36" S In = 104.66
INV 36" N Out = 104.66

~~SSMH 3324A
RIM = 115.10
INV 12" S In = 109.27
INV 12" N Out = 109.27~~

~~EX SSMH 3324
RIM = 115.70
INV 10" S In = 109.47
INV 10" N Out = 109.37~~

SSMH 3324
RIM = 115.70
INV 12" S In = 109.40
INV 12" N Out = 109.40

EX CBSN 2890
GRATE = 113.73
INV 18" SE Out = 108.28

APPROXIMATE
RIGHT OF WAY

APPROXIMATE
RIGHT OF WAY