



City of
Los Banos
At the Crossroads of California

Contract Documents
for
Construction of

**IDAHO AVENUE
WATERLINE REPLACEMENT**

JANUARY 2019

Bid Proposals must be received no later than 2:00 p.m., April 2, 2019
City of Los Banos City Clerk
520 J Street
Los Banos, CA 93635

City of Los Banos
Public Works Department

Table of Contents

Advertisement for Bids

Information for Bidders

Bid

Bid Bond

Sample Forms

- Agreement
- Certificate of Contractor
- Payment Bond
- Performance Bond
- Notice of Award
- Notice to Proceed
- Change Order

General Provisions

1. Terms and Definitions
2. Order of Precedence of Contract Documents
3. Venue
4. Giving Notice
5. Cumulative Remedies
6. Non-Discrimination
7. Non-Discrimination of the Disabled
8. Additional Instructions and Detail Drawings
9. Schedules, Reports and Records
10. Drawings and Specifications
11. Shop Drawings, Product Data and Samples
12. Materials, Services and Facilities
13. Inspection and Testing
14. Substitutions
15. Patents
16. Surveys, Permits and Regulations
17. Protection of Work, Property and Persons
18. Supervision by Contractor
19. Changes in the Work
20. Changes in Contract Price
21. Time for Completion and Liquidated Damages
22. Correction of Work
23. Suspension of Work, Termination and Delay
24. Progress Estimates
25. Progress Payments
26. Prompt Payment
27. Acceptance and Final Payment
28. Quantities and Unit Prices
29. Insurance
30. Contract Security
31. Assignments
32. Indemnification
33. Separate Contracts
34. Subcontracting
35. Employment of Apprentices
36. Payment of Prevailing Wages

37. Registration to Train Apprentices
38. Penalties
39. Engineer's Authority
40. Land and Rights-of-Way
41. Warranty and Guarantee
42. One (1) Year Warranty Period
43. Correction of Defective Work
44. Early Completion
45. Extended Warranties and Guarantees
46. Arbitration
47. Taxes
48. Contractor's Understanding
49. Accidents
50. Safety and Sanitation
51. Climatic Conditions
52. Officials Not to Benefit
53. Clean-Up
54. Notice to Owner
55. Payment of Withheld Funds
56. Storm Water Pollution Prevention Measures

Special Provisions

1. Requirements
2. Description of Work
3. Commencement, Prosecution and Completion of Work
4. Hours of Work
5. City Permits and Business Licenses
6. Testing
7. Responsibility Regarding Existing Utilities and Private Property
8. Obstructions
9. Materials Furnished By Owner
10. Materials Furnished By Contractor
11. Schedule of Values, Material List and Substitutions
12. Request for Extension of Time
13. Rights-of-Way
14. Coordination with Other Work
15. Closure of Streets
16. Construction Signs, Barricades, Lights and Flagmen
17. Traffic Control Plan
18. Disposal of Waste Materials
19. Noise Control
20. Water Supply
21. Notifications
22. Work Not Listed in Proposal
23. Submittals
24. Bid Item Descriptions

Technical Specifications

- | | |
|----------|--|
| 01 22 00 | Explanation of Bid Items |
| 01 57 56 | Traffic Control Plan |
| 01 77 00 | Contract Closeout |
| 02 01 20 | Protection of Underground Facilities & Monuments |
| 02 41 00 | Demolition |
| 03 33 15 | Concrete Sidewalk, Curb, & Gutter |
| 09 90 00 | Painting and Coating (Site) |

31 23 17	Trenching Backfilling and Compacting
32 11 23	Aggregate Base
32 12 16	Asphalt Concrete Paving
32 17 23	Traffic Signing Striping and Markings
33 01 00	Pipe Fittings
33 05 26	Utility Line Marking
33 12 19	Fire Hydrants
33 13 00	Disinfection of Water Distribution System
40 05 23	Valves and Appurtenances

Advertisement for Bids

CITY OF LOS BANOS
520 J Street
Los Banos, California 93635

Notice is hereby given that separate sealed bids for the award of contract for the **Construction of IDAHO AVENUE WATERLINE REPLACEMENT** will be received by the City of Los Banos at the office of the City Clerk until 2:00 p.m. Pacific Daylight Time, April 2, 2019 and then at said office publicly opened and read aloud.

The major work consists of the installation of approximately 900 linear feet of 8-inch waterline on Idaho Avenue from L Street to J Street to increase flows in the area. The installation of the new pipe on Idaho Avenue will connect to an existing 6-inch line at J Street and a 10-inch line at L Street. Residential service laterals and water valves shall also be replaced. The work also includes a partial removal and replacement of sidewalk, curb and gutter, and the asphalt above proposed underground improvements. Additionally, two ADA ramps will be installed at the corners of Idaho Avenue and K Street, and Idaho Avenue and J Street. The existing 4-inch waterline on Idaho Avenue shall be abandoned in place.

The time for completion shall be ninety (90) calendar days.

The Contract Documents, in their entirety, can be viewed and/or obtained from the City of Los Banos website at www.losbanos.org or at the following locations:

Central California Builders Exchange (www.cencalbx.com)

Builders Exchange of Stockton (www.besonline.com)

Valley Builders Exchange, Inc. (www.valleybx.com)

Dodge Data & Analytics (www.construction.com/plans/)

A payment bond prepared and executed in accordance with California Civil Code Section 3247 and a bond for faithful performance of the contract will be required of the successful bidder who is awarded the contract.

The successful bidder must comply with the latest general prevailing rate of per diem wages as determined by the Director of Industrial Relations, State of California, Department of Industrial Relations and is to be paid to the various craftsmen and laborers required to construct said improvements and is made a part of the specifications and contract for said work to which reference is hereby made for further particulars.

No contractor or subcontractor may be listed on a bid proposal or awarded a contract for public work on a public works project unless registered with the Department of Industrial Relations pursuant to Labor Code section 1725.5.

This project is subject to compliance monitoring and enforcement by the Department of Industrial Relations. Contractor registration information can be found at:

<http://www.dir.ca.gov/Public-Works/PublicWorks.html>

Each bid shall be accompanied by cashier's or certified check or by a bidder's bond, made payable to the City of Los Banos and executed by a corporate surety licensed to issue surety bonds in the State of California, for an amount equal to at least ten percent (10%) of the amount of said bid and no bid shall be considered unless such cashier's or certified check or bidder's bond is enclosed therewith.

The successful bidder of this project shall have the following current and active California State Contractor's License at the time of the submission of the bid and throughout the duration of the contract: **Class A.**

Bidders shall refer to the Contract Document's Information for Bidders for complete instructions.

Bidders are solely responsible for the cost of preparing their bids.

The City specifically reserves the right, in its sole discretion, to reject any or all bids, to re-bid, or to waive inconsequential defects, in bidding not involving time, or quality of the work. The City may reject any and all bids and waive any minor irregularities in the bids.

Information for Bidders

Sealed bids will be received by the City of Los Banos (herein called the "Owner"), at the office of the City Clerk until 2:00 p.m. Pacific Daylight Time (PDT), on April 2, 2019, then at said office, publicly opened and read aloud. Owner shall reject all bids received after the specified time and will return such bids to bidder, unopened. Bidders must submit bids in accordance with these instructions. No emailed or faxed bids will be accepted.

The major work consists of the installation of approximately 900 linear feet of 8-inch waterline on Idaho Avenue from L Street to J Street to increase flows in the area. The installation of the new pipe on Idaho Avenue will connect to an existing 6-inch line at J Street and a 10-inch line at L Street. Residential service laterals and water valves shall also be replaced. The work also includes a partial removal and replacement of sidewalk, curb and gutter, and the asphalt above proposed underground improvements. Additionally, two ADA ramps will be installed at the corners of Idaho Avenue and K Street, and Idaho Avenue and J Street. The existing 4-inch waterline on Idaho Avenue shall be abandoned in place.

The time for completion is ninety (90) calendar days.

Each bid must be submitted in a sealed envelope and addressed to the City of Los Banos at 520 J Street, Los Banos, CA 93635. Each sealed envelope containing a bid must be plainly marked on the outside as "**IDAHO AVENUE WATERLINE REPLACEMENT: Attention City Clerk**", and the envelope shall also bear on the outside, the name of the bidder, and their address. If forwarded by mail, the sealed envelope containing the bid must be enclosed in another envelope addressed to the City of Los Banos at 520 J Street, Los Banos, CA, 93635, and also clearly state, "**IDAHO AVENUE WATERLINE REPLACEMENT: Attention City Clerk**".

A complete bid includes the Bid Form, List of Subcontractors, Equal Employment Opportunity, Non-Collusion Affidavit, Debarment and Suspension Certification, Bid Schedule, Experience, Bid Bond with surety, and a copy of a current California State Contractor's License. A signed Addendum, if issued, must also be submitted with the sealed bid. The Total Bid Amount must be filled in, in ink or typewritten, and the bid must be fully completed and executed when submitted. Only one set of original bid forms are required to be submitted. Mistakes must be corrected and the correction inserted; correction must be initialed in ink by person or persons signing the bid. No conditional bids will be accepted.

The bid shall be signed by a person or persons legally authorized to bind bidder to the contract. The individual or individuals signing each document shall warrant that they are authorized to bind the bidder.

The Owner may waive any informalities or minor defects or reject any and all bids. Any bid may be withdrawn prior to the above scheduled time for the opening of bids or authorized postponement thereof. Any bid received after the time and date specified shall not be considered. No bidder may withdraw a bid within 30 days after the actual date of the opening thereof. Should there be reasons why the contract cannot be awarded within the specified period, the time may be extended by mutual agreement between the Owner and the bidder.

Each bid must be accompanied by a bid bond payable to the Owner for ten percent (10%) of the total amount of the bid. As soon as the bid amounts have been compared, the Owner will return the bid security of all except the three lowest responsive and responsible bidders. Once a bid has been awarded, and the payment bond and performance bond of the successful bidder has been received by the Owner, the bid security of the three remaining lowest responsive and responsible bidders will be returned.

All bonds must be acknowledged before a Notary Public by both the bidder and the surety. Attorneys-in-fact who sign bid bonds or payment bonds and performance bonds must file with each bond a certified and effective dated copy of their power of attorney.

Award and Execution of Contract

The party to whom the contract is awarded will be required to execute the Agreement, and obtain the performance bond and payment bond along with satisfactory evidence of insurance within ten (10) calendar days from the date when the Notice of Award is delivered to the successful bidder. The Notice of Award shall be accompanied by the necessary agreement and bond forms. In case of failure of the bidder to execute the Agreement, the Owner may, at his option, consider the bidder in default, in which case the bid bond accompanying the bid shall become the property of the Owner.

A performance bond and a payment bond, each in the amount of 100 percent of the Contract Price, with a corporate surety named on the current list of "Surety Companies Acceptable on Federal Bonds" as published in the Treasury Department Circular Number 570, will be required for the faithful performance of the contract. The payment bond must be issued by an admitted surety insurer holding a certificate of authority to transact surety insurance in California issued by the Insurance Commissioner.

All bonds must be acknowledged before a Notary Public by both the bidder and the surety. Attorneys-in-fact who sign bid bonds or payment bonds and performance bonds must file with each bond a certified and effective dated copy of their power of attorney.

The Owner, within 15 days of receipt of the performance bond, payment bond and agreement signed by the party to whom the contract was awarded, shall sign the Agreement and return to such party an executed duplicate of the agreement. Should the Owner not execute the Agreement within such period, the bidder may, by written notice, withdraw his signed Agreement. Such notice of withdrawal shall be effective upon receipt of the notice by the Owner.

The Notice to Proceed shall be issued within 10 days of the execution of the Agreement by the Owner. Should there be reasons why the Notice to Proceed has not been issued within such period, the time may be extended by mutually agreed upon, and the bidder may terminate the Agreement without further liability on the part of either party.

All applicable laws, ordinances, and the rules and regulations of all authorities having jurisdiction over construction of the project shall apply to the Contract throughout.

Subcontractors

The subcontractors listed by bidder in the bid shall list therein the name and address of each subcontractor to whom the bidder proposes to subcontract portions of the work in an amount in excess of one-half of one percent of the total bid or \$10,000, whichever is greater, in accordance with the Subletting and Subcontracting Fair Practices Act, commencing with Section 4100 of the Public Contract Code. The bidder's attention is invited to other provisions of the Act related to the imposition of penalties for a failure to observe its provisions by using unauthorized subcontractors or by making unauthorized substitutions.

Registration with California Department of Industrial Relations (DIR)

A contractor or subcontractor shall not be qualified to bid on, be listed in a bid proposal, subject to the requirements of Section 4104 of the Public Contract Code, or engage in the performance of any contract for public work, as defined in this chapter, unless currently registered and qualified to perform public work pursuant to Section 1725.5. It is not a violation of this section for an unregistered contractor to submit a bid that is authorized by Section 7029.1 of the business and Professions Code or by Section 10164 or 20103.5 of the Public Contract Code, provided the contractor is registered to perform public work pursuant to Section 1725.5 at the time the contract is awarded. Labor Code Section 1771.1(a) requires contractors and their subcontractors to possess and maintain such registration with DIR in order to be awarded and to perform on public works projects (regardless of funding source).

Pursuant to Section 1771.4, each contractor and subcontractor shall furnish certified payroll records to the Labor Commissioner at least monthly and in a format prescribed by the Labor Commissioner of the DIR. Until such time that the DIR gives awarding agencies direct access to all certified payrolls submitted by contractors and subcontractors, contractor and his subcontractors are also required to submit copies of payroll records to Owner on a monthly basis. Information on the above can be found at:

Prevailing Wage

This work is subject to prevailing wage requirements. If there is a difference between the minimum wage rates predetermined by the Secretary of Labor and the prevailing wage rates determined by the Director of the Department of Industrial Relations of the State of California for similar classification of labor, the contractor and his subcontractor shall not pay less than the higher wage rate. In accordance with the provisions of Section 1773 of the Labor Code of the State of California, the Owner has obtained from the Director of the Department of Industrial Relations, the general prevailing rate for each craft, classification, or type of workman required for execution of the Agreement. A copy of said prevailing rate of per diem wages is on file in the office of the Owner, and available from the California Department of Industrial Relations' Internet web site at <http://www.dir.ca.gov/DLSR/PWD>.

The Federal minimum wage rates for this work as predetermined by the United States Secretary of Labor may be examined at the offices described above where the Contract Documents may be seen. Addenda to modify the Federal minimum wage rates, if necessary, will be posted on the internet at www.losbanos.org. Future effective general prevailing wage rates, which have been predetermined are on file with the California Department of Industrial Relations and are referenced but not printed in the general prevailing wage rates.

Bidders must satisfy themselves as to the accuracy of the estimated quantities in the Bid Schedule by examination of the site and a review of the drawings and specifications including addenda. After bids have been submitted, the bidder shall not assert that there was misunderstanding concerning the quantities of work or the nature of the work to be done. The failure or omission of any bidder to do any of the foregoing shall not relieve any bidder from any obligation with respect to his bid.

The Contract Documents contain the provisions required for the construction of the project. The Owner will not be responsible for, nor be bound by, any oral instructions, interpretations, or explanations issued by the Owner or its representatives. Any request for clarifications or questions of the Contract Documents shall be made in writing or email and deliverable to:

City of Los Banos Public Works Department
Attn: Greg Pimentel
greg.pimentel@losbanos.org
411 Madison Avenue
Los Banos, CA 93635

Requests for clarification or questions shall be delivered to the Owner before 5:00 p.m. PST on March 20, 2019. Any Owner response to a request for clarification, questions and answers will be posted to the City's website at www.losbanos.org no later than 5:00 p.m. PST on March 22, 2019 and if necessary, shall become a part of the bid as an addendum.

Proposed timeline of events associated with the awarding of bid:

Release of Advertisement for Bid		March 1, 2019
Deadline to Submit Questions/Clarifications	5:00 p.m.	March 20, 2019
Addendum/Questions/Clarifications posted	5:00 p.m.	March 22, 2019
Bid Opening	2:00 p.m.	April 2, 2019
City Council Considers Bid		April 17, 2019 (tentative)
Issuance of a Notice to Proceed	On or before:	May 6, 2019 (tentative)
Construction to Begin	On or before:	May 6, 2019 (tentative)

Qualification of Bidder

The Owner may make such investigation as it deems necessary to determine the ability of the bidder to provide the services requested, and the bidder shall furnish to the Owner all information and data for this purpose as the Owner may request. The Owner reserves the right to reject any bid should

the evidence submitted by, or investigation of, the bidder fail to satisfy the Owner that such bidder is properly qualified to carry out the obligations of the bid and to complete the requirements contemplated therein.

Governing Law and Venue

This bid, or any contract that may result from the award of this bid, shall be deemed to be made under, and shall be governed by and construed in accordance with, the laws of the State of California. Any action brought to enforce the terms, or provision of this bid or any contract that may result from the award of this bid, shall have venue in the County of Merced, State of California.

Mandatory Bid Protest Procedure

The lack of prompt procedure to resolve disputes regarding the bidding process would impair the Owner's ability to carry out its purpose of contracting this project in a timely manner. Therefore, to the maximum extent authorized by law and notwithstanding any other procedures specified in these Contract Documents, all disputes and/or protests regarding the bidding process shall be subject to the following procedure. In submitting a bid to the Owner for this work, the bidder agrees to comply with and to be bound by this procedure.

Any bid protest must be submitted in writing to the Owner before 5:00 p.m. on the fifth (5th) business day following bid opening.

1. The initial protest document must contain a complete statement of the basis for the protest, and all supporting documentation. A non-refundable fee of One Thousand Dollars (\$1,000.00) made payable to the "City of Los Banos" shall accompany the protest documents and will be used by the Owner to recover costs in evaluating the bid protest. A bid protest submitted without the requisite fee shall not be considered by the Owner.
2. The party filing the protest must have actually submitted a bid for the work. A subcontractor of a party submitting a bid for the work may not submit a bid protest. Only bidders who the Owner otherwise determines are responsive and responsible are eligible to protest a bid.
3. A party may not rely on the bid protest submitted by another bidder, but must timely pursue its own protest.
4. The protest must refer to the specific portion of the Contract Documents which forms the basis for the protest.
5. The protest must include the name, address and telephone number of the person representing the protesting party.
6. The party filing the protest must concurrently transmit a copy of the initial protest document and any attached documentation to all other parties with a direct financial interest which may be adversely affected by the outcome of the protest. Such parties shall include all other bidders who appear to have a reasonable prospect of receiving an award depending upon the outcome of the protest.
7. The Owner will give the protested bidder five (5) business days after the receipt of the protest to submit a written response. The responding bidder shall transmit the response to the protesting bidder concurrent with the delivery to the Owner.
8. The procedure and time limits set forth in this paragraph are mandatory and are the bidder's sole and exclusive remedy in the event of bid protest. The bidder's failure to comply with these procedures shall constitute a waiver of any right to further pursue the bid protest, including filing a Government Code Claim or legal proceedings.

If the Owner determines that a protest is frivolous, the protesting bidder may be determined to be non-responsive and/or non-responsible and that bidder may be determined to be ineligible for future contract awards.

Cancellation of Contract

The Owner may terminate any contract derived from this bid as follows:

- WITHOUT CAUSE at any time by giving thirty (30) calendar days written notice to the successful bidder;
- WITH CAUSE (Default) at any time by giving ten (10) calendar days written notice to the successful bidder. Cancellation for cause shall be at the discretion of the Owner and shall be, but is not limited to, failure to supply the items, materials, equipment or services specified within the time allowed or within the terms, conditions or provisions of this bid. The successful bidder may not cancel any contract derived from this bid, without prior written consent of the Owner.

Bid Form

TO: City of Los Banos
520 J Street
Los Banos, CA 93635

In compliance with the Advertisement for Bids the undersigned, as bidder, hereby offers to provide to the Owner, in accordance with the terms and conditions in the provisions set forth in the Contract Documents the stated total bid amount quoted on this Bid Form for the work of

IDAHO AVENUE WATERLINE REPLACEMENT

Total Bid Amount: \$ _____

(Total Bid Amount in Written Form)

The undersigned certifies under penalty of perjury under the laws of the State of California and the United States of America, that the above quotation constitutes a bona-fide offer for the work, that undersigned is a duly authorized representative of the company listed, that the quotation is in no way sham or collusive, and that the executed Agreement between the bidder and Owner constitutes acceptance of bidder's total bid for the work stated in the Contract Documents. The undersigned has read the General Provisions, Special Provisions, and Technical Specifications in these Contract Documents. The undersigned further certifies, under penalty of perjury that the Non-Collusion Affidavit required by Title 23 United States Code, Section 112 and Public Contract Code Section 7106; and the Title 49 Code of Federal Regulations, Part 29 Debarment and Suspension Certification are true and correct.

The undersigned acknowledges receipt of the following addenda: _____

Signature: _____ Date: _____

Title: _____

Name of Business: _____

Doing business as: (*Circle One*): An Individual A Partnership A Corporation

Business Address: _____

Telephone No.: _____ Fax No.: _____

E-Mail Address: _____

License Number: _____ Class & Expiration Date: _____

Non-Collusion Affidavit
PUBLIC CONTRACT CODE 7106

In conformance with Title 23 United States Code Section 112 and Public Contract Code 7106 the bidder declares that the bid is not made in the interest of, or on behalf of, any undisclosed person, partnership, company, association, organization, or corporation; that the bid is genuine and not collusive or sham; that the bidder has not directly or indirectly induced or solicited any other bidder to put in a false or sham bid, and has not directly or indirectly colluded, conspired, connived, or agreed with any bidder or anyone else to put in a sham bid, or that anyone shall refrain from bidding; that the bidder has not in any manner, directly or indirectly, sought by agreement, communication, or conference with anyone to fix the bid price of the bidder or any other bidder, or to fix any overhead, profit, or cost element of the bid price, or of that of any other bidder, or to secure any advantage against the public body awarding the contract of anyone interested in the proposed contract; that all statements contained in the bid are true; and, further, that the bidder has not, directly or indirectly, submitted his or her bid price or any breakdown thereof, or the contents thereof, or divulged information or data relative thereto, or paid, and will not pay, any fee to any corporation, partnership, company association, organization, bid depository, or to any member or agent thereof to effectuate a collusive or sham bid.

Debarment and Suspension Certification

TITLE 49, CODE OF FEDERAL REGULATIONS, PART 29

The bidder, under penalty of perjury, certifies that, except as noted below, he/she or any other person associated therewith in the capacity of owner, partner, director, officer, and manager:

- Is not currently under suspension, debarment, voluntary exclusion, or determination of ineligibility by any federal agency;
- Has not been suspended, debarred, voluntarily excluded or determined ineligible by any federal agency within the past 3 years;
- Does not have a proposed debarment pending; and
- Has not been indicted, convicted, or had a civil judgment rendered against it by a court of competent jurisdiction in any matter involving fraud or official misconduct within the past 3 years.

If there are any exceptions to this certification, insert the exceptions to an additional sheet of paper and include with the bid.

Exceptions will not necessarily result in denial of award, but will be considered in determining bidder responsibility. For any exception noted above, indicate on an additional sheet of paper to whom it applies, initiating agency, and dates of action.

NPDES/MS4 Compliance Certification

All construction projects within the City limits must comply with the National Pollutant Discharge Elimination System (NPDES) storm water regulation adopted by the EPA and the Phase II Small Municipal Separate Storm Sewer System (MS4) General Permit requirements, regardless of size.

The City is required under these permits to provide information to Contractors performing work within City limits about training opportunities to assist in managing potential pollutants from construction –related activities, selection, installation, implementation, and maintenance of Best Management Practices (BMPs), as well as overall program compliance. The City has provided such information and helpful links on their website at <http://www.losbanos.org/city-government/departments/public-works/>, under the Storm Water Management Plan tab.

The Bidder acknowledges that they are aware of the necessity to be in compliance with the NPDES and MS4 permits while working within City limits, and that information regarding such is available on the City's website.

Note: The above certifications are part of the bid. Signing this bid on the signature portion thereof shall also constitute signature of these certifications.

**Bid Schedule
For
IDAHO AVENUE WATERLINE REPLACEMENT**

Bidder agrees to perform all the work described in the Contract Documents for the following unit and lump sum prices and understands that the quantity of work shown is approximate only. The schedule shall be completed by the bidder with the unit and lump sum prices entered in numerals. The extensions shall be made by the bidder. In case of discrepancy between the unit prices and the extension thereof, the unit price shall be considered as correct when evaluating bids.

ITEM NO.	ITEM	QUANTITY AND UNIT	UNIT PRICE	AMOUNT
1	Mobilization/Demobilization	1 LS	\$	\$
2	Site Demolition and Pipeline Protection	1 LS	\$	\$
3	Customer Outreach & Satisfaction	1 LS	\$	\$
4	Traffic Control & General Safety	1 LS	\$	\$
5	Sawcut & Remove Existing AC Pavement	3,100 SF	\$	\$
6	Sawcut & Remove Existing Sidewalk, Curb & Gutter	2,050 SF	\$	\$
7	Abandon Existing Water Main	1 LS	\$	\$
8	Connection to Existing Water Main	3 EA	\$	\$
9	F&I 8-Inch C-900 DR 14 PVC Water Main	910 LF	\$	\$
10	F&I 10x10x8-inch Tee	1 EA	\$	\$
11	F&I 8x8x6x6-Inch Cross	1 EA	\$	\$
12	F&I 6x6x6-Inch Tee	1 EA	\$	\$
13	F&I 8-Inch Gate Valve	4 EA	\$	\$
14	F&I 6-Inch Gate Valve	1 EA	\$	\$
15	F&I 8-Inch Reducer	1 EA	\$	\$
16	F&I 6-Inch Reducer	1 EA	\$	\$
17	F&I 8-Inch Pipe Bends	7 EA	\$	\$
18	Install 1-Inch Water Service	27 EA	\$	\$
19	F&I Fire Hydrant Assembly	2 EA	\$	\$
20	F&I Combination Air Release Valve	1 EA	\$	\$
21	Remove and Replace Curb Return and Access Ramp per Caltrans Standard Plan A88A Modified Case C	2 EA	\$	\$

22	F&I Concrete Sidewalk	1,353	SF	\$	\$
23	F&I Concrete Curb and Gutter	271	LF	\$	\$
24	R&R Concrete Residential Drive Approach	1	EA	\$	\$
25	F&I AC Trench Patch	1,380	LF	\$	\$
26	F&I AC Replacement at Gutter Pan	406	LF	\$	\$
27	Replace Striping	1	LS	\$	\$
TOTAL:				\$	

Note: The representations made herein are made under penalty of perjury. Any information contained in the bid which is proven false shall be considered nonresponsive and this bid shall be rejected.

Bid Bond

We, _____

as Contractor, and _____

as Surety, jointly and severally, bind ourselves, our heirs, representatives, successors and assigns, as set forth herein, to the **City of Los Banos** (herein called "Owner") for payment

of the penal sum of _____

_____ Dollars (\$_____),

lawful money of the United States. Contractor has submitted the accompanying bid proposal

for the construction of: **IDAHO AVENUE WATERLINE REPLACEMENT**

If the Contractor is awarded the contract and enters into a written agreement, in the form prescribed by the Owner, at the price designated by Bid Schedule, and files a payment bond and performance bond with the Owner, or substitute security in lieu thereof, in the time and manner specified by the Owner, and carries all insurance in type and amount which conforms to the General Provisions, Special Provisions, and Technical Specifications in these Contract Documents and furnishes required certificates and endorsements thereof, then this obligation shall be null and void; otherwise it shall remain in full force and effect.

Forfeiture of this bond, or any deposit made in lieu thereof, shall not preclude the Owner from seeking all other remedies provided by law to cover losses sustained as a result of the Contractor's failure to do any of the foregoing.

Contractor and Surety agree that if the Owner is required to engage the services of an attorney in connection with the enforcement of this bond, each shall pay Owner's reasonable attorney's fees incurred with or without suit.

Executed on _____, 20

Contractor

(Seal if Corporation)

By: _____

Title _____

[SIGNATURE SHEET CONTINUES ONTO NEXT PAGE]

Any claims under this bond may be addressed to:

_____ (name and address of Surety)

_____ (name and address of Surety's agent for service of process in California, if different from above)

_____ (phone number of Surety's agent in California)

(Attach Acknowledgment)

Surety

By _____
(Attorney-in-Fact)

Notice: No substitution or revision to this bond form will be accepted. Sureties must be authorized to do business in and have an agent for service of process in California.

All bond forms must be acknowledged before a Notary Public by both the Contractor and the Surety. Attorneys-in-fact who sign bond forms must file with each bond a certified and effective dated copy of their power of attorney.

Agreement

SAMPLE

Note: Particulars left blank in this sample will be filled with project specific information as outlined in these bid documents.

THIS Agreement is dated as of the _____ day of _____ in the year 20__ by and between the **City of Los Banos, a California municipal corporation** ("Owner") and [ENTER NAME AND TYPE OF ENTITY] ("Contractor").

Owner and Contractor, in consideration of the mutual covenants hereinafter set forth, agree as follows:

1. WORK. Contractor shall complete the work indicated in Owner's Contract Documents entitled "IDAHO AVENUE WATERLINE REPLACEMENT."

The work is generally described as follows:

Construction of the installation of approximately 900 linear feet of 8-inch waterline on Idaho Avenue from L Street to J Street to increase flows in the area. The installation of the new pipe on Idaho Avenue will connect to an existing 6-inch line at J Street and a 10-inch line at L Street. Residential service laterals and water valves shall also be replaced. The work also includes a partial removal and replacement of sidewalk, curb and gutter, and the asphalt above proposed underground improvements. Additionally, two ADA ramps will be installed at the corners of Idaho Avenue and K Street, and Idaho Avenue and J Street. The existing 4-inch waterline on Idaho Avenue shall be abandoned in place.

- Contractor shall furnish all of the material, supplies, tools, equipment, labor and other services necessary for the construction and completion of the work described herein.

2. CONTRACT TIME. Contractor shall commence the work required by the Contract Documents within 10 calendar days after the date of the Notice to Proceed and will complete the same within the time period set forth in the bid, unless the period for completion is extended otherwise by the Contract Documents.

3. LIQUIDATED DAMAGES. Owner and Contractor recognize that time is of the essence of this Agreement and that Owner will suffer financial loss if the work is not completed within the time specified in Paragraph 2 herein, plus any extensions thereof allowed in accordance with Paragraph 21, Time for Completion and Liquidated Damages, of the General Provisions. The parties also recognize the delays, expense and difficulties involved in proving in a legal proceeding the actual loss suffered by Owner if the work is not completed on time. Accordingly, instead of requiring any such proof, Owner and Contractor agree that as liquidated damages for delay (but not as a penalty) Contractor shall pay Owner Eight Hundred Dollars (\$ 800.00) for each day that passes after the time specified in Paragraph 2 herein.

4. CONTRACT PRICE. Owner shall pay Contractor for completion of the work in accordance with the Contract Documents in current funds the amount set forth in the Bid Schedule(s). The Contractor agrees to perform all of the work described in the Contract Documents for the unit and lump sum prices set forth in the Bid Schedule(s).

5. PAYMENT PROCEDURES. Contractor shall submit applications for payment in accordance with Paragraph 24, Progress Estimates, of the General Provisions. Applications for payment will be processed by Owner as provided in the General Provisions.

6. CONTRACT DOCUMENTS. The Contract Documents which comprise the entire agreement between Owner and Contractor concerning the work consists of this Agreement and the following attachments to this Agreement:

- (A) Advertisement for Bids
- (B) Information for Bidders
- (C) Bid
- (D) Bid Bond
- (E) Agreement
- (F) Payment Bond
- (G) Performance Bond
- (H) Notice of Award
- (I) Notice to Proceed
- (J) Change Order
- (K) General Provisions
- (L) Special Provisions
- (M) Technical Specifications prepared by Provost & Pritchard Consulting Group entitled "IDAHO AVENUE WATERLINE REPLACEMENT", dated January, 2019.
- (N) Drawings prepared by Provost & Pritchard Consulting Group numbered 1 through 7.
- (O) Addenda
No. _____, dated _____ 20__
No. _____, dated _____ 20__

There are no Contract Documents other than those listed in this Paragraph 6. The Contract Documents may only be amended by change order as provided in Paragraph 19, Changes in the Work, of the General Provisions.

7. MISCELLANEOUS.

A. Terms used in this Agreement which are defined in Paragraph 1 of the General Provisions will have the meanings indicated in the General Provisions.

B. No assignment by a party hereto of any rights under or interests in the Contract Documents will be binding on another party hereto without the written consent of the party sought to be bound; and specifically but without limitation monies that may become due and monies that are due may not be assigned without such consent (except to the extent that the effect of this restriction may be limited by law), and unless specifically stated to the contrary in any written consent to an assignment, no assignment will release or discharge the assignor from any duty or responsibility under the Contract Documents.

C. Owner and Contractor each binds itself, its partners, successors, assigns and legal representatives to the other party hereto, its partners, successors, assigns and legal representatives in respect of all covenants, agreements and obligations contained in the Contract Documents.

D. The Laws of the State of California shall govern this Agreement. Venue is Merced County. The provisions of this paragraph shall survive expiration or other termination of

this Agreement regardless of the cause of such termination.

E. All bids become property of the Owner. All bids, including the accepted bid and any subsequent contract become public records per the requirements of the California Government Code, Sections 6250-6270, "California Public Records Act". Proprietary material must be clearly marked as such. Pricing and service elements of the successful bid are not consider proprietary information. The Owner will treat all information submitted in a bid as available for public inspection once the Owner has selected a contractor. If you believe that you have a legally justifiable basis under the California Public Records Act (Government Section 6250 et. seq.) for protecting the confidentiality of any information contained within your bid, you must identify any such information, together with the legal basis of your claim in your bid. In order for the Owner to assess confidentiality of any such information on your behalf, you must request, execute and submit an Owner-prepared written agreement to defend and indemnify the Owner for any liability, costs, and expenses incurred in asserting such confidentiality as part of your bid. The final determination as to whether the Owner will assert your claim of confidentiality on your behalf shall be sole discretion of the Owner.

F. This Agreement shall not be interpreted in favor of any Party by virtue of said Party not having prepared this Agreement.

G. If any time period provided for in this Agreement ends on the day other than a Business Day, the time period shall be extended to the next Business Day.

IN WITNESS WHEREOF, Owner and Contractor have caused this Agreement to be executed the day and year first above written.

Date

By: _____

Authorized Representative of Owner

Title: _____

ATTEST:

Lucille L. Mallonee
City Clerk

APPROVED AS TO FORM:

William A. Vaughn
City Attorney

Date

By: _____

Authorized Representative of Contractor

Title: _____

(Seal if Corporation)

(Attach Notarized Acknowledgement for Authorized Representative of Contractor)

Certificate of Contractor

I, _____
(Name)

certify that I am a/the _____
(Title)

designate sole proprietor, partner in partnership, or corporate officer with Contractor License
Number _____ in the entity named as Contractor in the foregoing Agreement. I
hereby expressly certify that the name of the entity to which I am associated is

(Company Name)

that this entity is in good standing and has complied with all applicable laws and regulations, and
that I have been expressly authorized by the proper parties in this entity to execute the Agreement
on behalf of the above-named entity.

ATTEST:

Signature: _____

This form must be acknowledged before a Notary Public. The acknowledgement must be attached.

Payment Bond

We, _____

as Contractor, and _____

as Surety, jointly and severally, bind ourselves, our heirs, representatives, successors and

assigns, as set forth herein, to the **City of Los Banos** (herein called "Owner") for payment

of the penal sum of _____

_____ Dollars (\$ _____),

lawful money of the United States. Owner has awarded the contract and entered into an

Agreement with the Contractor for the construction of:

IDAHO AVENUE WATERLINE REPLACEMENT

If Contractor or any of his subcontractors fails to pay any of the persons named in Section 3181 of the California Civil Code, or amounts due under the Unemployment Insurance Code with respect to work or labor performed under the contract or during the one-year guarantee period, or for any amounts required to be deducted, withheld, and paid over to the Franchise Tax Board from the wages of employees of the Contractor and his subcontractors pursuant to Section 13020 of the Unemployment Insurance Code, with respect to such work and labor, then Surety will pay the same in an amount not exceeding the sum specified above, and also will pay, in case suit is brought upon this bond, such reasonable attorney's fees as shall be fixed by the court.

This bond shall insure to the benefit of any of the persons named in Section 3181 of the California Civil Code, so as to give a right of action to them or their assigns in any suit brought upon this bond.

Surety agrees that no change, extension of time, alteration, or addition to the terms of the Contract, or the work to be performed, or the Provisions shall in any way affect its obligation on this bond, and it does hereby waive notice thereof.

Contractor and Surety agree that should Owner become a party to any action on this bond that each will also pay Owner's reasonable attorney's fees incurred therein in addition to the above sum.

[SIGNATURE SHEET BEGINS ON NEXT PAGE]

Executed in four original counterparts on: _____, 20____

Contractor

(Seal if Corporation)

By: _____

Title: _____

(Attach Acknowledgment of Authorized Representative of Contractor)

Any claims under this bond may be addressed to:

_____ (name and address of Surety)

_____ (name and address of Surety's agent for service of process in California, if different from above)

_____ (phone number of Surety's agent in California)

(Attach Acknowledgment)

Surety

By _____
(Attorney-in-Fact)

Notice: No substitution or revision to this bond form will be accepted. Sureties must be authorized to do business in and have an agent for service of process in California.

All bond forms must be acknowledged before a Notary Public by both the Contractor and the Surety. Attorneys-in-fact who sign bond forms must file with each bond a certified and effective dated copy of their power of attorney.

Performance Bond

We, _____

as Contractor, and _____

as Surety, jointly and severally, bind ourselves, our heirs, representatives, successors and

assigns, as set forth herein, to the **City of Los Banos** (herein called "Owner") for payment

of the penal sum of _____

_____ Dollars (\$ _____),

lawful money of the United States. Owner has awarded the contract and entered into an

Agreement with the Contractor for the construction of:

IDAHO AVENUE WATERLINE REPLACEMENT

The condition of this obligation is such that if the Contractor shall in all things abide by and well and truly keep and perform the covenants, and agreements in the said Contract Agreement, and any alteration thereof made as therein provided, on his part to be kept and performed at the time and in the manner therein specified, and shall faithfully fulfill the one-year guarantee of all materials and workmanship, and shall indemnify and save harmless the Owner and the Owner's Representative, and their consultants, and each of their directors, officers, employees and agents, as therein stipulated, this obligation shall become null and void, otherwise, it shall be and remain in full force and effect.

This Performance Bond shall remain in full effect during the one-year guaranty period following the completion of the work.

Surety agrees that no change, extension of time, alteration, or addition to the terms of the General Provisions, Special Provisions, and Technical Specifications in these Contract Documents shall in anyway affect its obligation in the bond, and it does hereby waive notice thereof.

Contractor and Surety agree that if the Owner is required to engage the services of an attorney in connection with the enforcement of this bond, each shall pay Owner's reasonable attorney's fees incurred with or without suit, in addition to the above sum.

[SIGNATURE SHEET BEGINS ON NEXT PAGE]

Executed in four original counterparts on : _____, 20____

Contractor

(Seal if Corporation)

By: _____

Title: _____

(Attach Acknowledgment of Authorized Representative of Contractor)

Any claims under this bond may be addressed to:

_____ (name and address of Surety)

_____ (name and address of Surety's agent for service of process in California, if different from above)

_____ (phone number of Surety's agent in California)

(Attach Acknowledgment)

Surety

By _____
(Attorney-in-Fact)

Notice: No substitution or revision to this bond form will be accepted. Sureties must be authorized to do business in and have an agent for service of process in California.

All bond forms must be acknowledged before a Notary Public by both the Contractor and the Surety. Attorneys-in-fact who sign bond forms must file with each bond a certified and effective dated copy of their power of attorney.

Notice of Award

To: _____

Date: _____
Project: _____

The Owner has considered the bid submitted by you for the above described work dated _____, 20____.

You are hereby notified that your bid has been accepted for the unit and lump sum prices set forth in the Bid Schedule totaling \$_____.

You are required by the Information for Bidders to execute the Agreement and furnish the required Contractor's performance bond and payment bond within ten (10) calendar days for the date of this Notice to you.

Before the Notice to Proceed can be issued, all required certificates of insurance, as stated in Section 29 of the General Provisions, and a copy of your Los Banos Business License must be submitted.

If you fail to execute said Agreement and to furnish said bonds within ten days from the date of this Notice, said Owner will be entitled to consider all your rights arising out of the Owner's acceptance of your bid as abandoned and as a forfeiture of your Bid Bond. The Owner will be entitled to such other rights as may be granted by law.

You are required to return an acknowledged copy of this Notice of Award to the Owner.

Owner

By _____

Title _____

ACCEPTANCE OF NOTICE

Receipt of the above Notice of Award is hereby acknowledged by

(Name of Contractor)

this _____ day of _____, 20____

By _____

Title _____

Notice to Proceed

To: _____

Date: _____
Project: _____

You are hereby notified to commence work in accordance with the Agreement dated _____, 20_____, on or before _____20_____, and you are to complete the work by _____, 20_____.

You are required to return an acknowledged copy of this Notice to Proceed to the Owner.

Owner

By _____

Title _____

ACCEPTANCE OF NOTICE

Receipt of the above Notice to Proceed is hereby acknowledged by

(Name of Contractor)

this _____ day of _____, 20_____

By _____

Title _____

Change Order

Order No. _____

Date: _____

Agreement Date: _____

Project: _____

Owner: _____

Contractor: _____

The following changes are hereby made to the Contract Documents:

Justification:

Change to Contract Price:

Original Contract Price: \$ _____

Current Contract Price adjusted by previous
Change Order: \$ _____

The Contract Price due to this Change Order
will be (increased) (decreased) by: \$ _____

The new Contract Price including this
Change Order will be: \$ _____

Change to Contract Time:

The Contract Time will be (increased) (decreased) by
calendar days. _____

The date for completion of all work will be: _____

The undersigned hereby agrees to the above-described amendment of the Agreement.

Contractor

Owner

This Change Order shall become a part of the Contract Documents only upon signature of both parties.

General Provisions

1. Terms and Definitions

Wherever used in the Contract Documents, the following terms shall have the meanings indicated, which shall be applicable to both the singular and plural thereof:

Addenda - Written or graphic instruments issued prior to the execution of the Agreement which modify or interpret the Contract Documents, by additions, deletions, clarifications or corrections.

ANSI – American National Standards Institute, current designation as of the Bid date unless otherwise indicated.

ASME – American Society of Mechanical Engineers, current designation as of the Bid date unless otherwise indicated.

ASTM – American Society for Testing Materials, current designation as of the Bid date unless otherwise indicated.

AWWA – American Water Works Association, current designation as of the Bid date unless otherwise indicated.

Bid - The offer or proposal of the bidder submitted on the prescribed form setting forth the prices for the work to be performed.

Bidder - Any person, firm or corporation submitting a bid for the work.

Bonds - Bid, Performance and Payment Bonds and other instruments of security, furnished by the Contractor and his surety in accordance with the Contract Documents.

Change Order - A written order to the Contractor authorizing an addition, deletion or revision in the work within the general scope of the Contract Documents, or authorizing an adjustment in the contract price or contract time.

Completion - That date as certified by the Engineer when the construction of the project or a specified part thereof is sufficiently completed, in accordance with the Contract Documents, so that the project or specified part can be utilized for the purposes for which it is intended.

Contract Documents - the contract, including Advertisement for Bids, Information for Bidders, Bid, including Bid Representations and Certifications, Bid Bond, Agreement, Payment Bond, Performance Bond, Notice of Award, Notice to Proceed, Change Order, General Provisions, Special Provisions, Technical Specifications, Drawings, and Addenda.

Contract Price – The total monies payable to the Contractor under the terms and conditions of the Contract Documents.

Contract Time – The number of calendar or working days as stated in the Contract Documents for the completion of the work.

Contractor – The person, firm or corporation with whom the Owner has executed the Agreement.

Drawings – The part of the Contract Documents which shows the characteristics and scope of the work to be performed and which have been prepared or approved by the Engineer.

Engineer – City Engineer of the City of Los Banos, acting either directly or through properly authorized agents, such agents, acting within the scope of the particular duties entrusted to them.

Field Order – A written order effecting a change in the work not involving an adjustment in the contract price or an extension of the contract time, issued by the Engineer to the Contractor during construction.

IEEE – Institute of Electrical and Electronics Engineers, current designation as of the bid date unless otherwise indicated.

NEMA – National Electrical Manufacturers Association, current designation as of the bid date unless otherwise indicated.

Notice of Award – The written notice of the acceptance of the Bid from the Owner to the successful bidder.

Notice to Proceed – Written communication issued by the Owner to the Contractor authorizing him to proceed with the work and establishing the date of commencement of the work.

Owner – City of Los Banos.

Production Data – All illustrations, standard schedules, performance charts, instructions, brochures, diagrams and other information furnished by the Contractor to illustrate a material, product or system for some portion of the work.

Project – The undertaking to be performed as provided in the Contract Documents.

REA – Rural Electrification Association, current designation as of the bid date unless otherwise indicated.

Samples – Physical examples which illustrate materials, equipment or workmanship, and establish standards by which the work will be judged.

Shop Drawings – All drawings, diagrams, schedules and other data which are specifically prepared for the work by the Contractor, a subcontractor, manufacturer, supplier or distributor, to illustrate some portion of the work.

Specifications – A part of the Contract Documents consisting of written descriptions of a technical nature of materials, equipment, construction systems, standards and workmanship.

Standards - City of Los Banos Standard Specifications, The Standard Specifications of the Department of Transportation of the State of California (Caltrans) dated 2010 and subsequent updates to that 2010 edition, and The Standard Plans of the Department of Transportation of the State of California (Caltrans) dated 2010 and subsequent updates to this 2010 edition.

Subcontractor – An individual, firm or corporation having a direct contract with the Contractor or with any other subcontractor for the performance of a part of the work at the site.

Supplier – Any person or organization who supplies materials or equipment for the work, including that fabricated to a special design, but who does not perform labor at the site.

Work – All labor necessary to produce the construction required by the Contract Documents, and all materials and equipment incorporated or to be incorporated in the project.

Written Notice – Any notice to any party of the Agreement relative to any part of this Agreement in writing and considered delivered and the service thereof completed, when posted by certified or registered mail to the said party at his last given address, or delivered in person to said party or his authorized representative on the work.

2. Order of Precedence of Contract Documents

In resolving conflicts resulting from errors or discrepancies in any of the Contract Documents, the order of precedence shall be as follows:

1. Permits from other agencies as may be required by law
2. Change orders
3. Agreement
4. Addenda
5. Contractor's Bid (Bid Form)
6. Advertisement for Bids
7. Information for Bidders
8. Supplementary General Conditions
9. General Provisions
10. Special Provisions
11. Technical Specifications
12. Drawings
13. Referenced Standard Specifications

If the conflicts cannot be resolved by the precedence prescribed above, the most stringent requirements shall prevail.

3. Venue

Contractor, and any subcontractor, supplier and any other person or organization performing any part of work, agree that each of them will waive jurisdiction and venue and shall submit to the jurisdiction of the courts of the State of California in the County of Merced, regardless of residence or domicile, with respect to any actions or suits at law or in equity arising under or related to the bidding, award or performance of the work or with regard to any matter whatsoever arising out of or relating to the validity, construction, interpretation or reinforcement of the Agreement as against Owner or any of their consultants, and/or any of their respective directors, officers, employees, representatives or agents.

4. Giving Notice

Whenever any provision of the Contract Documents requires the giving of written notice, it will be deemed to have been validly given if delivered in person to the individual or to a member of the firm or to an officer of the corporation for whom it is intended, or if delivered at or sent by registered or certified mail, postage prepaid, to the last business address known to the giver of the notice.

5. Cumulative Remedies

The duties and obligations imposed by these General Provisions and the rights and remedies available hereunder to the parties hereto, and, in particular but without limitation, the warranties, guarantees and obligations imposed upon Contractor by the General Provisions and all of the rights and remedies available to Owner thereunder are in addition to, and are not to be construed in any way as a limitation of, any rights and remedies available to any or all of them which are otherwise imposed or available by laws or regulations, by special warranty or guarantee or by other provisions of the Contract Documents, and the provisions of this paragraph will be as effective as if repeated specifically in the Contract Documents in connection with each particular duty, obligation, right and remedy to which they apply.

6. Non-discrimination

During the performance of the project, Contractor and subcontractors shall not unlawfully discriminate

against any employee or applicant for employment because of race, color, ancestry, religion, sex, national origin, marital status, age, medical condition (cancer related), physical handicap (including AIDS), or sexual orientation. Equal employment extends, but is not limited to recruitment, compensation, benefits, layoff, termination, and all other conditions of employment. Contractor and subcontractors shall ensure that the evaluation/treatment of their employees and applicants for employment are free of such discrimination. Contractor and subcontractors shall comply with the provisions of the Fair Employment and Housing Act (Government Code, Section 12900 et seq.) and the applicable regulations promulgated there under (California Administrative Code, Title 2, Section 7285.0 et seq.). The applicable regulations of the Fair Employment and Housing Commission implementing Government Code, Section 12900, set forth in Chapter 5 of Division 4 of Title 2 of the California Administrative Code and incorporated into this agreement by reference and made a part hereof as if set forth in full.

Contractor and any subcontractors shall give written notice of their obligations under this clause to labor organizations with which they have a collective bargaining or other agreement.

Contractor shall include the nondiscrimination and compliance provisions of the clause in all subcontracts to perform work under the contract.

Contractor shall grant access by representative of the Department of Fair Employment and Housing and the Owner upon reasonable notice at any time during normal business hours, but in no case less than twenty-four (24) hours notice, to such of its books, records, accounts, other sources of information and its facilities as said Owner shall require to ascertain compliance with this clause.

7. Non-discrimination of the Disabled

The Owner will not aid or perpetuate discrimination against a qualified disabled individual by funding as an agency, organization, or person that discriminates on the basis of handicap in providing aid, benefit, or service to beneficiaries of the program or activity. The Owner is committed to provide access to all Owner services, programs, and meetings open to the public for people with disabilities. In this regard the Owner and all of its vendors and Contractor will take all reasonable steps to ensure that disabled individuals have the maximum opportunity for the same level of aid, benefit, or service as any other individual.

8. Additional Instructions and Detail Drawings

The Contractor may be furnished additional instructions and detail drawings by the Engineer, as necessary to carry out the work required by the Contract Documents. The additional drawings and instructions thus supplied will become a part of the Contract Documents. The Contractor shall carry out the work in accordance with the additional detail drawings and instructions.

9. Schedules, Reports and Records

The Contractor shall submit to the Owner such schedules, reports, records and other data as the Owner may request concerning work performed or to be performed.

Prior to the first partial payment estimate, the Contractor shall submit schedules showing the order in which he proposed to carry on the work, including dates at which he will start the various parts of the work, estimated date of completion of each part and, as applicable:

- A. A detailed cost breakdown of the work under each bid item awarded. The breakdown, after receiving favorable review by the Engineer, will become the basis for partial payment determination. Elements of work shall be grouped by building, structure, pipeline, system, etc. Within each grouping, work shall be itemized by readily measurable quantities of work completed in place. For example, concrete should be in units of cubic yard including form work and reinforcing steel. Mobilization costs, bond and insurance costs, and overhead costs shall not be prorated over items of work. In the event the cost breakdown is not favorably reviewed by the Engineer, another cost breakdown shall be submitted that is mutually acceptable to the Contractor and the Engineer.
- B. The dates at which special detail drawings will be required; and respective dates for

submission of shop drawings, the beginning of manufacture, the testing and the installation of materials, supplies and equipment. The Contractor shall also submit a schedule of payments that he anticipates he will earn during the course of the work.

10. Drawings and Specifications

The intent of the drawings and specifications is that the Contractor shall furnish all labor, materials, tools, equipment, and transportation necessary to complete the project in an acceptable manner, ready for use, occupancy or operation by the Owner.

In case of conflict between the drawings and specifications, the specifications shall govern. Figure dimensions on drawings shall govern over scale dimensions and detailed drawings shall govern over general drawings.

Any discrepancies found between the drawings and specifications and site condition or any inconsistencies or ambiguities in the drawings or specifications shall be immediately reported to the Engineer, in writing, who shall promptly correct such inconsistencies or ambiguities in writing. Work done by the Contractor after his discovery of such discrepancies, inconsistencies or ambiguities shall be done at the Contractor's risk.

The Owner will furnish to the Contractor, free of charge, six copies of drawings and specifications for the work. The Contractor shall keep one copy of all current drawings and specifications on the job site, in good order, available to the Engineer and his representatives.

All drawings, specifications, and copies thereof furnished by the Owner are the property of the Owner. They are not to be used on other work, and, with the exception of the signed contract set, are to be returned to the Owner on request, at the completion of the work.

11. Shop Drawings, Production Data and Samples

The Contractor shall review, approve and submit to the Engineer all Shop Drawings, Production Data and Samples as may be necessary for prosecution of the Work and as required by the Contract Documents. The Contractor shall review and approve all Shop Drawings, Production Data and Samples prior to submitting them to the Engineer. By approving and submitting Shop Drawings, Production Data and Samples, the Contractor represents that he has determined and verified all materials, measurements and criteria related thereto, and that he has checked and coordinated the information contained within such submittals with the requirements of the Contract Documents. Any Shop Drawing, Production Data or Sample submitted to the Engineer without having been approved by the Contractor will be returned unreviewed to the Contractor.

For each item where shop drawings, production data or samples are required, the Contractor shall submit a minimum of six approved sets, hard copies, or one set, electronically. The Engineer shall review all shop drawings, production data and samples and retain three sets after his review. The remaining sets shall be returned to the Contractor with actions defined as follows:

- A. NO EXCEPTIONS TAKEN – Accepted subject to its compatibility with future submissions and additional partial submissions for portions of the work not covered in this submission.
- B. MAKE CORRECTIONS NOTED – Same as NO EXCEPTIONS TAKEN except that minor corrections as noted shall be made by the Contractor.
- C. REVISE AND RESUBMIT – Rejected because of major inconsistencies or errors which shall be resolved by the Contractor prior to subsequent review by the Engineer.
- D. REJECTED – Submitted material does not conform to Contract Documents in major respect.

The Engineer's review is only for general conformance with the design concept of the project and general compliance with the information given in the Contract Documents. It shall not include review of quantities, dimensions, weights or gauges, fabrications processes, construction methods, coordination with other trades, or construction safety precautions, all of which are the responsibility of the Contractor.

The Engineer shall not be responsible for any deviations from the Contract Documents not brought to the attention of the Engineer in writing by the Contractor and acknowledged in writing by the Engineer.

Portions of the work requiring shop drawings, production data and samples shall not begin until the submission has been favorably reviewed by the Engineer. A copy of each favorably reviewed shop drawing, product data and sample shall be kept in good order by the Contractor at the site and shall be available to the Engineer.

12. Materials, Services and Facilities

It is understood that, except as otherwise specifically stated in the Contract Documents, the Contractor shall provide and pay for all materials, labor, tools, equipment, water, light, power, transportation, supervision, and all other services and facilities of any nature whatsoever necessary to execute, complete, and deliver the work within the specified time.

Materials and equipment shall be so stored as to insure the preservation of their quality and fitness for the work. Stored materials and equipment to be incorporated in the work shall be located so as to facilitate prompt inspection.

Manufactured articles, materials and equipment shall be applied, installed, connected, erected, used, cleaned and conditioned as directed by the manufacturer.

Materials, supplies and equipment shall be in accordance with samples submitted by the Contractor and reviewed by the Engineer.

Materials, supplies or equipment to be incorporated into the work shall not be purchased by the Contractor or any subcontractor subject to a chattel mortgage or under a conditional sale contract or other agreement by which an interest is retained by the seller.

13. Inspection and Testing

All materials and equipment used in the construction of the project shall be subject to adequate inspection and testing in accordance with generally accepted standards, as required and defined in the Contract Documents.

The Contractor shall provide, at his expense, the necessary testing and inspection services required by the Contract Documents, unless otherwise provided. (See Section 6 of the Special Provisions)

The Owner shall provide all other inspections and testing services not required by the Contract Documents. If the Contract Documents, laws, ordinances, rules, regulations or orders of any public authority having jurisdiction specifically require any work to be inspected, tested, approved by someone other than the Contractor, the Contractor will give the Engineer timely notice of readiness. The Contractor will then furnish the Engineer the required certificates of inspection, testing or approval.

Neither observations by the Engineer nor inspections, tests or approvals by persons other than the Contractor shall relieve the Contractor from his obligations to perform the Work in accordance with the requirements of the Contract Documents.

The Engineer and his representatives will at all times have access to the Work. In addition, authorized representatives and agents of the Owner and appropriate Federal or State agencies shall be permitted to inspect all work, material, payrolls, records of personnel, invoices of materials, and other relevant data and records. The Contractor will provide proper facilities for such access and observation of the Work and also for any inspection or testing thereof.

If any work is covered contrary to the written request of the Engineer, it must, if requested by the Engineer be uncovered of his observation and replaced at the Contractor's expense.

If any work has been covered which the Engineer has not specifically requested to observe prior to it being covered, or if the Engineer considers it necessary or advisable that covered work be inspected or tested by others, the Contractor, at the Engineer's request, will uncover expose or otherwise make available for observation, inspection or testing as the Engineer may require, that portion of the work in question, furnishing all necessary labor, materials, tools, and equipment. If it is found that such work is

not found to be defective, the Contractor will be allowed an increase in the contract price of an extension of the contract time, or both, directly attributable to such uncovering, exposure, observation, inspection, testing and reconstruction and an appropriate change order shall be issued.

14. Substitutions

Whenever a material, article or piece of equipment is identified on the Drawings or Specifications by reference to brand name or catalogue number, it shall be understood that this is referenced for the purpose of defining the performance of other salient requirements and that other products of equal capacities, quality and function shall be considered. The Contractor may recommend the substitution of a material, article or piece of equipment of equal substance and function for those referred to in the Contract Documents by reference to brand name or catalogue number, and if, in the opinion of the Engineer, such material, article, or piece of equipment is of equal substance and function to that specified, the Engineer may approve its substitution and use by the Contractor. The Contractor warrants that if substitutes are approved, no major changes in the function or general design of the project will result. Incidental changes or extra component parts required to accommodate the substitute will be made by the Contractor without a change in the contract price or contract time.

15. Patents

The Contractor shall pay all applicable royalties and license fees. He shall defend all suits or claims for infringement of any patent rights and save the Owner harmless from loss on account thereof, except that the Owner shall be responsible for any such loss when a particular process, design, or the product of a particular manufacturer or manufacturers is specified, but if the Contractor has reason to believe that the design, process or product specified is an infringement of a patent, he shall be responsible for such loss unless he promptly gives such information to the Engineer.

16. Surveys, Permits and Regulations

The Engineer will furnish lines and grades as required for the construction of the work. The Contractor shall make a general check of all lines, dimensions and elevations and shall make all necessary rechecks during the progress of the work to avoid errors in construction. The Contractor shall be responsible for proper dimensions and fittings of all items of work being performed by him. Should any discrepancy be found in lines, dimensions or elevations, they shall be reported to the Engineer immediately.

The Contractor shall protect all existing property and survey monuments, including survey control monuments for this work. The Contractor is responsible for protecting and preserving survey monuments and other survey markers. Any survey monuments damaged as a direct or indirect result of construction activities shall be re-established by a duly licensed land surveyor at the Contractor's sole expense. A corner record shall be filed in accordance with State law for any reset monuments at the Contractor's sole expense.

The Contractor shall carefully preserve benchmarks, reference points and stakes and, in case of willful or careless destruction, he shall be charged with the resulting expense and shall be responsible for any mistakes that may be caused by their unnecessary loss or disturbance.

Permits and licenses of a temporary nature necessary for the prosecution of the work shall be secured and paid for by the Contractor. Permits, licenses and easements for permanent structures or permanent changes in existing facilities shall be secured and paid for by the Owner, unless otherwise specified. The Contractor shall give all notices and comply with all laws, ordinances, rules and regulations bearing on the conduct of the Work as drawn and specified. If the Contractor observes that the Contract Documents are at variance therewith, he shall promptly notify the Engineer in writing, and any necessary changes shall be adjusted as provided in Paragraph 19 of these General Provisions, Changes in the Work.

17. Protection of Work, Property and Persons

The Contractor shall be responsible for initiating, maintaining and supervising all safety precautions and programs in connection with the work. He will take all necessary precautions for the safety of, and shall provide the necessary protection to prevent damage, injury or loss to all employees on the work and

other persons who may be affected thereby, all the work and all materials or equipment to be incorporated therein, whether in storage on or off the site, and other property at the site or adjacent thereto, including trees, shrubs, pavements, roadways, structures and utilities not designated for removal, relocation or replacement in the course of construction.

The Contractor shall comply with all applicable laws, ordinances, rules, regulations and orders of any public body having jurisdiction. He shall erect and maintain, as required by the conditions and progress of the work, all necessary safeguards for safety and protection. He shall notify owners of adjacent utilities when prosecution of the work may affect them. The Contractor shall remedy all damages, injury or loss to any property caused, directly or indirectly, in whole or in part, by the Contractor, any subcontractor or anyone directly or indirectly employed by any of them or anyone for whose acts any of them may be liable, except damage or loss attributable to the fault of the Contract Documents or to the acts or omissions of the Owner or the Engineer or anyone employed by either of them or anyone for whose acts either of them may be liable, and not attributable, directly or indirectly, in whole or in part, to the fault or negligence of the Contractor.

In emergencies affecting the safety of persons or the work or property at the site or adjacent thereto, the Contractor, without special instruction or authorization from the Engineer or Owner, shall act to prevent threatened damage, injury or loss. He will give the Engineer prompt written notice of any significant changes in the work or deviations from the Contract Documents caused thereby, and a change order shall thereupon be issued covering the changes and deviations involved.

18. Supervision by Contractor

The Contractor shall supervise and direct the work. He shall be solely responsible for the means, methods, techniques, sequences and procedures of construction. The Contractor shall employ and maintain on the work, a qualified supervisor or superintendent who shall have been designated in writing by the Contractor as the Contractor's representative at the site. The supervisor shall be present on the site at all times as required to perform adequate supervision and coordination of the work.

19. Changes in the Work

The Owner may at any time, as the need arises, order changes within the scope of the work without invalidating the Agreement. If such changes increase or decrease the amount due under the Contract Documents, or in the time required for performance of the work, an equitable adjustment shall be authorized by written change order.

The Engineer may also, at any time, by issuing a field order, make changes in the details of the work. The Contractor shall proceed with the performance of any changes in the work so ordered by the Engineer unless the Contractor believes that such field order entitles him to a change in contract price or contract time, or both, in which event he shall give the Engineer written notice thereof within seven (7) days after the receipt of the ordered change, and the Contractor shall not execute such changes pending the receipt of an executed change order or further instruction from the Owner.

20. Changes in Contract Price

The contract price may be changed only by a written change order. The value of any work covered by a change order or of any claim for increase or decrease in the contract price shall be determined by one or more of the following methods in the order of precedence listed below:

- A. Unit prices previously approved.
- B. An agreed lump sum.
- C. If a lump sum or unit price cannot be mutually agreed upon, the Contractor shall be entitled to the sum of the following costs of doing the extra work:
 1. Direct Labor Costs. Charges for cost of all the labor furnished and used by the Contractor shall be made for manual classifications up to and including general foreman. It will not include charges for assistant superintendents, superintendents, office personnel,

timekeepers, and maintenance and mechanics. The time charged to extra work shall be subject to the daily approval of the Engineer and evidence of such daily approval shall be submitted with the billing. Labor rates used to calculate the costs shall be those so designated in the Advertisement for Bids. No time or charges will be allowed, except when the men are actually engaged in the proper, efficient, and diligent performance or completion of the extra work as authorized. Overtime shall not be worked without prior approval by the Engineer.

2. Equipment Costs. Charges for the rental and operation of the equipment furnished and used by the Contractor shall be made for all prime construction and automotive equipment. It will not include charges for equipment or tools with a new cost of \$1,000.00 or less. Equipment time charges must be subject to the daily approval submitted with the billing. The equipment rental and operation rates used shall be those agreed upon by the Engineer and the Contractor prior to commencement of the extra work. No time or charges will be allowed except when equipment is actually being used for the proper and efficient performance or completion of the extra work as authorized.

3. Material Costs. Charges for the cost of materials furnished by the Contractor shall be made providing such furnishing was specifically authorized in the extra work order and the actual use verified by the Engineer. Charges must be net cost to the Contractor delivered at the job, and vendor's invoice must accompany the billing along with verification of use of such materials by the Engineer.

4. Tools, Supplies, Overhead, Supervision and Profit. A charge for tools, supplies, overhead, supervision and profit will be allowed in the amount of 15% of the Total Direct Labor Costs, and Material Costs, as defined above.

Any extra work performed hereunder shall be subject to all of the provisions of the contract and the Contractor's sureties shall be bound with reference thereto as under the Contract.

21. Time for Completion and Liquidated Damages

The date of beginning and the time for completion of the work are essential conditions of the Contract Documents and the work embraced shall be commenced on a date specified in the Notice to Proceed.

Time is of the essence in this Agreement. The Contractor shall proceed with the work at such a rate of progress to ensure full completion within the contract time. It is expressly understood and agreed, by and between the Contractor and the Owner, that the contract time for the completion of the work described herein is a reasonable time.

The parties hereto agree that it is extremely difficult and impractical in this case to determine the actual damages the Owner will suffer if the Contractor fails to complete the work within the contract time and for said reason, if the Contractor shall fail to complete the work within the contract time, or extension of time granted by the Owner, then the Contractor will pay to the Owner the amount for liquidated damages as specified in the Agreement for each calendar day that the Contractor shall be in default after the time stipulated in the Contract Documents. The time for completion of the work shall be extended, and the Contractor shall not be charged with liquidated damages or any excess cost when the delay in completion of the work is due to the following, and the Contractor has promptly given written notice of such delay to the Engineer:

- A. To any preference, priority or allocation order duly issued by the Owner.
- B. To unforeseeable caused beyond the control and without the fault or negligence of the Contractor, including but not restricted to, acts of God or of the public enemy, acts of the Owner, acts of another contractor in the performance of a contract with the Owner, fires, floods, epidemics quarantine restrictions, strikes, freight embargoes, and climatic conditions which, in the opinion of the Engineer, make prosecution of the work unreasonably difficult.
- C. To any delays of subcontractors occasioned by any of the causes specified in the above

paragraphs.

22. Correction of Work

The Contractor shall promptly remove from the premises all work rejected by the Engineer for failure to comply with the Contract Documents, whether incorporated in the construction or not, and the Contractor shall promptly replace and re-execute the work in accordance with the Contract Documents and without expense to the Owner and shall bear the expense of making good all work of other contractors destroyed or damaged by such removal or replacement.

23. Suspension of Work, Termination and Delay

The Owner may, at any time and without cause, suspend the work or any portion thereof for a period of not more than ninety days, or such further time as agreed upon by the Contractor, by written notice to the Contractor and the Engineer, which notice shall fix the date on which work shall be resumed. The Contractor will resume that work on the date so fixed. The Contractor will be allowed an increase in the contract price or an extension of the contract time, or both, directly attributable to any such suspension.

If the Contractor is adjudged as bankrupt or insolvent, or if he makes a general assignment for the benefit of his creditors, or if a trustee or receiver is appointed for the Contractor or for any of his property, or if he files a petition to take advantage of any debtor's act or to reorganize under the bankruptcy or applicable laws, or if he repeatedly fails to supply sufficient skilled workmen or suitable materials or equipment, or if he fails to make prompt payments to subcontractors or for labor, materials or equipment or if he disregards laws, ordinances, rules, regulations or orders of any public body having jurisdiction over the work or if he disregards the authority of the Engineer, or if he otherwise violates any provision of the Contract Documents, then the Owner may, without prejudice to any other right or remedy and after giving the Contractor and his surety a minimum of ten (10) days from delivery of a written notice, terminate the services of the Contractor, and finish the work by whatever method he may deem expedient. In such case the Contractor shall not be entitled to receive any further payment until the work is finished. If the unpaid balance, the Contractor shall pay the difference to the Owner. Such costs incurred by the Owner will be determined by the Engineer and incorporated in a change order.

Where the Contractor's services have been so terminated by the Owner, said termination shall not affect any right of the Owner against the Contractors then existing or which may thereafter accrue. Any retention or payment of monies by the Owner due the Contractor will not release the Contractor from compliance with the Contract Documents.

After ten (10) days from delivery of a written notice to the Contractor and the Engineer, the Owner may without cause and without prejudice to any other right or remedy, elect to abandon the project and terminate the contract. In such case, the Contractor shall be paid for all work executed and any expense sustained plus reasonable profit.

If, through an act or fault of the Contractor, the work is suspended for a period of more than ninety (90) days by the Owner or under an order of court or other public authority, or the Engineer fails to act on any request for payment within thirty (30) days after it is submitted, or the Owner fails to pay the Contractor substantially the sum approved by the Engineer or awarded by arbitrators within thirty (30) days of its approval and presentation, then the Contractor may, after the (10) days from delivery of a written notice to the Owner and the Engineer stop the work until he has been paid all amounts then due, in which event and upon resumption of the work, change orders shall be issued for adjusting the contract price or extending the contract time or both to compensate for the costs and delays attributable to the stoppage of the work.

24. Progress Estimates

On or about the last day of the calendar month, the Contractor will, except as hereinafter provided, make in writing and certify to the Owner an estimate which, in his opinion, is just and fair of the amount and value of the work completed by the Contractor up to that time in the performance of the contract. In case of work for which unit prices are named in the contract, the estimate shall be computed on the basis of said unit prices. In the case of work for which a lump sum is named in the contract, the Engineer may

use a breakdown of the lump sum price submitted by the Contractor, provided that such breakdown is submitted within 15 calendar days after the execution of the Agreement in a form acceptable to the Engineer. No payment will be made to the Contractor until such schedule has been submitted to and reviewed by the Engineer. To the figure thus arrived at shall be added any amounts due the Contractor for extra work and the amount of any approved claims for extra costs to the date of the progress estimate the retained percentage hereinafter provided for shall be deducted from the total thus computed; and from the remainder, there shall be further deducted any amounts due the Owner from the Contractor for supplies or materials furnished or services rendered and any other amounts that may be due the Owner under the terms of the contract. In preparing estimates for partial payment, consideration shall be given to delivery on the site of pipe, and fittings which will become a part of the finished construction work and for which payment in full has been made by the Contractor, but no consideration will be given to preparatory work done or other materials on hand. From the balance thus determined shall be deducted the amount of all previous payments and the remainder shall constitute the partial estimate for that month. Such partial estimates shall not be required to be made by strict measurement, but may be made by measurement or by estimation or partly by one method and partly by the other and it shall be sufficient if they are approximate only. Partial estimates may be withheld or reduced if, in the opinion of the Engineer, the Contractor is not diligently and efficiently endeavoring to comply with the intent of the Agreement.

25. Progress Payments

The Owner will make payments on account of the contract as follows: Not later than the 30th day of the month following the month in which the contract is awarded, and the 30th day of each calendar month thereafter, the Owner will pay to the Contractor 95% of the amount earned by the Contractor during the preceding month at the rate of prices set forth in the contract, based on the estimate of the Engineer.

The retention will be held by the Owner until 35 days following filing of the Notice of Completion.

26. Prompt Payment

The Contractor shall promptly pay all subcontractors and suppliers within ten (10) days of receipt of any progress payment, final payment or retention paid by the Owner to the Contractor. Contractor shall advise all subcontractors and suppliers that all second-tier subcontractors and suppliers must be paid within then (10) days of their receipt of payment from the Contractor.

27. Acceptance and Final Payment

Upon receipt of written notice from the Contractor that the work is ready for final inspection and acceptance, the Engineer will promptly make such inspection, and when he finds the work acceptable under the contract, and the contract fully performed, he will promptly issue a final certificate, over his own signature, stating that the work required by this contract has been completed. The Owner then shall issue a formal Notice of Completion, and the entire balance found to be due shall be paid to the Contractor by the Owner 35 days from the date of recording by the Owner of the Notice of Completion of all work covered by this contract.

Before issuance of the Notice of Completion, the Contractor shall submit evidence satisfactory to the Owner that all payrolls, material bills, and other indebtedness connected with the work have been paid, or if not paid, then the Contractor shall submit evidence of the status of any unpaid indebtedness.

The making and acceptance of the final payment shall constitute a waiver of all claims by the Owner except the following:

- A. those arising from unsettled liens;
- B. those arising from faulty work appearing within 12 months after the date of filing of the Notice of Completion;
- C. those arising from failure to meet the requirements of the Contract Documents or the specifications; or,

- D. those arising from manufacturers' guarantees.

The acceptance by Contractor of the final payment referred to in this paragraph 27 herein, shall be a release of Owner from all claims of liability to Contractor for anything done or furnished for, or relating to, the work or for any act or neglect of Owner or of any person relating to or affecting the work, except demands against Owner for the remainder, if any, of the amounts kept or retained under the provisions of Paragraph 25, Progress Payments, herein; and excepting pending, unresolved claims.

28. Quantities and Unit Prices

The quantities noted in the schedule are approximation for comparing bids, and no claim shall be made against the Owner for excess or deficiency therein. Payment at the unit prices set forth in the schedule will constitute payment in full for the completed work and will include materials, supplies, labor, tools, machinery, and all other expenditures incident to satisfactory compliance with the contract, unless otherwise specifically provided.

The quantities of work performed will be computed for payment by the Engineer on the basis of measurements taken by the Engineer, and these measurements shall be final and binding.

29. Insurance

The Contractor shall not commence work under this Agreement until he has obtained all the insurance required under this section and such insurance has been approved by the Owner, nor shall the Contractor allow any subcontractor to commence work on his subcontract until the insurance required of the subcontractor has been so obtained and approved. All insurance required under this section shall be maintained at the expense of the Contractor continuously during the life of the contract up to the date of acceptance of the work by the Owner.

Commercial General Liability and Automobile Liability Insurance – The Contractor shall provide and maintain the following commercial general liability and automobile liability insurance:

- A. Coverage – Coverage for commercial general liability and automobile liability insurance shall be at least as broad as the following:
1. Insurance Services Office Commercial General Liability coverage (Occurrence Form CG 0001)
 2. Insurance Service Office Form Number CA 0001 (ed. 1/87) covering Automobile Liability, Code 1 (any auto)
- B. Limits – The Contractor shall maintain limits no less than the following:
1. General Liability – Two million dollars (\$2,000,000) per occurrence for bodily injury, personal injury and property damage. If Commercial General Liability Insurance or other form with a general aggregate limit is used, either the general aggregate limit shall apply separately to the project/location (with the ISO CG 2501 or insurer's equivalent endorsement provided to the Owner) or the general aggregate limit shall be twice the required occurrence limit.
 2. Automobile Liability – One million dollars (\$1,000,000) per accident for bodily injury and property damage combine single limit.
- C. Required provisions – The general liability and automobile liability policies are to contain, to be endorsed to contain the following provisions:
1. The Owner and its directors, officers, employees, agents and volunteers are to be covered as insured as respects: liability arising out of activities performed by or on behalf of the Contractor, products and completed operations of the Contractor, premises owned, occupied or used by the Contractor, or automobiles owned, leased, hired or borrowed by the Contractor. The coverage shall contain no special

limitations on the scope of protection afforded to the Owner and its directors, officers, employees, agents, and volunteers.

2. For any claims related to this work, the Contractor's insurance shall be the primary insurance as respects the Owner and its directors, officers, employees, agents and volunteers. Any insurance, pooled coverage or self-insurance maintained by the Owner and its directors, officers, employees, agents and volunteers shall not contribute to it.
 3. Any failure to comply with reporting or other provisions of the policies including breaches of warranties shall not affect coverage provided to the Owner and their directors, officers, employees, agents and volunteers.
 4. The Contractor's insurance shall apply separately to each insured against whom claim is made or suit is brought, except with respect to the limits of the insurer's liability.
 5. Each insurance policy required by this clause shall be endorsed to state that coverage shall not be suspended, voided, canceled by either party, reduced in coverage or in limits except after thirty (30) days prior written notice by certified mail, return receipt requested, has been given to the Owner.
- D. Deductibles and Self-Insured Retentions – Any deductible or self-insured retention must be declared to and approved by the Owner. At the option of the Owner, either the insurer shall reduce or eliminate such deductibles or self-insured retentions.
- E. Acceptability of Insurers – Insurance is to be placed with insurers having a current A.M. Best's rating of no less than A-: VII or equivalent.

Workers' Compensation and Employer's Liability Insurance – The Contractor and all subcontractors shall cover or insure under the applicable laws relating to workers' compensation insurance, all of their employees working on or about the construction site, regardless of whether such coverage or insurance is mandatory or merely elective under law, and the Contractor shall defend, protect and save harmless the Owner and its directors, officers, employees, agents and volunteers from and against all claims, suits, and actions arising from any failure of the Contractor or any subcontractor to maintain such insurance. Before beginning work, Contractor shall furnish to the Owner satisfactory proof that Contractor has taken out for the period covered by the work under this Contract, full compensation insurance for all persons employed directly by Contractor or through subcontractors in carrying out the work contemplated under this Contract, all in accordance with the "Workers' Compensation and Insurance Act," Division IV of the Labor Code of the State of California and any Acts amendatory thereof.

The Contractor shall provide employer's liability insurance in the amount of, at least, \$1,000,000 per accident for bodily injury and disease.

The Contractor shall provide the Owner with a certificate of Workers' Compensation and Employers liability insurance coverage.

In signing the Agreement, Contractor makes the following certification required by Section 1861 of the Labor Code:

"I am aware of the provisions of Section 3700 of the Labor Code which requires each employer to be insured against liability for workmen's compensation or to undertake self insurance in accordance with the provisions of that code, and I will comply with such provisions before commencing the performance of the work of this contract."

Evidences and Cancellation of Insurance – Prior to execution of the Agreement, the Contractor shall file with the Owner evidence of insurance from an insurer or insurers certifying to the coverage of all insurance required herein. Such evidence shall include original copies of the ISO CG 2010 (or insurer's

equivalent) signed by the insurer's representative and certificate of insurance (Accord Form 25-S or equivalent). All evidence of shall be certified by a properly authorized officer, agent or qualified representative of the insurer and shall certify the names of the insured, any additional primary insurers, where appropriate, the type and amount of the insurance, the location and operations to which the insurance applies, the expiration date, and that the insurer will give by certified mail, written notice to the Owner at least thirty (30) days prior to the effective date of any cancellation, lapse or material change in the policy.

The Contractor shall, upon demand of the Owner, deliver to the Owner all such policy or policies of insurance and the receipts for payment of premiums thereon; and should the Contractor neglect to obtain and maintain in force any such insurance or deliver such policy or policies and receipts to the Owner, then it shall be lawful for the Owner to obtain and maintain such insurance, and the Contractor hereby appoints the Owner the true and lawful attorney-in-fact to do all things necessary for this purpose. All money paid by the Owner for insurance premiums under the provisions of this article shall be charged to the Contractor.

30. Contract Security

The Contractor shall, within ten (10) days after the receipt of the Notice of Award, furnish the Owner with a performance bond and a payment bond in penal sums equal to 100% of the contract price, conditioned upon the performance by the Contractor of all undertakings, covenants, terms, conditions and agreements of the Contract Documents, and upon the prompt payment by the Contractor to all persons supplying labor and materials in the prosecution of the work provided by the Contract Documents. Such bonds shall be executed by the Contractor and corporate bonding company licensed to transact such business in the state in which the Work is to be performed and named on the current list of "Surety Companies Acceptable Federal Bonds" as published in the Treasury Department Circular Number 570. The expense of these bonds shall be borne by the Contractor. If at any time a surety on any such bond is declared a bankrupt or loses its right to do business in the state in which the work is to be performed or is removed from the list of surety companies accepted on Federal bonds, Contractor shall within ten (10) days after notice from the Owner to do so, substitute an acceptable bond (or bonds) in such form and sum and signed by such other surety or sureties as may be satisfactory to the Owner. The premiums on such bond (s) shall be paid by Contractor. No further payments shall be deemed due nor shall be made until the new surety or sureties shall have furnished an acceptable bond to the Owner.

Attached to the bonds shall be the original, or a certified copy, of the unrevoked appointment, power of attorney, bylaws or other instrument which entitles and authorizes the person to execute the bond to do so, a certified copy of the certificate of authority or the insurer issued by the Insurance Commissioner of the county in which the Owner is located which would state that the certificate of authority of the insurer (the bonding company) has not been surrendered, revoked, cancelled, annulled, or suspended.

The performance bond shall remain in full force and effect during the warranty period of 12 months from the date of acceptance of the work by the Owner.

If requested by the Owner or Engineer, copies of the insurer's most recent annual statement and quarterly statement filed with the Department of Insurance pursuant to Article 10 (commencing with Section 900) of Chapter 1 of Part 2 of Division 1 of the Insurance Code, shall be provided to the Owner or Engineer within 10 calendar days of the insurer's receipt of the request to submit the statements.

31. Assignments

Neither the Contractor nor the Owner shall sell, transfer, assign or otherwise dispose of the contract or any portion thereof, or of his right, title or interest therein, or his obligation thereunder, without written consent of the other party.

32. Indemnification

Contractor shall indemnify and hold harmless and defend the Owner and the Engineer and their directors, officers, employees, agents or volunteers, and each of them from and against:

- A. Any and all claims, demands, causes of action, damages, costs, expenses, losses or liabilities, in law or in equity, of every kind and nature whatsoever for, but not limited to, injury to or death of any person including Owner and/or Engineer and/or Contractor, or any directors, officers, employees, agents volunteers of the Owner, Engineer or Contractor, and damages to or destruction of property of any person, including but not limited to, Owner, Engineer and/or Contractor and their directors, officers, employees, agents or volunteers arising out of or in any manner directly or indirectly connected with the work to be performed under this Agreement, however caused regardless of any negligence of the Owner or the Engineer or their directors, officers, employees, agents, or volunteers, except the sole negligence of willful misconduct or active negligence of the Owner or the Engineer or their directors, officers, employees, agents or volunteers:
- B. Any and all actions, proceedings, damages, costs, expenses, penalties or liabilities in law or equity, of every kind or nature whatsoever, arising out of , resulting from or on account of the violation of any governmental law or regulation, compliance with which is the responsibility of Contractor.

Contractor shall defend, at Contractor's own cost, expense and risk, any and all such aforesaid suits, actions or other legal proceedings of every kind that may be brought or instituted against the Owner and the Engineer or their directors, officers, employees, agents or volunteers.

Contractor shall pay and satisfy any judgment, award or decree that may be rendered against the Owner and their directors, officers, employees, agents, or volunteers in any such suit, action or other legal proceedings.

Contractor shall reimburse the Owner and their directors, officers, employees, agents and/or volunteers, for any and all legal expenses and costs incurred by them in connection therewith or in enforcing the indemnity herein provided.

Contractor agrees to carry insurance for this purpose as set out in the specifications. See Paragraph 29 of these General Provisions for insurance specifications and coverage. Contractor's obligation to indemnify shall not be restricted to insurance proceeds, if any, received by the Owner and the Engineer or their directors, officers, employees, agents and/or volunteers.

33. Separate Contracts

The Owner reserves the right to let other contracts in connection with this project. The Contractor shall afford other contractors reasonable opportunity for the introduction and storage of their materials and the execution of their work, and shall properly connect and coordinate his work with theirs. If the proper execution or results of any part of the Contractor's work depend upon the work of any other contractor, the Contractor shall inspect and promptly report to the Engineer any defects in such work that render it unsuitable for such proper execution and results.

The Owner may perform additional work related to the project by himself, or he may let other contracts containing provisions similar to these. The Contractor will afford the Contractors who are parties to such contracts (or the Owner, if he is performing the additional work himself), reasonable opportunity for the introduction and storage of materials and equipment and the execution of work, and shall properly connect and coordinate his work with theirs.

In the performance of additional work by other contractors or the Owner is not noted in the Contract Documents prior to the execution of the Agreement, written notice thereof shall be given to the Contractor prior to starting any such additional work. If the Contractor believes that the performance of such requires additional expense or entitles him to an extension of the contract time, he may make a claim therefore as provided in Items 19 and 20 of these General Provisions.

34. Subcontracting

The Contractor may utilize the services of specialty subcontractors on those parts of the work which, under normal contracting practices, are performed by specialty subcontractors.

The Contractor shall be fully responsible to the Owner for the acts and omissions of his subcontractors, and of persons either directly or indirectly employed by them, as he is of the acts and omissions of persons directly employed by him.

The Contractor shall cause appropriate provisions to be inserted in all contracts relative to the work to bind subcontractors to the Contractor by the terms of the Contract Documents in so far as applicable to the work of subcontractors and to give the Contractor the same power as regards terminating any subcontract that the Owner may exercise over the Contractor under any provision of the Contract Documents.

Nothing contained in this contract shall create any contractual relation between any subcontractor and the Owner.

Contractor shall include all subcontractors as insured under its policies or shall furnish separate certificates and endorsements for each subcontractor. All coverage for subcontractors shall be subject to all of the requirements stated herein.

35. Employment of Apprentices

The Contractor and any subcontractor under him shall comply with the requirements of Sections 1777.5 and 1777.6 of the Labor Code in the employment of apprentices. The responsibility for compliance with the provisions of said Section 1777.5 for all apprenticeship occupations shall rest with the Contractor. Information relative to apprenticeship standards, wage schedules and other requirements may be obtained from the Division of Apprenticeship Standards, 455 Golden Gate Avenue, San Francisco, California, or from its branch offices.

36. Payment of Prevailing Wages

The Contractor and all subcontractors under him shall pay all laborers, workmen and mechanics on all work included in this contract no less than the general prevailing rate of per diem wages for work performed, (to-wit, within the limits of the City), and no less than the general prevailing rate of per diem wages for legal holiday and overtime work in said locality, which per diem wages shall not be less than the stipulated rate contained in a schedule thereof which has been ascertained and determined by the Council to be the general prevailing rate of per diem wages for each craft or type of workman or mechanic needed to execute this contract, and which is now on file with the City Clerk, as set forth in the Information for Bidders, and by reference it is incorporated herein and made a part hereof.

The Contractor shall forfeit, as a penalty to the Owner, two hundred dollars (\$200.00) for each laborer, workman or mechanic employed for each calendar day or portion thereof such laborer, workman or mechanic is paid less than the said stipulated rates for any work done under this contract by him or by any subcontractor under him in violation of Articles 1 and 2 of Chapter 1 Part 7 of Division 11 of the Labor Code of the State of California, and said sums and amounts which shall have been so forfeited pursuant to the herein paragraph and the said terms of said Labor Code shall be withheld and retained from payments due to the Contractor under said contract, pursuant to this contract and the said terms of said Labor Code; but no sum shall be so withheld, retained or forfeited except from the final payment without a full investigation by either the Division of Labor law Enforcement of the State Department of Industrial Relations or by said Council.

The difference between such stipulated prevailing wage rates and the amount paid to each workman for each calendar day, or a portion thereof, for which each workman was paid less than the stipulated prevailing wage rate shall be paid to each workman by the Contractor. The Contractor shall comply with the provisions of Section 1775 of the Labor Code of the State of California.

The Contractor and his subcontractors shall submit certified payroll information electronically to the Department of Industrial Relations as well as a hard copy of said certified payrolls to the Owner on a monthly basis.

37. Registration to Train Apprentices

Pursuant to Labor Code Section 1777.5, all contractors shall file with the appropriate Joint Apprenticeship Training Committee, a DAS-140 form registering to train apprentices. This requirement to register to train apprentices is mandated by Section 1777.5 whether or not you are signatory to or a party of any approved training program. Only those programs approved by the California Apprenticeship Council are applicable to accept DAS-140 registration forms.

If the contractor is approved to train apprentices, then apprentices must be called in a ratio not less than one apprentice hour for each five journeyman hours.

However, if the entire contract may be completed within 20 working days or the entire contract (nor subcontracts) is less than thirty thousand (\$30,000), then the Contractor is exempt from requesting apprentices under Labor Code Section 1777.5.

In addition, all contractors are required to make appropriate training contributions as set forth in the prevailing wage determination to each appropriate JATC, or in the alternative, to the California Apprenticeship Council. Payments shall be made not less than monthly, calculated and paid by the fifteenth of each month, for work performed that prior month.

The address for the applicable Joint Apprenticeship Training Committee and for the California Apprenticeship Council can be obtained by calling the Division of Apprenticeship Standards.

38. Penalties

Failure to pay the appropriate prevailing wage can result in penalties being assessed as follows:

- A. Up to \$50.00 per day per worker for each and every violation; and,
- B. debarment from future public works for a period not to exceed three years.
- C. \$50.00 per day per worker for each failure to comply with the payment of overtime for all hours worked in excess of 8 in one day or 40 in one week.

Failure to register to train apprentices or failure to pay the appropriate training contribution can result in penalties being assessed as follows:

- A. \$100.00 per day for each day of violation; and,
- B. debarment from future public works for a period not to exceed three years.

39. Engineer's Authority

The Engineer shall act as the Owner's representative. He shall decide questions which may arise as to quality and acceptability of materials furnished and work performed. He shall interpret the intent of the Contract Documents in a fair and unbiased manner. The Engineer will make visits to the site and determine if the work is proceeding in accordance with the Contract Documents.

The Contractor will be held strictly to the intent of the Contract Documents in regard to the quality of materials, workmanship and execution of the work. Inspections may be made at the factory or fabrication plant of the source of material supply.

The Engineer will not be responsible for the construction means, controls, techniques, sequences, procedures, or construction safety.

40. Land and Rights-of-Way

Prior to issuance of the Notice to Proceed, the Owner shall obtain all land and rights-of-way necessary for carrying out and for the completion of the work to be performed pursuant to the Contract Documents, unless otherwise mutually agreed.

The Owner shall provide to the Contractor information which delineates and describes the lands owned and rights-of-way acquired.

The Contractor shall provide, at his own expense and without liability to the Owner, any additional land

and access thereto that the Contractor may desire for temporary construction facilities, or for storage of materials.

41. Warranty and Guarantee

Contractor warrants and guarantees to Owner that all work will be in accordance with the Contract Documents and will not be defective. Prompt notice of defects known to Owner shall be given to Contractor. All defective work, whether or not in place, may be rejected, corrected or accepted as provided in Paragraph 19, Changes in the Work, of these General Provisions. Defective work may be rejected even if approved by prior inspection.

42. One (1) Year Warranty Period

The warranty period shall commence when the Notice of Completion is issued, at notice of beneficial occupancy or at notice of partial utilization of the work to be warranted has been issued, or a later date if so specified in the Agreement, or mutually agreed to, and extend until one (1) year after that date or whatever longer period may be prescribed by laws or regulations or by the terms of any applicable special guarantee or specific provision of the Contract Documents.

43. Correction of Defective Work

If within the designated warranty period, or such longer period as may be required by Laws or Regulations, the work, or any part of the work, is discovered to be defective, Contractor shall promptly, without an adjustment in contract price and in accordance with Owner's written instructions, either correct that defective work, or if it has been rejected by Owner, remove it from the site and replace it with non-defective work. If circumstances warrant it, including but not limited to, in an emergency, Owner may have the defective work corrected or the rejected work removed and replaced. In that event, Contractor shall not be allowed to recover any associated costs, and he shall reimburse Owner for all direct, indirect and consequential costs of Owner, and Owner shall be entitled to an appropriate decrease in contract price, to withhold a set-off against amount recommended for payment, or make a claim on Contractor's bond if Contractor has been paid in full. Where defective work (and damage to other work resulting therefrom) has been corrected, removed or replaced during the warranty period, the one (1) year warranty period with respect to such work will be extended for an additional period of one (1) year after such correction or removal and replacement has been satisfactorily completed.

44. Early Completion

The one (1) year warranty period will not begin until the Notice of Completion is filed. If Contractor completes the work or portions thereof prior to this time, he shall preserve the equipment and/or facilities by developing and implementing a preventive maintenance program in compliance with manufacturer's recommendations to maintain the equipment and/or facilities unless Owner has issued a notice of beneficial occupancy or notice of partial utilization for the warranted work. At start up, Contractor will be required to get his equipment and/or facilities ready to put into service.

45. Extended Warranties and Guarantees

Owner may at its sole discretion extend the one (1) year warranty period up to twenty-four (24) months, in which case Contractor shall maintain the warranties and guarantees. If such extension of the one (1) year warranty period causes an increase in the cost of the warranties and guarantees provided by Contractor, an adjustment in contract price shall be made as provided by the Contract Documents.

46. Arbitration

With the prior approval of the Owner and the Contractor, all claims, disputes and other matters in question arising out of, or relation to, the Contract Documents or the breach thereof, except for claims which have been waived by the making and acceptance of final payment as provided by Item 27 of these General Provisions, may be decided by arbitration in accordance with the Arbitration Rules of the American Arbitration Association. If entered into, the agreement to arbitrate shall be specifically

enforceable under the prevailing arbitration law. The award rendered by the arbitrators shall be final, and judgment may be entered upon it in any court having jurisdiction thereof.

Notice of the request for arbitration shall be filed in writing with the other party to the Contract Documents and with the American Arbitration Association, and a copy shall be filed with the Engineer. The request for arbitration shall set forth specifically the dispute to be arbitrated. Acceptance by the other party of the request to arbitrate shall constitute the agreement to arbitrate and arbitration shall proceed forthwith. No legal proceedings other than to enforce arbitration shall be commenced on any issue covered by the arbitration agreement.

The Contractor shall carry on the work and maintain the progress schedule during any arbitration proceedings, unless otherwise mutually agreed in writing.

47. Taxes

The Contractor shall pay all sales, consumer, use and other similar taxes required by the law of the place where the work is performed.

48. Contractor's Understanding

It is understood and agreed that the Contractor has, by careful examination, satisfied himself as to the nature and extent of the work, the character, quality, and quantity of the materials to be encountered, the character of the equipment and facilities needed preliminary to and during the prosecution of the work, the general and local conditions, and all other matters which can in any way affect the work under this contract. No verbal agreement or conversation with any officer, agent or employee of the Engineer or the Owner, either before or after the execution of this Agreement, shall affect or modify any of the terms or obligations herein contained.

49. Accidents

The Contractor shall provide, at the site, such equipment and medical facilities as are necessary to supply first-aid service to anyone who may be injured in connection with the work. The Contractor must promptly report in writing to the Engineer all accidents whatsoever arising out of, or in connection with the performance of the work, whether on or adjacent to the site which causes death, personal injury, or property damages, giving full details and statements of witnesses. In addition, if death or serious injuries or serious damages are caused, the accident shall be reported immediately by telephone or messenger to both the Engineer and the Owner. If any claim is made by anyone against the Contractor or any subcontractor on account of any accident, the Contractor shall promptly report the facts in writing to the Engineer, giving full details of the claim.

50. Safety and Sanitation

The Contractor shall provide adequate safety and sanitation facilities according to State laws and local ordinances.

The Contractor will assume sole and complete responsibility for job site conditions during the course of construction of the project, including safety of all persons and equipment. This responsibility shall apply continuously and not be limited to normal working hours.

51. Climatic Conditions

The Engineer may order the Contractor to suspend any work that may be subject to damage by climatic conditions. The Contractor may suspend work if climatic conditions are such that the Contractor is unable to work. In such case, the Contractor, within seven days, shall request in writing a change order to extend the contract time.

52. Officials Not To Benefit

No official of the Owner shall receive any benefit that may arise by reason of this contract.

53. Clean-Up

During the progress of the work, the Contractor shall maintain the site and related structures and equipment in a clean, orderly condition and free from unsightly accumulations of rubbish. Upon completion of the work, the Contractor shall remove from the vicinity of the work all plants, buildings, rubbish, unused materials, concrete forms, temporary bridging, and other like material, belonging to him or used under his direction during construction, and in the event of his failure to do so, the same may be removed by the Owner after 10 calendar days notice to the Contractor at the expense of the Contractor, and his surety or sureties shall be liable therefore.

As part of the final clean-up, the Contractor shall dress up and grade the right-of-way to match existing ground surfaces, and shall remove therefrom all weeds and other growth. Where the construction has crossed yards or driveways, they shall be restored to a condition equivalent to the condition existing prior to the construction as determined by the Engineer.

No direct payment will be made to the Contractor for any clean-up work, but all compensation therefore shall be included in the prices bid in the schedule for the various items of work.

54. Notice to Owner

In the event this contract involves digging trenches or excavations that extend deeper than four feet below the surface, the Contractor shall promptly, and before the following conditions are disturbed, notify Owner, in writing, of any:

- A. Material that the Contractor believes may be material that is hazardous waste, as defined in Section 25117 of the Health Safety Code, that is required to be removed to a Class I, Class II, or Class III disposal site in accordance with provisions of existing law;
- B. Subsurface or latent physical conditions at the site differing from those indicated;
- C. Unknown physical conditions at the site of any unusual nature, different materially from those ordinarily encountered and generally recognized as inherent in work of the character provided for in the contract.

Owner shall promptly investigate the conditions. If Owner finds that the conditions do materially so differ, or do involve hazardous waste, and cause a decrease or increase in the Contractor's cost of, or the time required for, performance of any part of the work, Owner shall issue a change order under the procedures described in the contract.

In the event a dispute arises between Owner and Contractor whether the conditions materially differ, or involve hazardous waste, or cause a decrease or increase in the Contractor's cost of, or time required for, performance of any part of the work, the Contractor, shall not be excused from any scheduled completion date provided for by the contract, but shall proceed with all work to be performed under the contract. The Contractor shall retain any and all rights provided either by contract or by law which pertain to the resolution of disputes and protests between Contractor and Owner.

55. Payment of Withheld Funds

The Owner shall retain 5% of each payment from Contractor and shall make prompt and regular incremental acceptances of portions, as determined by the Owner, of the agreed upon work, and pay retention to the Contractor based on these acceptances. The Contractor, or subcontractor, shall return all monies withheld in retention from a subcontractor within 30 days after receiving payment for work satisfactorily completed and accepted including incremental acceptances of portions of the contract agreement work by the Owner. Federal law (49CFR26.29) requires that any delay or postponement of payment over 30 days may take place only for good cause and with the Owner's prior written approval. Any violation of this provision shall subject the violating Contractor or subcontractor to the penalties, sanctions and other remedies specified in Section 7108.5 of the Business and Professions Code. These requirements shall not be construed to limit or impair any contractual, administrative, or judicial remedies otherwise available to the Contractor or subcontractor in the event of a dispute involving late payment or nonpayment by the Contractor, deficient subcontract performance, or noncompliance. When the work is

complete, the Owner will issue a Notice of Completion to the County. The Owner will pay all retention funds to the Contractor thirty-five (35) Days after Notice of Completion has been recorded.

56. Storm Water Pollution Prevention Measures

Storm Water Pollution Prevention Measures shall be performed in accordance with the provisions in Section 13-3, "Storm Water Pollution Prevention Plan," of the Standard Specifications.

A. GENERAL

In compliance with the State and Federal regulations regarding storm water management during construction, the Contractor shall not allow any debris, waste materials or pollutants, originating from the Contractor's operations, to enter the storm drainage system, which leads to contamination of local creeks and ponding basins.

The Contractor shall properly dispose of all wastes and excess materials in a legal manner to the satisfaction of the Owner.

B. SELECTIVE BMPS FOR STORM WATER POLLUTION PREVENTION

As applicable to the project or directed by the Engineer, the Contractor shall implement any or all of the following Best Management Practices (BMPs):

1. Material Handling and Storage

a. Nonhazardous Materials

i. Designated Delivery and Storage Area

The Contractor shall propose areas in the vicinity of or within the project site or within the Contractor's staging site, which are suitable for material delivery and storage. To the maximum extent practicable, these areas shall be away from gutters, catch basins, drainage courses or creeks. The Contractor shall submit the proposed areas to and shall obtain the approval from the Engineer in writing prior to bringing in materials.

ii. Storage of Granular Materials

The Contractor shall store granular materials at least ten feet (10') away from any inlet or curb return and shall prevent the granular materials from entering the storm drain system, drainage courses or creeks. During wet weather or when rain is forecast within 24 hours, the Contractor shall cover granular materials with a tarpaulin and surround the material with sandbags or other approved heavy objects.

b. Hazardous Materials

i. Hazardous materials include, but are not limited to, petroleum products, antifreeze, paints, thinners, solvents, pesticides, herbicides and various other toxic chemicals.

ii. The Contractor shall propose, within the project site or the Contractor's staging site, an area that is suitable for hazardous material delivery and storage. To the maximum extent practicable, the area shall be away from inlets, gutters, drainage courses or creeks. The Contractor shall submit the proposed area to and shall obtain approval from the Engineer in writing prior to bringing in hazardous materials.

iii. The Contractor shall label and store all hazardous materials and hazardous wastes in accordance with secondary containment regulations, the City of Los Banos Hazardous Materials Storage Ordinance and all applicable Merced County, State and Federal laws and

regulations.

iv. The Contractor shall keep all hazardous materials or waste in containers and fully covered to avoid contamination of storm runoff.

v. The Contractor shall keep an accurate, up-to-date inventory, including Materials Safety Data Sheets (MSDSs), of hazardous materials and hazardous wastes stored on-site to assist emergency response personnel in the event of a hazardous material incident.

2. Hazardous Material Usage

a. The Contractor shall follow all local, State and Federal policies, laws and regulations governing the use of hazardous materials.

b. The Contractor shall use only Category III pesticides for pest control. If Category III pesticides are unavailable, have been tried but proven ineffective, or when it is necessary to prevent a pest outbreak that poses an immediate threat to public health or significant economic loss, the City may consider allowing the use of Category II pesticides with a dose of up to LD50 (a dose that kills 50 percent of the targeted pest population in the laboratory) provided that the risk to the applicator and impact to the environment can be justified. Use of Category I pesticides is prohibited.

c. Apply pesticides at the appropriate time to maximize their effectiveness and minimize the likelihood of discharging non-degraded pesticides into storm water system, drainage courses and creeks.

d. Mix only as much material as is necessary for treatment. Calibrate application equipment prior to and during use to ensure desired application rate. Do not mix or load pesticides adjacent to storm drain system, drainage courses or creeks.

e. The Contractor shall not overapply herbicides, pesticides or fertilizers and shall follow the manufacturer's instructions regarding uses, protective equipment, ventilation, flammability and mixing of chemicals. Over-application of a pesticide is a "label violation" subject to an enforcement action by the Merced County Agriculture Department.

f. When rain is forecast within 24 hours or during wet weather, the Contractor shall not apply chemicals in outside areas unless otherwise allowed by the Engineer in writing.

3. Integrated Pest Management Methods

The Contractor shall employ, in place of pesticides, integrated pest management methods including:

- a. No control
- b. Physical or mechanical methods
- c. Least toxic chemicals (insecticidal soaps and oil, etc.)

4. Vehicle and Equipment Cleaning, Maintenance and Fueling

a. Cleaning

The Contractor shall not clean or wash vehicles or equipment on-site or in the streets. If allowed by the Engineer in writing, cleaning and washing shall be performed in a designated and bermed area approved by the Engineer using water only. No soaps, solvents, degreasers, steam cleaning equipment or similar methods are permitted. The Contractor shall not allow wash water to flow into streets, gutters, storm drain system, drainage courses or creeks.

b. Maintenance and Fueling

i. The Contractor shall perform maintenance and fueling of vehicles or equipment in a designated, bermed area or over a drip pan that will prevent waste, leaks or spills from entering streets, gutters, storm drain system, drainage courses or creeks.

ii. The Contractor shall inspect all vehicles and equipment arriving on-site for leaking fluids and shall promptly repair leaking vehicles and equipment. Drip pans shall be used to catch leaks until repairs can be made. Shut-off valves on equipment must be working properly.

5. Spill Prevention and Control

a. If hazardous materials are used on the project, the Contractor shall keep a stockpile of spill clean-up materials, such as rags or absorbents, readily accessible on-site.

b. Above-ground storage tanks and their installations shall comply with City, State and Federal requirements.

c. The Contractor shall immediately contain and prevent spills or leaks from entering storm drain system, drainage courses or creeks and shall properly clean up and dispose of the spills or leaks. The Contractor shall not wash the spills or leaks into streets, gutters, storm drain system, drainage courses or creeks and shall not bury the spills or leaks.

d. In case of a hazardous material spillage, the Contractor shall immediately call 911 and shall handle the spilled material in accordance with the requirements of 6, "Disposal of Hazardous Waste," below.

6. Disposal of Hazardous Waste

a. Unless the Contractor is a licensed hazardous waste handler, the Contractor shall contract with a licensed hazardous waste handler to remove and dispose of hazardous waste materials unless the waste quantities to be transported are below threshold limits for transportation as specified in the State and Federal regulations.

b. The Contractor shall arrange for regular hazardous waste collection to comply with limits for storage of hazardous waste.

c. The Contractor may dispose of dry, empty paint cans, buckets, paintbrushes, rollers, rags and drop cloths in the trash.

d. The Contractor shall dispose of hazardous waste at facilities authorized for treatment, storage and disposal of hazardous waste only.

7. Street Sweeping

At the end of each day or as directed by the Engineer, the Contractor shall sweep roadways of all debris and excess materials attributed to the Contractor's operations.

8. Water Usage

a. The Contractor shall use the least amount of water necessary for dust control and street sweeping operations.

b. The Contractor shall not use water to flush dust and debris down the street in place of street sweeping.

9. Dumpsters and Portable Sanitary Facilities

a. If dumpsters or portable sanitary facilities are used, they shall be

stationed at least ten feet (10') away from storm drain facilities.

b. The Contractor shall arrange for regular waste collection to keep dumpsters and portable sanitary facilities from overflowing and shall regularly inspect these facilities for leaks. If a leak is discovered, the Contractor shall arrange for the repair or replacement of facilities that leak. The Contractor shall not wash the dumpsters or portable sanitary facilities on-site.

10. Earthwork

The Contractor shall maximize the control of erosion and sediment by using the Best Management Practices for erosion and sedimentation control described in the California Storm Water Best Management Practice Handbook—Construction Activity or ABAG Manual of Standards for Erosion and Sediment Control Measures.

11. Dewatering

a. The Contractor shall route water through a control device, such as a sediment trap, sediment basin or Baker tank, to remove settleable solids prior to discharging the water into the storm drain system. Refer to the California Storm Water Management Practice Handbook for these sediment control measures.

b. Approval of the control device shall be obtained in advance from the Engineer.

c. Filtration of the water following the control device may be required on a case-by-case basis.

d. If the Engineer determines that the dewatering operation would not generate an appreciable amount of settleable solids, the control device may be waived.

12. Saw Cutting

a. During saw cutting or grinding operation, use as little water as possible.

b. During saw cutting, the Contractor shall cover or barricade catch basins using filter fabric, straw bales, sandbags or fine gravel dams to keep slurry out of the storm drain system. When protecting a catch basin, the Contractor shall ensure that the entire opening of the catch basin is covered. Refer to California Storm Water Best Management Practice Handbook for these control measures.

c. The Contractor shall shovel, absorb or vacuum saw cut slurry and pick up the waste as the work progresses prior to moving to the next location, as specified elsewhere in these specifications or as directed by the Engineer.

d. If saw cut slurry enters catch basins, the Contractor shall, at the Contractor's cost, clean up the storm drain system immediately.

13. Concrete, Grout and Mortar Related Work

a. Material Handling

i. The Contractor shall avoid mixing excess amounts of fresh concrete or cement mortar on-site.

ii. The Contractor shall store concrete, grout and mortar away from storm drain facilities or drainage courses and shall ensure that these materials do not enter the storm drain system.

b. Washing of Concrete Truck and Tools

- i. The Contractor shall not wash out concrete trucks or equipment into streets, gutters, storm drain system, drainage courses or creeks.
- ii. The Contractor shall perform washing of concrete trucks and tools off-site or in a designated area on-site where the water will flow onto dirt or into a temporary pit in a dirt area. The Contractor shall let the water percolate into the soil and dispose of the hardened concrete in a trash container. If a suitable dirt area is not available, the Contractor shall collect the wash water and dispose of it off-site.

14. Asphalt Concrete Paving

a. Project Site Management

- i. When rain is forecast within 24 hours or during wet weather, the Engineer may prevent the Contractor from paving.
- ii. The Engineer may direct the Contractor to protect drainage courses by using earth dike, straw wattle or sandbag to trap and filter sediment. Refer to California Storm Water Best Management Practice Handbook for these control measures.
- iii. The Contractor shall place drip pans or absorbent material under paving equipment when not in use.
- iv. The Contractor shall cover catch basins and manholes when paving or applying prime coat, tack coat, seal coat, fog seal or slurry seal.
- v. If the paving operation includes an on-site mixing plant, the Contractor shall comply with Merced County NPDES General Industrial Activities Storm Water Permit requirements.
- vi. The Contractor shall preheat, transfer or load hot bituminous material away from storm drain system, drainage courses or creeks.

b. Paving Waste Management

The Contractor shall not sweep or wash down excess sand (placed as part of a sand seal or to absorb excess oil) into streets, gutters, storm drain system or creeks but shall collect the sand and dispose of it off-site. The Contractor shall not wash fresh asphalt concrete pavement.

15. Painting

a. General

- i. The Contractor shall remove as much excess paint as possible from brushes, rollers and other tools before starting cleanup.
- ii. The Contractor shall conduct cleaning of painting equipment and tools in a designated area approved by the Engineer.
- iii. The Contractor shall not allow wash water from cleaning of painting equipment and tools into streets, gutters, storm drain system, drainage courses or creeks.

b. Water-Based Paint

To the maximum extent practicable, the Contractor shall dispose of wash water from water cleaning of brushes, rollers and other tools used in water-based painting work to the sanitary sewer or direct wash water onto dirt area and spade in.

c. Oil-Based Paint

The Contractor shall dispose of waste thinner and solvent and sludge from cleaning of brushes, rollers and other tools used in oil-based painting work as hazardous waste and the Contractor shall handle the waste as described in Section 6, "Disposal of Hazardous Waste," above. To the maximum extent practicable, the Contractor shall filter paint thinner and solvents for reuse.

16. Thermoplastic

a. The Contractor shall transfer and load hot thermoplastic away from drainage systems or drainage courses or creeks.

b. The Contractor shall sweep thermoplastic grindings into plastic bags. Yellow thermoplastic grindings may require special handling as they may contain paint.

C. CONTRACTOR TRAINING AND AWARENESS

1. The Contractor shall train all employees and subcontractors on the storm water pollution prevention requirements contained in these specifications.

2. The Contractor shall inform subcontractors of the storm water pollution prevention contract requirements and include appropriate subcontract provisions to ensure that these requirements are met.

3. The Contractor shall post warning signs in areas treated with chemicals.

D. BMP IMPLEMENTATION

The Contractor shall be responsible throughout the duration of the construction period for installing and maintaining the applicable BMPs and for removing and legally disposing of temporary control measures. Unless otherwise directed by the Engineer or specified elsewhere in these specifications, the Contractor's responsibility for BMP implementation shall continue throughout any temporary suspension of work ordered in conformance with the provisions in Section 8-1.06, "Suspensions," of the Standard Specifications.

Throughout the rainy season, all soil-disturbed areas of the site shall be fully protected with soil stabilization and sediment control device approved by the Engineer at the end of the same day the soil is disturbed unless fair weather is predicted the next day and the protective measures are exempt by the Engineer. The Contractor shall monitor the weather forecast on a daily basis and inform the Engineer of the forecast. The National Weather Service forecast shall be used for this purpose. If precipitation is predicted for the following day, construction schedule shall be altered as required to install appropriate BMPs or to ensure that the already installed BMPs are in good operating condition prior to the onset of rain.

E. BMP MAINTENANCE

To ensure proper implementation and effectiveness of the BMPs, the Contractor shall regularly inspect and maintain the deployed BMPs throughout the construction site. The Contractor shall identify corrective actions and the time needed to address any deficient BMPs or reinstate any BMPs that have been discontinued. The Contractor shall keep written records of all BMP inspections, maintenance and corrective actions.

The frequency of the BMP inspection shall be as follows:

1. Prior to a forecast storm;
2. After any precipitation that causes runoff;
3. At 24-hour intervals during extended rain events; and
4. Routinely, at a minimum of once every week.

If the Contractor or the Engineer identifies a deficiency in the deployment or functioning of a BMP, the deficiency shall be corrected immediately. If requested by the Contractor and

approved by the Engineer in writing, the deficiency may be corrected at a later time or date but the corrective action shall not be later than the onset of the subsequent rain event. The correction of deficient BMPs shall be at no additional cost to the City.

F. RESPONSIBILITIES, CONSEQUENCES, AND REMEDIES

1. Conformance with the provisions of this section or other requirements in various other sections of these specifications shall not relieve the Contractor from the Contractor's responsibilities as provided in various relevant articles of Section 7, "Legal Relations and Responsibilities to the Public," of the Standard Specifications, and as specified herein.
2. For purposes of this section, costs and liabilities include, but are not limited to, fines, penalties and damages, whether assessed against the City or the Contractor, including those levied under the Federal Clean Water Act and the State Porter-Cologne Water Act.
3. If solid or liquid materials or waste, hazardous or otherwise, or pollutants originating from the Contractor's operation enter the storm drain system or water courses, the Contractor will be required to thoroughly clean up the affected storm drain facilities and water courses to the satisfaction of the Engineer. If the Contractor fails to clean up the affected facilities as required, the City will issue a stop-work order and take necessary actions to effect the cleanup of the affected facilities.
4. The Contractor shall be responsible for all costs, including fines, the City's cost of defense, the cost of cleanup by others ordered by the City, and liabilities imposed by law as a result of the Contractor's failure or negligence in complying with the requirements specified herein.
5. In accordance with the provisions of Section 7-1.05, "Indemnification," of the standard Specifications if the Contractor fails to accept or reject a tender of defense and indemnity within fifteen (15) calendar days, the City may, in addition to the remedies authorized by law, retain any sum due the Contractor until disposition has been made of all claims or suits for damages or until the Contractor accepts or rejects the tender of defense, whichever occurs first.

G. PAYMENT

Full compensation for storm water pollution control shall be considered as included in the payment for various other items of work and no additional compensation will be made therefore.

Special Provisions

1. Requirements

It is required that there be constructed and completed in accordance with the Contract Documents for "Construction of IDAHO AVENUE WATERLINE REPLACEMENT" for the City of Los Banos, all work as described in these Contract Documents.

2. Description of Work

The principal components of the work to be performed under these Contract Documents include the following:

The major work consists of the installation of approximately 900 linear feet of 8-inch waterline on Idaho Avenue from L Street to J Street to increase flows in the area. The installation of the new pipe on Idaho Avenue will connect to an existing 6-inch line at J Street and a 10-inch line at L Street. Residential service laterals and water valves shall also be replaced. The work also includes a partial removal and replacement of sidewalk, curb and gutter, and the asphalt above proposed underground improvements. Additionally, two ADA ramps will be installed at the corners of Idaho Avenue and K Street, and Idaho Avenue and J Street. The existing 4-inch waterline on Idaho Avenue shall be abandoned in place.

Any incidental work not described in the Contract Documents which is necessary to complete the Work shall be furnished and installed as part of this contract at no additional cost to the Owner. The work shall be complete and ready for service to the satisfaction of the Owner. The Contractor is responsible to inspect the site and observe actual working conditions prior to bidding the project.

3. Commencement, Prosecution and Completion of Work

The Contractor shall commence work and shall complete all of the work in accordance with the schedule and within the time stated in the bid. The capacity of the Contractor's construction plant, sequence of operations, method of operations, and the forces employed shall at all times during the continuance of the contract, be subject to the approval of the Engineer and shall be such as to ensure the completion of the work within the time specified.

4. Hours of Work

Construction work shall be completed between the hours of 7:00 a.m. and 9:00 p.m. Monday through Friday using normal construction practices. No work shall be performed on Saturday or Sunday. The Contractor may request to the Owner to perform construction outside of these specified hours.

5. Permits and Business Licenses

The Contractor will need an Encroachment Permit from the Public Works Department prior to start of construction. The Contractor and all subcontractors working within the city limits of Los Banos shall apply for and have issued a business license from the City of Los Banos (209-827-7000) prior to commencement of work.

6. Testing

Field density tests shall be made of each compacted layer (subbase and aggregate base) as directed by the Engineer. When these tests indicate that the density of any layer of fill or portion thereof is less than the specified density, that layer shall be reworked until the required density has been obtained.

Field density tests (compaction testing) shall be performed by a geotechnical laboratory retained by the Owner and under the supervision of a registered geotechnical engineer.

Initial compaction testing will be paid by the Owner. Retesting of areas that failed the initial testing will be paid for by the Contractor.

7. Responsibility Regarding Existing Utilities and Private Property

The existence and location of public and private utilities indicated on the drawings are not guaranteed and any additional utilities and facilities not shown on the drawings shall be investigated and protected by the Contractor. The Contractor shall be held responsible for damage to and for maintenance and protection of existing pipelines, public utilities, drives, curbs and gutters, sidewalks, and fences. Excavation in the vicinity of existing public utility structures, underground electrical or telephone cable, oil or gas pipelines, and waterlines shall be carefully done by hand. The Contractor shall adequately protect all adjoining property and structures from damage, whether within or without of the Owner furnished rights-of-way, and shall be fully responsible for any damage to adjoining property and structures which may result from work done under this contract. The Contractor shall use extreme care during construction to prevent damage from dust to crops and adjacent property. The Contractor shall sprinkle the areas where the passage of operation of vehicles and equipment creates a dust problem, or take other preventive measures as directed by the Engineer. The Contractor shall furnish all labor, equipment, materials and means required to control dust which is in any way a result of the Contractor's operations.

The Contractor shall be responsible for all damage or injury which may result to any property, outside of the construction right-of-way or within the right-of-way where so noted, from the Contractor's operations hereunder, or otherwise, from the performance of the Agreement by said Contractor or any of his subcontractors or employees.

The Contractor shall attempt to maintain access to the residential and commercial driveways within the construction area at all times during working hours and shall provide access during non-working hours, weekends and holidays.

Payment for all work specified above shall be included in the unit or lump sum prices bid in the schedule for the various items of work.

8. Obstructions

The Contractor shall notify the Engineer and the appropriate regional notification center for operators of subsurface installation at least 3 working days, but not more than 14 calendar days, prior to performing any excavation or other work close to any underground pipeline, conduit, duct, wire or other structure. Failure to contact the notification center prohibits excavation. Regional notification centers include but are not limited to the following:

NOTIFICATION CENTER	TELEPHONE
Underground Service Alert Northern California (USA) www.usanorth811.org	811 or 1-800-227-2600

9. Materials Furnished By Owner

No labor, material, or other facilities shall be provided by the Owner unless otherwise indicated on the drawings or in the Contract Documents.

10. Materials Furnished By Contractor

Unless otherwise stipulated, the Contractor shall provide and pay for all materials, labor, water, tools, equipment, light, power, transportation, and other facilities necessary for the execution and completion of the work.

11. Schedule of Values, Material List and Substitutions

Prior to the commencement of work, and within 10 days following the signing of the contract by the Owner and the Contractor, the Contractor shall submit 2 copies of a Schedule of Values for all lump sum bid items in the Bid Schedule and a *complete* list of equipment and materials to be furnished, including all substitutions proposed to the Engineer for approval. Partial or incomplete material lists will not be considered. No substitutions will be considered thereafter. Only one request for substitution will be considered on each item of material or equipment.

12. Request for Extension of Time

All extension of time requests shall be made in writing to the Engineer within seven (7) calendar days from the delay occurrence date. In the case of continuing cause of delay, only one claim is necessary.

13. Rights-of-Way

The Contractor shall not be entitled to extra compensation for hardships and increased cost caused by the work being adjacent to telephone-telegraph lines and guy wires, power lines and guy wires, buildings, fences, pipelines, ditches, roadways, and other obstacles which may physically restrict or limit the use of construction equipment. In some cases, such physical confinement may necessitate special methods of construction of the work. If the Contractor desires to utilize additional area, he shall obtain the necessary approvals from the landowner. No additional compensation shall be paid to the Contractor for the cost of obtaining additional right-of-way or for the inability to obtain such.

14. Coordination with Other Work

Other work including but not necessarily restricted to relocation of power and telephone poles, installation of a gas line and relocation of water meters may be in progress near or at the construction site at the time the Contractor is in performance of the work specified herein. The Contractor shall coordinate his work with that of others so that prosecution of all work will proceed smoothly.

15. Closure of Streets

The Contractor will be allowed to temporarily close the streets being paved to vehicular traffic between the hours 7:00 a.m. and 5:00 p.m. on the day the streets are being paved. All street closure dates shall be coordinated with and approved by the Engineer for approval no later than 10 working days prior to the earliest proposed closures and detours.

16. Construction Signs, Barricades, Lights and Flagmen

The Contractor shall furnish, erect and maintain adequate barricades, lights, signs and other devices and take other protective measures to prevent damage to the public. The Contractor shall also furnish adequate warning to the public of dangerous conditions to be encountered. Where one lane of a public road is closed, the Contractor shall furnish flagmen at each end of the closed lane to control traffic in the open lane. The Contractor shall also furnish adequate warning to the public of dangerous conditions to be encountered.

Payment for traffic control and other safety measures shall be included in the Traffic Control Plan lump sum price bid in the Bid Schedule.

17. Traffic Control Plan

It is the Contractor's sole responsibility to establish and implement a Traffic Control Plan conforming to Sections 7-1.08, "Public Convenience" 7-1.09, "Public Safety", and Section 12, "Construction Area Traffic Control Devices", of the Caltrans Standard Specifications. Nothing in these Contract Documents shall be construed as relieving the Contractor from his responsibility.

The Traffic Control Plan shall be prepared, stamped and signed by a professional engineer registered in California, and three copies provided to the Engineer before the Contractor is issued a Notice to Proceed.

Payment for the preparation and implementation of the Traffic Control Plan shall be made at the applicable lump sum price bid in the Bid Schedule.

18. Disposal of Waste Materials

Waste material shall be disposed of in accordance with local regulatory requirements. Provide watertight conveyance for liquid, semi-liquid or saturated solids which tend to bleed during transport. Liquid loss from transported materials is not permitted, whether being delivered to construction site or hauled away for disposal. Fluid materials hauled for disposal must be specifically acceptable at selected disposal site.

19. Noise Control

Conduct operations to cause least annoyance to residents in vicinity of work, and comply with applicable local ordinances. Equip compressors, hoists, and other apparatus with mechanical devices necessary to minimize noise and dust. Equip compressors with silencers on intake lines. Equip gasoline or oil-operated equipment with silencers or mufflers on intake and exhaust lines.

20. Water Supply

Water will be available to the Contractor in performance of the work without charge from all Owner fire hydrants. Prior to the use of any hydrant the Contractor shall notify the Owner and obtain and install a meter furnished by the Public Works Department on the fire hydrant. It will be the Contractor's responsibility to convey the water to the work site. Regardless of the method of conveyance chosen, it shall not be cause for closure of any streets nor shall it create a nuisance to nearby residents. An air gap shall be maintained between the hose or pipe discharge to prevent possible backflow in the event of distribution system pressure loss. The Contractor shall pay a One Thousand Dollar (\$1,000) deposit per meter for the use of the fire hydrant meter. The deposit may be refunded in full if the fire hydrant meter is returned undamaged.

21. Notifications

The Owner will notify the Contractor in writing of any non-compliance with the foregoing provisions or of any environmentally objectionable acts and corrective action to be taken. State or local agencies responsible for verification of certain aspects of the environmental protection requirements shall notify the Contractor in writing, through the Owner, of any non-compliance with State or local requirements. The Contractor shall, after receipt of such notice from the Owner or from the regulatory agency through the Owner, immediately take corrective action. Such notice, when delivered to the Contractor or his authorized representative at the site of the work, shall be deemed sufficient for the purpose. If the Contractor fails or refuses to comply promptly, the Owner may issue an order stopping all or part of the work until satisfactory corrective action has been taken. No part of the time lost due to any such stop orders shall be made the subject of a claim for extension of time or for excess costs or damages by the Contractor unless it is later determined that the Contractor was in compliance.

22. Work Not Listed in Proposal

It is the intent of the plans, specifications and contract documents to provide for the construction of completed and finished facilities and works of improvement unless otherwise specifically provided. Except for authorized changes in the work, payment for said complete and finished facilities and works of improvement will be made only on the basis of the contract items of work listed in the proposal. All other work, including the furnishing of plants, labor, materials, tools, equipment, and incidentals, provided for in the plans, specifications and contract documents, or required for the proper completion of the work as a whole, for which no separate payment has been provided shall be a supplementary obligation of the Contractor and payment therefore shall be considered included in the prices paid for the various contract items of work listed in the proposal.

23. Submittals

The Contractor shall submit to the Engineer, a minimum of six sets, hard copies, or one electronic copy of the following submittals for review and approval:

1. Traffic Control Plan
2. Water Pipeline and Appurtenances (Fittings, Tees, Crosses, Service Saddles, Reducers, Bends, Valves, Valve Boxes, Corp Stops, Ball Meter Valve, Water Meter Service Tubing, Water Meter Boxes, Restrained Joints)
3. Tracer Wire
4. Marking Tap

5. Aggregate Base
6. Backfill
7. Concrete Mix Design
8. Asphalt Concrete Mix Design
9. Thermoplastic Paint

Within 10 days after the effective date of the Agreement and before starting to perform any work, the Contractor shall submit to the Engineer for review and approval:

1. A work schedule indicating the times for starting and completing the various stages of the work. No progress payment shall be made to Contractor until an acceptable schedule has been submitted to the Engineer.
2. Traffic Control Plan
3. Notice to Residents in English and Spanish
4. A Schedule of Values - a breakdown of each lump sum price to be used to determine deductive change orders, if necessary.
5. A complete list of equipment and materials to be furnished
6. City of Los Banos Business License for Contractor and all subcontractors

If more than TWO submittals for a single item are required because of incorrect or insufficient data, or the submittal is unacceptable, or because the Contractor wishes to change previously approved material, then all costs incurred by the Owner for the additional review shall be deducted from monies due the Contractor.

A revised work schedule shall be submitted within 5 days of request by the Engineer. No future progress payments shall be made to Contractor until an acceptable schedule has been submitted to Engineer.

24. Bid Item Descriptions

Bid Item 1 – Mobilization/Demobilization: Payment for this item shall include full compensation for all labor, materials, tools, equipment and incidentals making up the cost of mobilization, move-in, move-out, all necessary bonds, insurance, permits, licenses, and fees required during the performance of the work as specified. This item also includes demobilization, including the removal of all equipment, supplies, personnel and incidentals from the project at the end of construction. Payment for mobilization shall be made with the first progress payment and shall not exceed 80 percent of the bid item amount. Payment for demobilization shall be made with the last progress payment and shall not be less than 20 percent of the bid item amount. This bid item will be paid for by Lump Sum.

Bid Item 2 – Site Demolition and Pipeline Protection: Payment under this item shall be considered full compensation for all labor, materials, tools, equipment and incidentals required to complete all miscellaneous facilities or work shown or specified on the plans and specifications, and not specifically included in any other bid item. Included in this bid item shall be, but not necessarily limited to, such items as supporting of poles and protection of other utilities near excavations; verifying the locations of existing utilities, concrete slurry where pipes have four inches or less between them, minor grading to provide or maintain drainage; providing temporary fencing for security; removal and

replacement of existing mailboxes if necessary; removing and replacing other existing improvements as required; tree trimming and/or removal, and/or other operations as set forth and required but not specifically included in another bid item, all in conformance with existing codes and as directed by the Engineer. This bid item will be paid for by Lump Sum, prorated, based on percentage of work completed.

Bid Item 3 – Customer Outreach & Satisfaction: Contractor shall provide two (2) advance written notices to property owners/residents of the impending work and the temporary no-parking restrictions one (1) to two (2) days prior to working in the areas. The notice shall describe the nature of the work, the location and duration of the parking prohibition, and who to call if they have questions during construction. The Contractor shall provide a sample of the notice to the Engineer for approval prior to distribution.

Any complaints received by the City from property owners dissatisfied with the installation shall be corrected by the Contractor before payment is made. Any water tap blockage or leaks caused by the installation of new service lines will be repaired by the Contractor at Contractor's expense. The decision by the city regarding the credibility of an owner's complaint shall be final. The Contractor shall promptly correct any deficiencies, including but not limited to, water leaks that are a direct or indirect result of the installation when directed to do so by the City.

It shall be presumed that any leaks in the vicinity of the water meter reported by the customer to either the City or the Contractor within 30 calendar days after completion of work at the customer's property are the result of the installation work, unless a preexisting condition has been noted on the work order. The Contractor shall repair such leaks and correct all damages which occur during the 30-day period at the Contractor's expense. This bid item will be paid for by Lump Sum.

Bid Item 4 – Traffic Control & General Safety: Payment under this item shall be considered full compensation for all labor, materials, tools, equipment and incidentals required to implement and maintain all temporary traffic control measures. This bid item will be paid for by Lump Sum, prorated, based on percentage of contract work completed.

Bid Item 5 – Sawcut & Remove Existing AC Pavement: Payment for this item shall include full compensation for all labor, materials, tools, equipment and incidentals required to sawcut, remove and dispose of existing asphalt concrete pavement in accordance with the plans and specifications. Bid quantity shown is estimated from approximated dimensions. This bid item will be paid for Per Square Foot.

Bid Item 6 – Sawcut & Remove Existing Sidewalk, Curb & Gutter: Payment for this item shall include full compensation for all labor, materials, tools, equipment and incidentals required to sawcut, remove and dispose of existing concrete curb, gutter and sidewalk, in accordance with the plans and specifications. Bid quantity shown is estimated from approximated dimensions This bid item will be paid for Per Square Foot.

Bid Item 7 – Abandon Existing Water Main: This bid item includes full compensation for all labor, materials, tools, equipment and incidentals making up the cost of all work including water main abandonment and/or removal as needed, including asphalt removal and replacement as described in the

Specifications and shown on the Plans. This bid item will be paid for by Lump Sum, prorated, based on percentage of work completed.

Bid Item 8 – Connection to Existing Water Main: Payment under this item shall be considered full compensation for all labor, materials, tools, equipment and incidentals necessary for connection new water main to existing water main in accordance with the plans and specifications. Included in this bid item shall be all excavation, field verification of pipe size, trench preparation, bedding, backfill, compaction, testing, disinfection, removal of existing pipe, water tight caps/plugs on abandoned lines and other fittings necessary including restraining joints, and all other work necessary to result in a complete and operational water main This bid item will be paid for Per Each.

Bid Item 9 – F&I 8-Inch C-900 DR 14 PVC Water Main: Payment under this item shall be considered full compensation for all labor, materials, tools, equipment and incidentals necessary for furnishing and installing C-900 DR 14 PVC Water Main to the lines and grades shown in accordance with the plans and specifications. Payment for this item shall be made on a Linear Foot basis, and shall include payment for all excavation, trench preparation, bedding, fittings, backfill, disinfection, compaction, testing, worker protection, and other work required to result in a complete and operating water main.

Bid Item 10 – F&I 10x10x8-Inch Tee: Payment under this item shall be considered full compensation for all labor, materials, tools, equipment and incidentals necessary for furnishing and installing crosses and appurtenances in accordance with the plans and specifications. Included in this bid item shall be all excavation, bedding, backfilling, compaction, watering; disinfection, testing and other work required to result in a complete and operational tee as detailed in the plans and specifications. This bid item will be paid for Per Each.

Bid Item 11 – F&I 8x8x6x6-Inch Cross: Payment under this item shall be considered full compensation for all labor, materials, tools, equipment and incidentals necessary for furnishing and installing tees and appurtenances in accordance with the plans and specifications. Included in this bid item shall be all excavation, bedding, backfilling, compaction, watering; disinfection, testing and other work required to result in a complete and operational cross as detailed in the plans and specifications. This bid item will be paid for Per Each.

Bid Item 12 – F&I 6x6x6-Inch Tee: Payment under this item shall be considered full compensation for all labor, materials, tools, equipment and incidentals necessary for furnishing and installing crosses and appurtenances in accordance with the plans and specifications. Included in this bid item shall be all excavation, bedding, backfilling, compaction, watering; disinfection, testing and other work required to result in a complete and operational tee as detailed in the plans and specifications. This bid item will be paid for Per Each.

Bid Item 13 – F&I 8-Inch Gate Valve: Payment under this item shall be considered full compensation for all labor, materials, tools, equipment and incidentals necessary for furnishing and installing gate valve, riser, cover with lid, concrete collar, and all appurtenances in accordance with the plans and specifications. Included in this bid item shall be all excavation, bedding, backfilling, compaction, watering; disinfection, testing and other work required to result in a complete and operational gate valve as detailed in the Plans and Specifications. This bid item will be paid for Per Each.

Bid Item 14 – F&I 6-Inch Gate Valve: Payment under this item shall be considered full

compensation for all labor, materials, tools, equipment and incidentals necessary for furnishing and installing gate valve, riser, cover with lid, concrete collar, and all appurtenances in accordance with the plans and specifications. Included in this bid item shall be all excavation, bedding, backfilling, compaction, watering; disinfection, testing and other work required to result in a complete and operational gate valve as detailed in the plans and specifications. This bid item will be paid for Per Each.

Bid Item 15 – F&I 8-Inch Reducer: Payment under this item shall be considered full compensation for all labor, materials, tools, equipment and incidentals necessary for furnishing and installing reducers and appurtenances in accordance with the plans and specifications. Included in this bid item shall be all excavation, bedding, backfilling, compaction, watering; disinfection, testing and other work required to result in a complete and operational reducer as detailed in the plans and specifications. This bid item will be paid for Per Each.

Bid Item 16 – F&I 6-Inch Reducer: Payment under this item shall be considered full compensation for all labor, materials, tools, equipment and incidentals necessary for furnishing and installing reducers and appurtenances in accordance with the plans and specifications. Included in this bid item shall be all excavation, bedding, backfilling, compaction, watering; disinfection, testing and other work required to result in a complete and operational reducer as detailed in the plans and specifications. This bid item will be paid for Per Each.

Bid Item 17 – F&I 8-Inch Pipe Bends: Payment under this item shall be considered full compensation for all labor, materials, tools, equipment and incidentals necessary for furnishing and installing bends and appurtenances in accordance with the plans and specifications. Included in this bid item shall be all excavation, bedding, backfilling, compaction, watering; disinfection, testing and other work required to result in a complete and operational bends as detailed in the Plans and Specifications. This bid item will be paid for Per Each.

Bid Item 18 – Install 1-Inch Water Service: Payment under this item shall be considered full compensation for all labor, materials, tools, equipment and incidentals necessary for constructing Water Services in accordance with the plans and specifications. Included in this bid item shall be all excavation, trench preparation, bedding, fittings, backfill, compaction, testing, disinfection, and other work required to result in a complete and operating water service. Installation of new meter and meter box in the locations specified on the plans shall be paid for under this bid item. The City will provide the new meter to the Contractor at no cost. This bid item will be paid for Per Each.

Bid Item 19 – F&I Fire Hydrants Assembly: Payment under this item shall be considered full compensation for all labor, materials, tools, equipment and incidentals necessary for furnishing and installing Fire Hydrant Assemblies and all appurtenances in accordance with the plans and specifications. Included in this bid item shall be all excavation, bedding, backfilling, compaction, watering; disinfection, testing and other work required to result in a complete and operational Fire Hydrant Assembly as detailed in the plans and specifications. This bid item will be paid for Per Each.

Bid Item 20 – F&I Combination Air Release Valve: Payment under this item shall be considered full compensation for all labor, materials, tools, equipment and incidentals necessary for furnishing and installing Air Release Valve and all appurtenances in accordance with the plans and specifications. Included in this bid item shall be all excavation, bedding, backfilling, compaction, watering;

disinfection, testing and other work required to result in a complete and operational Air Release Valve as detailed in the plans and specifications. This bid item will be paid for Per Each.

Bid Item 21 – R&R Curb Return and Access Ramp per Caltrans Standard Plan A88A Modified Case C: Payment under this item shall be considered full compensation for all labor, materials, tools, equipment and incidentals required to construct concrete curb return and access ramp per Caltrans Standard Plan A88A Modified Case C to the lines and grades shown and specified. This bid item includes pavement removal, excavation, preparation and compaction of subgrade, furnishing, grading and compacting the granular base material, forming, furnishing the Portland cement concrete, placement, finishing, furnishing and installation of truncated dome material and all other work required to result in a complete concrete curb return. This bid item will be paid for Per Each.

Bid Item 22 – F&I Concrete Sidewalk: Payment under this item shall be considered full compensation for all labor, materials, tools, equipment and incidentals required to construct concrete sidewalk to the lines and grades shown and specified in accordance with the plans and specifications. This bid item includes excavation, preparation and compaction of subgrade, furnishing, grading and compacting the granular base material, forming, furnishing the Portland cement concrete, placement, doweling into existing concrete, finishing and all other work required to result in a complete sidewalk. Bid quantity shown is estimated from approximated dimensions. This bid item will be paid for Per Square Foot.

Bid Item 23 – F&I Concrete Curb and Gutter: Payment under this item shall be considered full compensation for all labor, materials, tools, equipment and incidentals required to construct concrete curbs and gutters to the lines and grades shown and specified in accordance with the plans and specifications. This bid item includes excavation, preparation and compaction of subgrade, furnishing, grading and compacting the granular base material, forming, furnishing and placing the Portland cement concrete, placement, doweling into existing concrete, finishing and all other work required to result in a complete curb and gutter. Bid quantity shown is estimated from approximated dimensions. This bid item will be paid for Per Lineal Foot.

Bid Item 24 – R&R Concrete Residential Drive Approach: Payment under this item shall be considered full compensation for all labor, materials, tools, equipment and incidentals required to construct concrete residential drive approach at the locations and to the lines and grades shown and specified, in accordance with the Plans and Specifications. This bid item includes pavement removal, excavation, preparation and compaction of Subgrade, grading and compacting the granular base material, forming, furnishing and placement of Portland cement concrete, finishing and all other work required to result in a complete drive approach including the curb & gutter. This bid item will be paid for Per Each.

Bid Item 25 – F&I AC Trench Patch: Payment under this item shall be considered full compensation for all labor, materials, tools, equipment and incidentals required to furnish and place Type A asphalt concrete pavement to the lines and grades shown in accordance with the plans and specifications. This bid item will include furnishing the material, placement, compaction, prime coat, asphaltic emulsion coating on vertical surfaces to abut the new pavement, grading and compaction of subgrade, and all other work required to result in an asphalt pavement meeting the requirements of the plans and specifications. The asphalt concrete

pavement for permanent trench resurfacing of utility trenches will be paid for under this bid item. This bid item will be paid for Per Lineal Foot.

Bid Item 26 – F&I AC Replacement at Gutter Pan: Payment under this item shall be considered full compensation for all labor, materials, tools, equipment and incidentals required to furnish and place Type A asphalt concrete pavement to the lines and grades shown in accordance with the plans and specifications. This bid item will include furnishing the material, placement, compaction, prime coat, asphaltic emulsion coating on vertical surfaces to abut the new pavement, grading and compaction of subgrade, and all other work required to result in an asphalt pavement meeting the requirements of the plans and specifications. The asphalt concrete pavement for permanent pavement resurfacing adjacent to new curb and gutter will be paid for under this bid item. This bid item will be paid for Per Lineal Foot.

Bid Item 27 – Replace Striping: Payment under this item shall be considered full compensation for all labor, materials, tools, equipment and incidentals required to furnish and install pavement striping/markings, which may be damaged during construction activities, including removing and disposing of painting pavement striping and markings, and doing all other work necessary to complete the signing and striping installations in accordance with the plans and specifications. This bid item will be paid for by Lump Sum, prorated, based on percentage of work completed.

Technical Provisions



City of
Los Banos
At the Crossroads of California

CITY OF LOS BANOS
PUBLIC WORKS DEPARTMENT

BID SET
TECHNICAL SPECIFICATIONS FOR:
IDAHO AVENUE WATERLINE REPLACEMENT

Prepared By



4701 Sisk Road, Suite 102
Modesto, CA 95356-9320

January 2019



DATE SIGNED January 31, 2019

TABLE OF CONTENTS

DIVISIONS 01 - 40 TECHNICAL SPECIFICATIONS

01 22 00	Explanation of Bid Items
01 57 56	Traffic Control
01 77 00	Contract Closeout
02 01 20	Protection of Underground Facilities & Monuments
02 41 00	Demolition
03 33 15	Concrete Sidewalk, Curb, & Gutter
09 90 00	Painting and Coating (Site)
31 23 17	Trenching Backfilling and Compacting
32 11 23	Aggregate Base
32 12 16	Asphalt Concrete Paving
32 17 23	Traffic Signing Striping and Markings
33 01 00	Pipe & Fittings
33 05 26	Utility Line Marking
33 12 19	Fire Hydrants
33 13 00	Disinfection of Water Distribution System
40 05 23	Valves and Appurtenances

SECTION 01 22 00

EXPLANATION OF BID ITEMS

PART 1 GENERAL

The Contract payment for the specified items of work as set forth in the Bid Schedule shall be full compensation for furnishing all labor, materials, methods or processes, implements, tools, equipment and incidentals and for doing all work involved as required by the provisions of the Contract Documents for a complete in place and operational system.

- A. Unless otherwise specified in the Specifications, quantities of work shall be determined per each, or from measurements or dimensions in a horizontal plane. All materials shall be measured on the basis of "in place" quantities and paid for using the units listed in the bid schedule.
- B. Except as noted, the Engineer will make field measurements of unit price items in order to determine the quantities of the various items as a basis for payment. On all unit price items, the contractor will be paid for the actual amount of the work performed in accordance with the contract documents, as computed from field measurements.
- C. Work or quantities not listed in the description of bid items are considered incidental to other construction and will not be separately measured or paid for. Compensation for such work and/or material shall be included in the prices paid for other items of work.

1.2 BID ITEMS

Bid Item 1 – Mobilization/Demobilization: Payment for this item shall include full compensation for all labor, materials, tools, equipment and incidentals making up the cost of mobilization, move-in, move-out, all necessary bonds, insurance, permits, licenses, and fees required during the performance of the work as specified. This item also includes demobilization, including the removal of all equipment, supplies, personnel and incidentals from the project at the end of construction. Payment for mobilization shall be made with the first progress payment and shall not exceed 80 percent of the bid item amount. Payment for demobilization shall be made with the last progress payment and shall not be less than 20 percent of the bid item amount. This bid item will be paid for by Lump Sum.

Bid Item 2 – Site Demolition and Pipeline Protection: Payment under this item shall be considered full compensation for all labor, materials, tools, equipment and incidentals required to complete all miscellaneous facilities or work shown or specified on the plans and specifications, and not specifically included in any other bid item. Included in this bid item shall be, but not necessarily limited to, such items as supporting of poles and protection of other utilities near excavations; verifying the locations of existing utilities, concrete slurry where pipes have four inches or less between them, minor grading to provide or

maintain drainage; providing temporary fencing for security; removal and replacement of existing mailboxes if necessary; removing and replacing other existing improvements as required; tree trimming and/or removal, and/or other operations as set forth and required but not specifically included in another bid item, all in conformance with existing codes and as directed by the Engineer. This bid item will be paid for by Lump Sum, prorated, based on percentage of work completed.

Bid Item 3 – Customer Outreach & Satisfaction: Contractor shall provide two (2) advance written notices to property owners/residents of the impending work and the temporary no-parking restrictions one (1) to two (2) days prior to working in the areas. The notice shall describe the nature of the work, the location and duration of the parking prohibition, and who to call if they have questions during construction. The Contractor shall provide a sample of the notice to the Engineer for approval prior to distribution.

Any complaints received by the City from property owners dissatisfied with the installation shall be corrected by the Contractor before payment is made. Any water tap blockage or leaks caused by the installation of new service lines will be repaired by the Contractor at Contractor's expense. The decision by the city regarding the credibility of an owner's complaint shall be final. The Contractor shall promptly correct any deficiencies, including but not limited to, water leaks that are a direct or indirect result of the installation when directed to do so by the City.

It shall be presumed that any leaks in the vicinity of the water meter reported by the customer to either the City or the Contractor within 30 calendar days after completion of work at the customer's property are the result of the installation work, unless a preexisting condition has been noted on the work order. The Contractor shall repair such leaks and correct all damages which occur during the 30-day period at the Contractor's expense. This bid item will be paid for by Lump Sum.

Bid Item 4 – Traffic Control & General Safety: Payment under this item shall be considered full compensation for all labor, materials, tools, equipment and incidentals required to implement and maintain all temporary traffic control measures. This bid item will be paid for by Lump Sum, prorated, based on percentage of contract work completed.

Bid Item 5 – Sawcut & Remove Existing AC Pavement: Payment for this item shall include full compensation for all labor, materials, tools, equipment and incidentals required to sawcut, remove and dispose of existing asphalt concrete pavement in accordance with the plans and specifications. Bid quantity shown is estimated from approximated dimensions. This bid item will be paid for Per Square Foot.

Bid Item 6 – Sawcut & Remove Existing Sidewalk, Curb & Gutter: Payment for this item shall include full compensation for all labor, materials, tools, equipment and incidentals required to sawcut, remove and dispose of existing concrete curb, gutter and sidewalk, in accordance with the plans and specifications. Bid

quantity shown is estimated from approximated dimensions This bid item will be paid for Per Square Foot.

Bid Item 7 – Abandon Existing Water Main: This bid item includes full compensation for all labor, materials, tools, equipment and incidentals making up the cost of all work including water main abandonment and/or removal as needed, including asphalt removal and replacement as described in the Specifications and shown on the Plans. This bid item will be paid for by Lump Sum, prorated, based on percentage of work completed.

Bid Item 8 – Connection to Existing Water Main: Payment under this item shall be considered full compensation for all labor, materials, tools, equipment and incidentals necessary for connection new water main to existing water main in accordance with the plans and specifications. Included in this bid item shall be all excavation, field verification of pipe size, trench preparation, bedding, backfill, compaction, testing, disinfection, removal of existing pipe, water tight caps/plugs on abandoned lines and other fittings necessary including restraining joints, and all other work necessary to result in a complete and operational water main This bid item will be paid for Per Each.

Bid Item 9 – F&I 8-Inch C-900 DR 14 PVC Water Main: Payment under this item shall be considered full compensation for all labor, materials, tools, equipment and incidentals necessary for furnishing and installing C-900 DR 14 PVC Water Main to the lines and grades shown in accordance with the plans and specifications. Payment for this item shall be made on a Linear Foot basis, and shall include payment for all excavation, trench preparation, bedding, fittings, backfill, disinfection, compaction, testing, worker protection, and other work required to result in a complete and operating water main

Bid Item 10 – F&I 10x10x8-Inch Tee: Payment under this item shall be considered full compensation for all labor, materials, tools, equipment and incidentals necessary for furnishing and installing crosses and appurtenances in accordance with the plans and specifications. Included in this bid item shall be all excavation, bedding, backfilling, compaction, watering; disinfection, testing and other work required to result in a complete and operational tee as detailed in the plans and specifications. This bid item will be paid for Per Each.

Bid Item 11 – F&I 8x8x6-Inch Cross: Payment under this item shall be considered full compensation for all labor, materials, tools, equipment and incidentals necessary for furnishing and installing tees and appurtenances in accordance with the plans and specifications. Included in this bid item shall be all excavation, bedding, backfilling, compaction, watering; disinfection, testing and other work required to result in a complete and operational cross as detailed in the plans and specifications. This bid item will be paid for Per Each.

Bid Item 12 – F&I 6x6x6-Inch Tee: Payment under this item shall be considered full compensation for all labor, materials, tools, equipment and incidentals necessary for furnishing and installing crosses and appurtenances in accordance with the plans and specifications. Included in this bid item shall be all excavation, bedding, backfilling, compaction, watering; disinfection, testing and other work

required to result in a complete and operational tee as detailed in the plans and specifications. This bid item will be paid for Per Each.

Bid Item 13 – F&I 8-Inch Gate Valve: Payment under this item shall be considered full compensation for all labor, materials, tools, equipment and incidentals necessary for furnishing and installing gate valve, riser, cover with lid, concrete collar, and all appurtenances in accordance with the plans and specifications. Included in this bid item shall be all excavation, bedding, backfilling, compaction, watering; disinfection, testing and other work required to result in a complete and operational gate valve as detailed in the Plans and Specifications. This bid item will be paid for Per Each.

Bid Item 14 – F&I 6-Inch Gate Valve: Payment under this item shall be considered full compensation for all labor, materials, tools, equipment and incidentals necessary for furnishing and installing gate valve, riser, cover with lid, concrete collar, and all appurtenances in accordance with the plans and specifications. Included in this bid item shall be all excavation, bedding, backfilling, compaction, watering; disinfection, testing and other work required to result in a complete and operational gate valve as detailed in the plans and specifications. This bid item will be paid for Per Each.

Bid Item 15 – F&I 8-Inch Reducer: Payment under this item shall be considered full compensation for all labor, materials, tools, equipment and incidentals necessary for furnishing and installing reducers and appurtenances in accordance with the plans and specifications. Included in this bid item shall be all excavation, bedding, backfilling, compaction, watering; disinfection, testing and other work required to result in a complete and operational reducer as detailed in the plans and specifications. This bid item will be paid for Per Each.

Bid Item 16 – F&I 6-Inch Reducer: Payment under this item shall be considered full compensation for all labor, materials, tools, equipment and incidentals necessary for furnishing and installing reducers and appurtenances in accordance with the plans and specifications. Included in this bid item shall be all excavation, bedding, backfilling, compaction, watering; disinfection, testing and other work required to result in a complete and operational reducer as detailed in the plans and specifications. This bid item will be paid for Per Each.

Bid Item 17 – F&I 8-Inch Pipe Bends: Payment under this item shall be considered full compensation for all labor, materials, tools, equipment and incidentals necessary for furnishing and installing bends and appurtenances in accordance with the plans and specifications. Included in this bid item shall be all excavation, bedding, backfilling, compaction, watering, disinfection, testing and other work required to result in a complete and operational bends as detailed in the Plans and Specifications. This bid item will be paid for Per Each.

Bid Item 18 – Install 1-Inch Water Service: Payment under this item shall be considered full compensation for all labor, materials, tools, equipment and incidentals necessary for constructing Water Services in accordance with the plans and specifications. Included in this bid item shall be all excavation, trench preparation, bedding, fittings, backfill, compaction, testing, disinfection, and other

work required to result in a complete and operating water service. Installation of new meter and meter box in the locations specified on the plans shall be paid for under this bid item. The City will provide the new meter to the Contractor at no cost. This bid item will be paid for Per Each.

Bid Item 19 – F&I Fire Hydrants Assembly: Payment under this item shall be considered full compensation for all labor, materials, tools, equipment and incidentals necessary for furnishing and installing Fire Hydrant Assemblies and all appurtenances in accordance with the plans and specifications. Included in this bid item shall be all excavation, bedding, backfilling, compaction, watering; disinfection, testing and other work required to result in a complete and operational Fire Hydrant Assembly as detailed in the plans and specifications. This bid item will be paid for Per Each.

Bid Item 20 – F&I Combination Air Release Valve: Payment under this item shall be considered full compensation for all labor, materials, tools, equipment and incidentals necessary for furnishing and installing Air Release Valve and all appurtenances in accordance with the plans and specifications. Included in this bid item shall be all excavation, bedding, backfilling, compaction, watering; disinfection, testing and other work required to result in a complete and operational Air Release Valve as detailed in the plans and specifications. This bid item will be paid for Per Each.

Bid Item 21 – R&R Curb Return and Access Ramp per Caltrans Standard Plan A88A Modified Case C: Payment under this item shall be considered full compensation for all labor, materials, tools, equipment and incidentals required to construct concrete curb return and access ramp per Caltrans Standard Plan A88A Modified Case C to the lines and grades shown and specified. This bid item includes pavement removal, excavation, preparation and compaction of subgrade, furnishing, grading and compacting the granular base material, forming, furnishing the Portland cement concrete, placement, finishing, furnishing and installation of truncated dome material and all other work required to result in a complete concrete curb return. This bid item will be paid for Per Each.

Bid Item 22 – F&I Concrete Sidewalk: Payment under this item shall be considered full compensation for all labor, materials, tools, equipment and incidentals required to construct concrete sidewalk to the lines and grades shown and specified in accordance with the plans and specifications. This bid item includes excavation, preparation and compaction of subgrade, furnishing, grading and compacting the granular base material, forming, furnishing the Portland cement concrete, placement, doweling into existing concrete, finishing and all other work required to result in a complete sidewalk. Bid quantity shown is estimated from approximated dimensions. This bid item will be paid for Per Square Foot.

Bid Item 23 – F&I Concrete Curb and Gutter: Payment under this item shall be considered full compensation for all labor, materials, tools, equipment and incidentals required to construct concrete curbs and gutters to the lines and grades shown and specified in accordance with the plans and specifications. This bid item includes excavation, preparation and compaction of subgrade,

furnishing, grading and compacting the granular base material, forming, furnishing and placing the Portland cement concrete, placement, doweling into existing concrete, finishing and all other work required to result in a complete curb and gutter. Bid quantity shown is estimated from approximated dimensions. This bid item will be paid for Per Lineal Foot.

Bid Item 24 – R&R Concrete Residential Drive Approach: Payment under this item shall be considered full compensation for all labor, materials, tools, equipment and incidentals required to construct concrete residential drive approach at the locations and to the lines and grades shown and specified, in accordance with the Plans and Specifications. This bid item includes pavement removal, excavation, preparation and compaction of Subgrade, grading and compacting the granular base material, forming, furnishing and placement of Portland cement concrete, finishing and all other work required to result in a complete drive approach including the curb & gutter. This bid item will be paid for Per Each.

Bid Item 25 – F&I AC Trench Patch: Payment under this item shall be considered full compensation for all labor, materials, tools, equipment and incidentals required to furnish and place Type A asphalt concrete pavement to the lines and grades shown in accordance with the plans and specifications. This bid item will include furnishing the material, placement, compaction, prime coat, asphaltic emulsion coating on vertical surfaces to abut the new pavement, grading and compaction of subgrade, and all other work required to result in an asphalt pavement meeting the requirements of the plans and specifications. The asphalt concrete pavement for permanent trench resurfacing of utility trenches will be paid for under this bid item. This bid item will be paid for Per Lineal Foot.

Bid Item 26 – F&I AC Replacement at Gutter Pan: Payment under this item shall be considered full compensation for all labor, materials, tools, equipment and incidentals required to furnish and place Type A asphalt concrete pavement to the lines and grades shown in accordance with the plans and specifications. This bid item will include furnishing the material, placement, compaction, prime coat, asphaltic emulsion coating on vertical surfaces to abut the new pavement, grading and compaction of subgrade, and all other work required to result in an asphalt pavement meeting the requirements of the plans and specifications. The asphalt concrete pavement for permanent pavement resurfacing adjacent to new curb and gutter will be paid for under this bid item. This bid item will be paid for Per Lineal Foot.

Bid Item 27 – Replace Striping: Payment under this item shall be considered full compensation for all labor, materials, tools, equipment and incidentals required to furnish and install pavement striping/markings, which may be damaged during construction activities, including removing and disposing of painting pavement striping and markings, and doing all other work necessary to complete the signing and striping installations in accordance with the plans and specifications. This bid item will be paid for by Lump Sum, prorated, based on percentage of work completed.

SECTION 01 57 56
TRAFFIC CONTROL

PART 1 GENERAL

1.1 WORK INCLUDED

- A. The work of this section consists of preparation and implementation of a Traffic Control Plan to provide for safe movement of vehicular, bicycle and pedestrian traffic around construction operations. The Contractor shall be solely responsible for providing all protective measures necessary.
- B. The Contractor shall establish and maintain detours and conduct construction operations in such a manner as to minimize hazard, inconvenience and disruption to the public.
- C. The Contractor shall provide for protection of pedestrians and separation of pedestrians from construction operations at all times.
- D. The Contractor shall provide adequate controls for congested vehicular and pedestrian traffic around Henry Miller Elementary School, while school is in session throughout the duration of the project.
- E. Clean up site each day after completing work and remove all traffic hazards. Daily traffic control measures shall continue until cleanup activities have been satisfactorily completed and the Contractor's equipment has been removed from the traveled way area.
- F. The Contractor shall direct, divert and detour traffic through, around and adjacent to construction operations in accordance with the approved Traffic Control Plan. The Contractor may revise the Traffic Control Plan as necessary only with approval of the Owner.

1.2 SUBMITTALS

- A. Submittals shall be in accordance with the General and Special Provisions.
- B. The Traffic Plan shall be submitted prior to or at the Pre-construction meeting with sufficient time for the Owner to review and approve the plan prior to construction beginning.
- C. The Traffic Control Plan shall include a map showing how detour routes will be signed, any specific street closure plans, and a description of how Contractor shall provide for the protection of pedestrians and bicyclists, and safe vehicle passage through the use of signs and flag persons, if necessary.
- D. The Contractor shall restore to original condition all property not designated for alteration by these Contract Documents.

PART 2 PRODUCTS

2.1 CONSTRUCTION SIGNS

- A. Construction signs shall conform to the standards of the MUTCD.
- B. Temporary warning signs in construction areas shall have a black legend on an orange background. Color for other signs shall follow the standard for all highway signs.
- C. All signs used shall be reflectorized or illuminated.
- D. Covers for existing signs shall match the color of the existing sign and be constructed of plywood or metal. No holes shall be drilled into existing signs.

2.2 OTHER TRAFFIC CONTROL DEVICES

- A. General: Traffic control devices shall conform to the standards of the MUTCD.
- B. Cones or Delineators:
 - 1. Cones or delineators shall consist of cylindrical or cone shaped plastic devices, which shall be 18 inches to 48 inches in height.
 - 2. Cones or delineators shall have a flexible base of suitable weight that will ensure stability.
 - 3. Cones used during hours of darkness shall be internally illuminated or reflectorized meeting the requirements of the MUTCD.
- C. Barricades:
 - 1. Barricades shall be Type I, Type II or Type III barricades as set forth in the MUTCD.
 - 2. Barricades used during hours of darkness shall be reflectorized and equipped with flashers.
- D. Flaggers
 - 1. Flaggers may be required to provide for public safety or the regulation of traffic, or by jurisdictional authorities; and if used, shall be properly equipped and certified.

PART 3 EXECUTION

3.1 DIVERTING TRAFFIC

- A. Whenever construction operations obstruct the flow of vehicular traffic or present a hazard to vehicles operating in the vicinity of construction operations, the

Contractor shall take appropriate action to warn, detour and otherwise protect approaching drivers and vehicles.

- B. Whenever construction operations obstruct the flow of pedestrian traffic or present a hazard to pedestrians, the Contractor shall take appropriate action to protect and separate pedestrians from the work area.
- C. Such action may include placement of barricades, warning signs, and/or provision of personnel as required to protect vehicles and pedestrians as conditions warrant.
- D. Keep traffic areas free of excavated material, construction equipment, pipe and other materials and equipment.
- E. Conduct operations in a manner to avoid unnecessary interference with public and private roads and drives and provide and maintain temporary access for businesses and residences. Provide and maintain suitable and safe bridges, detours, or other temporary expedients for accommodation of public and private travel. When access to private driveways must be temporarily denied due to construction operations, notify the property owner or responsible party of such closure not less than 24 hours in advance of closure. Give notification in writing and include the estimated duration of the closure.
- F. Notify the fire department, police/sheriff department, highway patrol, ambulance service, local school district, and transit 14 days before closing roadway or portion thereof. Notify said departments or agencies when streets are again passable for vehicles. Conduct operations with the least interference to fire equipment access, and at no time prevent such access. Furnish Contractor's night emergency telephone numbers to the police or sheriff's department.
- G. Pedestrian and bicycle access along sidewalks and streets will be kept open and safe from construction activities and traffic lanes.

3.2 *TRAFFIC CONTROL DEVICES*

- A. General:
 - 1. Traffic control devices shall be provided in sufficient quantities and types as required providing safe and adequate traffic control.
 - 2. During hours of darkness, approved lights shall be included, in proper working order, to illuminate signs and hazards and alert approaching traffic.
 - 3. Barricades shall be furnished and maintained along all open trenches in contact with traffic.
 - 4. No work may begin on any day or at any time before traffic control devices have been placed.
- B. Placement:

1. All traffic control devices shall be placed in accordance with the MUTCD and approved Traffic Control Plan.
 2. Locations of devices shall be adjusted to suit the conditions and circumstances of each detour situation. In all cases, signs shall be placed to most effectively convey their messages to approaching traffic.
- C. Maintenance of Devices:
1. The Contractor shall maintain all traffic control devices, at proper locations and in proper working order, during construction operations and whenever a hazard resulting from Contractor's operations exists.
 2. The Contractor shall adjust and revise traffic control devices, placement, etc., to suit changing conditions around construction operations.
- D. Removal of Devices:
1. Traffic control devices shall remain in place to alert approaching traffic of upcoming hazards.
 2. After hazard has been removed, all traffic control devices shall be removed. Signs shall be removed, or their messages covered to the satisfaction of the Owner.

3.3 NOTICE OF CHANGES

- A. The Contractor shall notify the Owner in writing at least forty-eight (48) hours, excluding holidays and weekends, prior to instituting any lane closure or detour. The Contractor shall also notify the Owner in writing at least forty-eight (48) hours, excluding holidays and weekends, prior to opening lane closures or detours before moving to another excavation segment. At the end of each day's work, the Contractor shall inform the Owner of the status of all detours and/or lane or road closures.

3.4 EMERGENCY VEHICLE ACCESS THROUGH DETOURS

- A. During all detours and/or street closures the Contractor shall provide for movement of emergency vehicles through the work area whenever possible.

3.5 ROADWAY USAGE BETWEEN OPERATIONS

- A. Keep fire hydrants and water control valves free from obstruction and available for use.
- A. At all times when work is not actually in progress, Contractor shall make passable and shall open to traffic such portions of the project and temporary roadways or portions thereof as may be agreed upon between Contractor and Owner.
- B. The Contractor shall not be permitted to maintain any lane closure or road closure during non-working hours without first obtaining approval of the Owner.

C. Restoration of Pavement:

1. During non-working hours the Contractor shall restore travel lanes to their original alignment and configuration by means of backfilling and temporary pavement or bridging where possible.
2. The Contractor shall place "ROUGH ROAD" signs conforming to the MUTCD at uneven temporary pavement or bridging.

3.6 *PARKING RESTRICTIONS*

A. General: The Contractor shall post approved "NO PARKING" signs at all locations necessary to establish work areas and detour traffic.

B. Signs:

1. Signs shall read: "NO PARKING - CONSTRUCTION TOW-AWAY ZONE." Show hours of parking restriction.
2. Signs shall be placed at least 24 hours in advance of restriction.

3.7 *PLATING OVER TRENCHES AND EXCAVATIONS*

A. General:

1. Plating shall be placed across all trenches and excavations in accordance with requirements of the specifications.

B. Design of Plating:

1. Plating for vehicular traffic shall be of sufficient width to accommodate the required number of travel lanes.
2. Plating shall be designed to support H-20 vehicular traffic.
3. All plating shall be set flush with travel surface or a satisfactory transition from travel surface to top of plating shall be provided.
 - a. A satisfactory transition shall mean a change in elevation between the levels of not less than twelve (12) inches horizontal to one (1) inch vertical.
 - b. Transition may be accomplished by means of temporary pavement.

END OF SECTION

SECTION 01 70 00
CONTRACT CLOSEOUT

PART 1 GENERAL

1.1 GENERAL

- A. It is the intent of these Contract Documents that the Contractor shall deliver a complete and operable facility capable of performing its intended functions and ready for use.

1.2 CLEANING

- A. Throughout the period of construction, the Contractor shall keep the work site free and clean of all rubbish and debris, and shall promptly remove from the work site, or from property adjacent to the work site, all unused and rejected materials, surplus earth, concrete, asphalt, and debris, excepting select material which may be required for refilling or grading.

1.3 FINAL SITE CLEAN-UP

- A. Upon completion of the work, and prior to final acceptance, the Contractor shall remove from the vicinity of the work all paint, surplus material, and equipment belonging to him or used under his direction during construction.
- B. The Contractor shall restore to original condition all property not designated for alteration by these Contract Documents.

1.4 WASTE DISPOSAL

- A. The Contractor shall dispose of surplus materials, waste products, demolition materials, and debris. The Contractor shall transport and dispose of waste materials in accordance with applicable laws and regulations.

1.5 PROJECT RECORD DOCUMENTS

- A. The Contractor shall maintain at the site, available to the Owner and Engineer, one copy of the Contract Documents, Drawings, Shop Drawings, Change Orders, and other modifications in good order and annotated to show all changes made during construction. These Documents shall be delivered to the Engineer for the Owner upon completion of the Work.
- B. Record documents shall be reviewed during progress meetings to ascertain that all changes have been recorded.
- C. Store Record Documents separate from documents used for construction.

1.6 TOUCH-UP AND REPAIR

- A. The Contractor shall touch-up or repair finished surfaces on structures, or installations that have been damaged prior to final acceptance. Surfaces on which such touch-up or repair cannot be successfully accomplished shall be completely refinished or in the case of hardware and similar small items, the item shall be replaced. Such items shall include, but not be limited to, the following:
1. Road surfaces
 2. Sidewalk Surfaces
 3. Curb and Gutter Surfaces
 4. Meter Boxes
 5. Valve Boxes
 6. Street Markings

1.7 FINAL EQUIPMENT CHECK

- A. After testing and before acceptance, all equipment shall be test run by the Owner for a minimum of 7 days to ensure proper operation.
- B. Submit written certification that Contract Documents have been reviewed, Work has been inspected, and that Work is complete in accordance with Contract Documents and ready for Engineer's inspection.
- C. Provide submittals to the Owner required by other governing authorities.

PART 2 PRODUCTS

(Not Used)

PART 3 EXECUTION

(Not Used)

END OF SECTION

SECTION 02 01 20

PROTECTING EXISTING UNDERGROUND UTILITIES

PART 1 GENERAL

1.1 UNDERGROUND FACILITIES

- A. Shown or Indicated: The information and data shown or indicated in the Contract Documents with respect to existing underground facilities at or contiguous to the Site is based on information and data furnished to Owner or Engineer by the owners of such underground facilities, including Owner, or by others.
1. Owner and Engineer shall not be responsible for the accuracy or completeness of any such information or data; and
 2. The cost of all of the following will be included in the Contract Price, and Contractor shall have full responsibility for:
 - a. Reviewing and checking all such information and data,
 - b. Locating all Underground Facilities shown or indicated in the Contract Documents,
 - c. Coordination of the Work with the owners of such underground facilities, including Owner, during construction, and
 - d. The safety and protection of all such underground facilities and repairing any damage thereto resulting from the Work.
- B. Not Shown or Indicated: If an underground facility is uncovered or revealed at or contiguous to the Site which was not shown or indicated with reasonable accuracy in the Contract Documents, the provisions of Divisions 0 and 1 shall apply.
1. Contractor shall develop and execute a work-plan, subject to Engineer's approval to protect underground facilities.
 2. The Contractor shall expose, prior to staking and trenching, all existing utilities and existing facilities which may control proposed facility grades, and alignment. Two working days notice shall be given to the Engineer prior to commencing this work.
 3. Full compensation for all costs involved in locating, verifying, protecting, exposing, and otherwise providing for utilities shall be included in the amounts bid for the various items of work, and no separate payment shall be made therefore.

1.2 PROTECTION

- A. The Contractor shall not interrupt the service function or disturb the supporting base of any Utility by disrupting any facility identified in the Plans and Specifications without authority from the Owner or order from the Engineer. Where protection of such facilities is required to ensure support of utilities, the Contractor shall, unless otherwise provided, furnish and place the necessary protection at the Contractor's expense.
- B. The Contractor shall be prepared at all times with labor, equipment and materials to make repair on damaged mains or Utility facilities. The Contractor shall immediately notify the Engineer and the Utility owner if he disturbs, disconnects or damages any Utility. The Contractor shall bear the costs of repair or replacement of any Utility facility described with reasonable accuracy in the Plans and Specifications that is damaged by the Contractor. No extra compensation will be made for the repair of any services or mains damaged by the Contractor, nor for any damage incurred if the neglect or failure of providing protective barriers, lights and other devices or means required to protect such existing utilities or facilities described with reasonable accuracy in the Plans and Specifications.

1.3 SURVEY MARKERS AND PERMANENT REFERENCE POINTS

A. Surveying and Permanent Survey Markers

The Engineer will take measurements to assure the preservation of survey markers (monuments and bench marks). The Contractor shall not disturb permanent survey markers without the consent of Engineer and shall bear the expense of replacing any that may be disturbed without permission.

1. Replacement of survey markers shall be done only by the Engineer.
2. The City is not responsible for staking or markings disturbed. This is the contractor's responsibility.

B. Lot Corner Monuments

The Contractor shall preserve property line and corner survey markers except where their destruction is unavoidable, and the Contractor is proceeding in accordance with accepted practice. Markers that are lost or disturbed by his operations shall be replaced at the Contractor's expense by the Engineer.

END OF SECTION

SECTION 02 41 00

DEMOLITION

PART 1 GENERAL

1.1 DESCRIPTION

- A. The work of this section consists of demolition and removal of pavements, slabs, miscellaneous debris, signs, barriers, salvaged items, and portions of abandoned utilities.
- B. Definitions:
 - 1. Portland Cement Concrete: A mixture of Portland cement, fine aggregate, coarse aggregate, admixtures (if used) and water, proportioned and mixed. Also, included is rebar.
 - 2. Asphalt Concrete: A mixture of liquid asphalt and graded aggregate used as paving material for roadways and parking lots.

1.2 WORK INCLUDED

- A. Repair and restoration of areas damaged due to demolition work.
- B. Salvaging of equipment for Owner.
- C. Removal of demolished materials from site.
- D. Remove existing piping and other existing structures as shown on the Plans to be removed.
- E. Properly dispose of all removed materials.
- F. Dewatering as needed in order to complete the proposed demolition.
- G. Removal of trees and landscaping as required for construction.

1.3 RELATED WORK

- A. Section 03 33 15 Concrete Sidewalk, Curb, & Gutter.
- B. Section 31 23 17 Trenching Backfilling and Compacting

1.4 SEQUENCING

- A. Sequence work to minimize interference with traffic and water service. The existing water system must remain in service until the new improvements become operational.

1.5 REGULATORY REQUIREMENTS

- A. Obtain required permits from City of Los Banos.
 - 1. Business License
- B. Dispose of removed materials in an approved disposal or salvage facility.
- C. Contractor and all subcontractors shall obtain City of Los Banos business license.

1.6 REFERENCES

- A. Section 16 – Clearing and Grubbing, State Standard Specifications
- B. Section 19 – Earthwork, State Standard Specifications

1.7 SUBMITTALS

- A. Submittals shall be in accordance with the General and Special Provisions.
- B. Demolition plan including sequence of operations. The plan shall specifically address methods of demolition, schedule, sequence of demolition, and procedures for archeological monitoring. Demolition shall not proceed until the plan has been approved.

1.8 QUALITY ASSURANCE

- A. General: Take all necessary precautions with regard to safety in carrying out the demolition and site work. Erect suitable barriers around open excavations and fulfill all appropriate requirements of CAL/OSHA. Comply with safety requirements for demolition, ANSI A10.6-06.

1.9 PROJECT CONDITIONS

- A. Underground utilities exist at this site. Contractor shall take all necessary precautions to protect said utilities. Notify Engineer of any deviation in utility location from that which is shown on the drawings.
- B. Keep dust to a minimum at the project site or any staging area. Use water trucks as necessary or as directed by the Engineer.
- C. Ensure safety of persons in demolition area. Provide temporary barricades as required.
- D. Excavations may encounter groundwater and require dewatering depending on the time of year and amount of seasonal run-off. Loose sands exposed in excavation sidewalls may be unstable and require shoring or lying back in accordance with OSHA requirements. Flowing sands may also be encountered in excavations below groundwater levels.

1.10 CLOSEOUT SUBMITTALS

- A. As specified in Section 01 77 00 – Contract Closeout.
- B. Show all capped and abandoned utility terminations and location of remaining facilities on project Record Drawings.

PART 2 PRODUCTS

2.1 REPAIR AND RESTORATION MATERIALS

- A. Backfill materials shall be as required by Section 19 - Earthwork, State Standard Specifications unless noted otherwise on the plans.
- B. Asphalt and concrete shall match existing materials and conditions.
- C. Asphalt and concrete shall be replaced in conformance with governing authority standards.

2.2 MATERIALS

- A. Salvaged Materials: Materials to be salvaged shall remain the property of the Owner and shall be stockpiled as directed by the Engineer. Contractor shall inventory all salvaged materials. Stockpiled materials shall be free of hazardous substances. Salvage materials include:
 - 1. Valves & Valve Boxes.
 - 2. Meters and Meter Boxes
 - 3. Fire Hydrants
 - 4. Corp Stops
- B. Items to be Salvaged and Relocated shall be salvaged and/or relocated as shown on the drawings, or as directed by the Engineer.
- C. Materials and items demolished and not designated for reuse, salvage or transfer to the Owner, as well as all debris, rubbish and other materials resulting from the demolition operations, shall become the property of the Contractor and shall be removed from the site within 48 hours of demolition.
- D. Storage or sale of the removed items will not be permitted at the site.
- E. As directed by the Engineer, recycled materials, Portland cement concrete and asphalt concrete, may be used in engineered fill and/or crushed miscellaneous base if it meets CDT Standard Specification, Section 26, Class 2 Aggregate Base, ¾-inch maximum (CMB). Portland cement concrete shall be crushed, to be used in engineered fill and/or CMB material, if material requirements are met.

PART 3 EXECUTION

3.1 INSPECTION

- A. Prior to demolition, inspect the site conditions, verifying all governing dimensions, notes and specification. Notify the Engineer of any errors or omissions in the contract documents.
- B. Make such explorations and probes as are necessary to ascertain any required protection measures before proceeding with the demolition and removal work.

3.2 PREPARATION

- A. Protect existing, appurtenances, structures, which are not to be demolished.
- B. Prior to demolition work, all soil erosion control best management practices including inlet protection barriers shall be in place. Contractor shall provide appropriate measures to prohibit demolition debris and/or soil from entering any storm drain
 - 1. Protect all buildings, structures, utilities, and vegetation to remain.

3.3 DEMOLITION REQUIREMENTS

- A. Conduct demolition to protect and minimize damage to structures and existing improvements.
- B. Conduct salvaging to protect and minimize damage to salvaged equipment.
- C. Execute the work in a careful, orderly and safe manner, with the least possible disturbance to the public. Cease operations immediately if adjacent work appears to be endangered. Do not resume operations until corrective measures have been taken.
- D. Pavement and Slabs:
 - 1. Remove completely all Portland cement concrete slabs-on-grade including, but not limited to, equipment pads, sidewalks, etc. If approved by the Engineer, the Contractor may crush Portland concrete for use as aggregate base.
 - 2. Saw cut existing asphalt concrete pavements cleanly in straight continuous lines. Remove asphalt concrete pavement as shown on the drawings. The Contractor may utilize the recycled asphalt concrete pavement for use as base course on this project. The Engineer shall determine if milling shall be used under this contract.
 - 3. Any material thus processed shall conform to the specifications for Section 32 11 23 - Aggregate Base

4. In areas that are demolished, but where no future roads or structures are shown, the exposed subgrade shall be scarified an additional 18 inches before placing backfill.
- E. Items to be Salvaged: Remove as directed by the Engineer. Remove carefully. All salvaged material remains the property of the Owner. Store where directed by the Engineer.
- F. Abandoned Utilities: Remove above ground utilities and terminate as approved by the utility company and the Engineer. Remove necessary portions of underground utilities to within 24 inches of excavation or final grade. Plug abandoned pipes and conduits with concrete plugs. Plugs shall be 6 inches or 2 times the pipe diameter in length, whichever is greater.
 1. Water lines shall be capped as close as possible to active mains/valves.

3.4 SALVAGE EQUIPMENT

- A. Salvaged equipment shall be delivered to the Owner at a designated site within the project site. Salvaged equipment shall be placed on wood or concrete blocks, so the equipment will be 4 inches minimum above ground elevation.
- B. Equipment to be salvaged:
 1. Valves & Valve Boxes
 2. Meters and Meter Boxes
 3. Fire Hydrants
 4. Corp Stops

3.5 ORDER OF WORK

- A. Existing facilities shall remain in operation until the new system is in operation. Coordination will be required with the Owner for temporary shut-off of existing pipeline system for connection of new pipeline to existing pipelines. Contractor shall submit plans to Owner for approval for shut-off duration at least 10 days prior to shut-off.
 1. Hours and duration of shut-off will be limited to a maximum of 4 hours in any single day.

3.6 PRESERVATION

- A. If indicated or required, preserve trees, plants, or other features designated to remain. Protect trees and plants from damage; fell trees in a manner which shall not injure standing trees, plants and improvements which are to be preserved.

3.7 RESTORATION

- A. All demolition areas, staging/stockpiling, and open excavations shall be filled in accordance with the Plans and Specifications. Fill all open excavations deeper than one foot to an elevation to match the surrounding topography.
 - 1. New Construction Areas: As shown on drawings.

3.8 DISPOSAL

- A. General: Except for items or materials to be salvaged, recycled, or otherwise reused, remove waste materials from Project site and legally dispose of them in a landfill or incinerator acceptable to authorities having jurisdiction.
 - 1. Except as otherwise specified, do not allow waste materials that are to be disposed of accumulate on-site.
 - 2. Remove and transport debris in a manner that will prevent spillage on adjacent surfaces and areas.
- B. Burning: Do not burn waste materials.
- C. Disposal: Remove waste materials from project property and dispose in a legal manner.

END OF SECTION

SECTION 03 33 15

CONCRETE SIDEWALK, CURB & GUTTER

PART 1 GENERAL

1.1 WORK INCLUDED

- A. The work of this section consists of constructing concrete walks, curbs, and gutters.

1.2 RELATED WORK

- A. Section 31 23 17 – Trenching, Backfilling and Compacting

1.3 REFERENCES

- A. Section 40 – Concrete Pavement, State Standard Specifications
- B. Section 90 – Portland Cement Concrete, State Standard Specifications
- C. City of Los Banos, Improvement Standards & Specifications

1.4 SUBMITTALS

- A. Submittals shall be in accordance with the General and Special Provisions.

1.5 QUALITY ASSURANCE

- A. Contractor shall arrange for concrete tests to be made by an independent testing laboratory acceptable to the City. Laboratory shall take, prepare, and cure samples, and do all field and laboratory testing. Promptly submit five copies of test reports to the Engineer. Testing shall comply with ASTM C94-17.
 - 1. Strength Tests: Strength tests shall be made from each 100 cubic yards of concrete or fraction thereof each day. For each test, three cylinders shall be molded, one to be used for a 7-day test.
 - 2. Air Content and Slump Tests: At the time samples are taken for strength tests, the laboratory shall make slump and air content tests.
 - 3. All costs for initial tests shall be borne by the City.
 - 4. The cost of any retests, including time for the Engineer, shall be borne by the Contractor at no additional cost to the project. Testing will be required as directed by the Engineer.

1.6 *PROJECT CONDITIONS:*

- A. Place concrete only when temperatures are above 35 degrees F, unless it is protected from freezing and approved in advance by the Engineer.

PART 2 PRODUCTS

2.1 *SELECT FILL*

- A. Dense, readily compactable material, free from vegetable matter and lumps of clay. Excavated material that meets this requirement may be used if approved.

2.2 *BASE COURSE*

- A. Hard, durable particles of stone, gravel, or other finely divided mineral matter. All particles shall pass a 1-inch square mesh sieve and shall be uniformly graded from coarse to fine to produce a dense, compacted base.

2.3 *CONCRETE*

- A. Materials: Materials, including cement, aggregates, water, and admixtures, shall meet the requirements of ASTM C94-17.

- 1. Cement: Type II.

- 2. Coarse Aggregate: Maximum size, 1-inch for hand methods, 3/4-inch for slip-form construction, and 1/2-inch for extruded curbs. For machine placed concrete, Contractor may, with Contracting Officer's approval, modify the aggregate grading specified in ASTM C94-17 to meet the recommendations of the manufacturer of the machine.

- a. Minimum Cement Content:

- 1) Sidewalks, curbs and gutters: Class "B" (5 sack).

- 2) Driveways and cross gutters: Class "A" (6 sack).

- B. Slump:

- 1. Concrete Walks: Maximum 4 inches.

- 2. Curb and Gutter:

- a. Hand Vibrated: Maximum 3 inches.

- b. Slip-Formed: Maximum 2 inches.

- C. Strength: 3,000 psi at 28 days.

- D. Manufacture and Delivery: Measurement of materials, batching, mixing, transporting, and delivery shall be as specified in ASTM C94. Discharge concrete

into forms within 1-1/2 hours after introduction of water to cement. When temperature of concrete is 85 degrees F or above, the time between introduction of water to cement and complete discharge of concrete into forms shall not exceed 45 minutes.

- E. Air Entraining Admixture: ASTM C260.
- F. Other admixtures complying with ASTM C494 or ASTM C618 may be used with approval of Engineer. No chlorides will be permitted.

2.4 *SURFACE RETARDANT*

- A. Rugasol S, manufactured by Sika Chemical Corporation, Lyndhurst, New Jersey, or approved equal.

2.5 *CURING COMPOUND*

- A. In accordance with Section 90 of the State Standard Specifications.

2.6 *CURING MATERIAL*

- A. Waterproof paper, polyethylene sheet, clean burlap, cotton mats, or other approved material that will not cause stain or discoloration.
- B. Using curing compound or curing materials, thoroughly cure and protect concrete keeping the surface moist for 7 days. Cure slabs with integral color in accordance with instructions of the pigment manufacturer. On exposed aggregate slabs or slabs with integral color, do not use polyethylene or paper sheeting.

PART 3 EXECUTION

3.1 *PREPARATION OF SUBGRADE*

- A. Excavate to required depth. Remove soft, yielding material and replace with select fill. Compact to a density of not less than 95 percent of the maximum density.

3.2 *MAINTENANCE OF SUBGRADE*

- A. Maintain subgrade in a compacted condition until concrete is placed.

3.3 *FORMS*

- A. Metal or uniform warp-free lumber, coated with form release agent. Grade forms to give slabs positive drainage and stake securely. Obtain approval of alignment and grade before placing concrete.

3.4 *PLACING:*

- A. Concrete slabs for walks shall be formed, placed, vibrated, and finished by hand using conventional methods. Concrete curbs or curbs and gutters may be constructed in the same manner, but Contractor has the option of machine placing curbs using the extrusion method or machine placing curb and gutter using the slip-form method.
- B. Place concrete on moistened subgrade monolithically between construction joints. Deposit to full depth in one operation. Consolidate immediately. After depositing concrete, screed and darby or bullfloat.

3.5 *FORM REMOVAL*

- A. Remove forms within 24 hours after concrete placement. Repair minor defects with mortar. Plastering will not be permitted on exposed faces.

3.6 *SLAB FINISHING*

- A. After darbying or bullfloating, stop finishing until bleeding has ceased and until concrete can support foot pressure with only about 1/4-inch indentation. Edge and joint, then float the slab. Use steel trowel to densify surface, then broom slab perpendicular to line of traffic.

3.7 *JOINTS*

- A. Construct joints true to line with faces perpendicular to surface.
 - 1. Contraction (Control) Joints: Space walk joints at intervals about equal to width of walk to a depth of one-fourth the slab thickness. Space curb and gutter joints not over 10 feet on center or match existing conditions and align them with sidewalk joints. Contraction joints shall be sawn.
 - a. Sawn: Cut with a power saw fitted with an abrasive or diamond blade within 4 to 12 hours after walk has been placed and finished. Use sawn joints on exposed aggregate.

3.8 *SIDEWALK RESTORATION*

- A. Where sections of miscellaneous sidewalk work requires removal and restoration the following shall apply:
 - 1. The surface of the sidewalk shall match the existing weakened plane joints, score joints and construction joint patterns with the adjoining sidewalks or City or County standards.
 - 2. Where short sections of sidewalk have been removed for replacement, a minimum distance of three (3) feet section of sidewalk shall be removed or as directed by the Engineer.

3. If curbs and gutters cannot be cut off square and neat, the entire curb and gutter shall be removed to the nearest weakened plane or expansion joint. No patching at joints will be permitted.

3.9 *FIELD QUALITY CONTROL*

- A. Surfaces shall not vary more than 5/16 inch when tested with a 10-foot straightedge, nor curb gutters and valley gutters shall not vary more than .03 feet from design grade.

END OF SECTION

SECTION 09 90 00

PAINTING AND COATING (SITE)

PART 1 GENERAL

1.1 WORK INCLUDED

- A. Field painting including surface preparation, surface protection, clean up, and/or other appurtenant work.
- B. All labor, materials, tools and equipment, and incidentals necessary and required for their completion.
- C. All pipe, fittings, equipment, and structures are to be field coated except for those specific exceptions contained in this specification or identified on the drawings. The painting schedule included at the end of this specification summarizes the surfaces to be coated, the required surface preparation, and the coating systems to be applied. Coating notes on the drawings are used to show exceptions to the schedules, to extend the limits of coating systems, or to clarify or show details for application of the coating systems.

1.2 RELATED WORK

- A. Section 33 12 19 Fire Hydrants

1.3 SUBMITTALS

- A. Submittals shall be in accordance with the Standard General Conditions and the Supplementary Conditions.
 - 1. Product technical data including:
 - a. Acknowledgement that products submitted meet requirements of standards referenced.
 - b. Performance criteria as required by the Engineer to determine quality.
 - c. Manufacturer's installation instructions and environmental parameters.
 - d. Material Safety Data Sheets.
 - e. Color samples.

1.4 AIR QUALITY REGULATORY COMPLIANCE

- A. All paint shall conform to the applicable air quality regulations at the point of application. Any paint material which cannot be guaranteed by the manufacturer to comply, whether specified by product designation or not, shall not be used.

- B. The volatile organic compound (VOC) of coatings materials limits set forth in Rule 460.1 of the San Joaquin Valley Unified Air Pollution Control District shall apply to this project. The manufacturers' products listed in paragraphs 09 90 00-3.01 and 3.02 have been selected on the basis of their apparent compliance with Rule 460.1; however, it shall remain the Contractor's responsibility to ensure that all coatings materials furnished are in compliance with all regulatory agencies.
- C. The product listed may meet the VOC requirement in the unthinned (as shipped) condition, but may exceed the VOC requirement if thinned to the manufacturer's allowable recommendations. In this situation, the product is not to be thinned beyond the limit indicated in Rule 460.1, and if the product cannot be suitably thinned for the intended application method or temperature requirements, it will be necessary to use another manufacturer's product subject to acceptance by the Engineer.
- D. It shall be the responsibility of the Contractor to ensure the compatibility of the field painting products which will be in contact with each other or which will be applied over shop painted or previously painted surfaces. Paint used in successive field coats shall be produced by the same manufacturer. Paint used in the first field coat over shop or field primed surfaces, or previously painted surfaces shall cause no wrinkling, lifting, or other damage to underlying paint.
- E. All paint used for intermediate and finish coats shall be guaranteed by the paint manufacturer to be fumeproof. Paint shall be lead-free and mercury-free.

1.5 QUALITY OF WORK

- A. All finishes shall be applied by skilled workmen in accordance with the best practices and standards of the painting trade. Brushes, rollers, all equipment, and the techniques used in applying finishes shall be of sufficient quality to assure the specified results. Work not conforming to this Specification shall be corrected by touching up or refinishing as directed by the Engineer.
- B. It is the purpose and intent of this Specification to cover the complete paint finishing of all exterior and interior surfaces as scheduled or specified and all surfaces which normally require a paint finish for corrosion resistance, weather protection, finished appearance or utility. Finished surfaces shall be of the type of finish, color sheen film thickness and quality specified.

1.6 DELIVERY AND STORAGE

- A. Painting materials shall be delivered to site in manufacturer's original containers with labels intact and seals unbroken. Painting materials and equipment shall be stored and protected against freezing and mixed in rooms assigned for that purpose. No chemicals, unauthorized thinners, or other materials, not included in the paint formulation shall be added to the paint for any purpose. All necessary precautions shall be taken to prevent fire. Rags or waste soiled with paint shall be removed from premises at end of each day's work, or shall be stored in covered metal containers.

1.7 EQUIVALENT PRODUCTS

- A. Whenever a coating is specified using the name of a proprietary product or the name of a particular manufacturer or vendor, the specified coating shall be understood as establishing the type and quality of coating desired.
- B. Other manufacturers' products will be accepted provided sufficient information is submitted to allow the Engineer to determine that the coatings proposed are equivalent to those named. Proposed coatings shall be submitted for review in accordance with the Section 01 33 00 - Submittals.
- C. Requests for review of equivalency will not be accepted from anyone except the Contractor, and such requests will not be considered until after the contract has been awarded.
- D. Specific products for various applications shall be as specified in Part 2. In addition to the products named in Part 2, equivalent products of the following manufacturers will also be acceptable:

Ameron
Carboline
Devoe
PPG (Pittsburgh)
Sherwin Williams Co.
Sinclair
Tnemec
Valspar

- E. Contractor shall provide verification that equivalent products are acceptable for the desired application.

1.8 REFERENCE STANDARDS

- A. SSPC – Society of Protective Coatings, Pittsburgh, PA
- B. ASTM – American Society For Testing And Materials, West Conshohocken, PA

PART 2 PRODUCTS

2.1 GENERAL

- A. All paint shall be the product of a recognized manufacturer exclusively engaged in the manufacture of painting material. All paints for wood and metal surfaces shall be well-ground and shall not skin, liver, curdle, or body excessively in the containers.
- B. The paint shall not show laps or unevenness of color or texture. When applied to vertical surfaces, it shall not sag.

- C. All exposed surfaces, including sides and edges, shall be painted. Hangers, brackets, fastenings and other miscellaneous items shall be painted with the same system as the adjacent material. Paint systems shall be in addition to shop primers.
- D. Paint shall be stored inside and shall be protected against freezing. No adulterant, unauthorized thinner, or other material not included in the paint formation shall be added to the paint for any purpose.
- E. Paint used in successive field coats shall be produced by the same manufacturer. Paint used in the first field coat over shop painted or previously painted surfaces shall cause no wrinkling, lifting, or other damage to underlying paint. Any paint system shall be the product of a single manufacturer.
- F. All paint used for intermediate and finish coats shall be guaranteed by the paint manufacturer to be lead-free, mercury-free, and fumeproof. Where paint materials are referenced to Federal or military specifications, the reference shall define general type and quality required but is not intended to limit acceptable materials to an exact formulation.
- G. For each paint, the Contractor shall follow the paint manufacturer's specific application instructions. Upon the Engineer's request, the Contractor shall furnish the following application instructions.
 - 1. Surface preparation recommendations.
 - 2. Type of primer to be used.
 - 3. Maximum dry and wet mil thickness per coat.
 - 4. Minimum and maximum curing times between coats.
 - 5. Thinner to be used with each paint.
 - 6. Ventilation requirements.
 - 7. Atmospheric conditions during which the paint shall not be applied.
 - 8. Allowable methods of application.
 - 9. Maximum allowable moisture content and minimum age of plaster, concrete and wood surfaces at time of paint application.
 - 10. Curing time before submergence in water.
- H. The minimum number of coats and minimum total dry mil thickness of the system for each surface shall be as specified in the paint schedule.

2.2 PAINTING SCHEDULE

- A. A schedule is appended to this section listing the surface preparation, primer, finish and dry mil thickness to be used on each surface to be coated.

2.3 PRIMERS AND PRETREATMENT

- A. P-1 Epoxy Primer - Minimum dry thickness 4 mils. Devoe "Bar Rust 235H", Sherwin Williams "Macropoxy 646 FC Epoxy B58-600", or Tnemec 69-1211 "Hi-Build Expoxoline."
- B. P-2 Rust Inhibitive, non-submerged - Minimum dry thickness 3 mils. Devoe "Devran 203 Waterborne Epoxy Primer", Sherwin Williams "Macropoxy 646 FC Epoxy B58-600" or Tnemec 135 "Chem Build."
- C. P-3 Rust inhibitive, submerged - Minimum dry thickness 4.0 mils. Devoe "Bar Rust 235H", Sherwin Williams "Macropoxy 646 FC Epoxy B58-600" or Tnemec 136 "Chem Build."
- D. P-4 Primer for Wood – Maximum of 400 sq. ft/gal. Devoe 2010-1200 "Ultra- Hide Durus Exterior Acrylic Primecoat", Sherwin Williams "A-100 Wood Primer B42W41" or Tnemec 151 "Elaso-Grip."
- E. P-5 Wallboard Primer – Maximum of 400 sq. ft/gal. Devoe 1060-1200 "Ultra- Hide Latex Primer- Sealer", Sherwin Williams "Preprite 200 Interior Latex Primer B28W200", or Tnemec 51-792 "PVA Sealer."
- F. P-6 High Build Acrylic – Maximum of 100 sq. ft/gal., Tnemec 180 WB Tneme-Crete, Sherwin Williams "Heavy Duty Block Filler B42W46".

2.4 INTERMEDIATE AND FINISH PAINTS

- A. F-1 Epoxy Resin - Minimum dry thickness 5 mils. Devoe "Bar Rust 235H", Sherwin Williams "Macropoxy 646 FC Epoxy B58-600", or Tnemec 69 "Hi-Build" epoxy.
- B. F-2 Gloss Acrylic Emulsion - Minimum dry thickness 2.0 mils Devoe " Devflex 4208 Waterbone Acrylic Enamel", Sherwin Williams "Shercryl Hi Performance Acrylic Gloss B66-300", or Tnemec 1028.
- C. F-3 Semi-gloss Acrylic Emulsion - Minimum dry thickness 2.5 mils Devoe "Devvflex 4216 HP Waterborne", Sherwin Williams "Shercryl Hi Performance Acrylic Semi-Gloss B66-350", or Tnemec 1029 "Tuf Cryl".
- D. F-4 High Build Epoxy (Substitute for Coal Tar) - Minimum dry thickness 6 mils. Devoe "Devtar 5A HS", Sherwin Williams "Targuard Coal Tar Epoxy B69B60", or Tnemec "V69F Black"
- E. F-5 Polyurethane O - Minimum dry thickness 2 mils. Devoe "Devthane 379H Aliphatic Urethane Gloss Enamel", Sherwin Williams "Hi Solids Polyurethane CA B65j-300", or Tnemec 1075 "Endurasheild."
- F. F-6 Acrylic Epoxy – Minimum dry film thickness 4 mils. Tnemec 113 Tneme-Tufcoat, Sherwin Williams " Waterbased Tile Clad Epoxy B73-100".
- G. F-7 High Build Acrylic – Maximum of 100 sq. ft./gal. Tnemec 180 WB Tneme-Crete, Sherwin Williams "Heavy Duty Block Filler B42W46".

2.5 FUSION BONDED EPOXY LINING AND COATING

- A. Lining and coating shall be a 100% solids, thermosetting, fusion-bonded, dry powder epoxy resin. Provide Scotchkote 134 or 206N, Lilly Powder Coatings "Pipeclad 1500 Red", or equal. Epoxy lining and coating shall meet or exceed the following requirements:

Hardness (Minimum): Barcol 17 (ASTM D 2583)
Rockwell 50 ("M" Scale)

Abrasion Resistance (Minimum) 1,000 cycles: 0.05 gram removed
5,000 cycles: 0.115 gram removed
ASTM D 1044, Tabor CS 17 wheel
1,000 gram weight

Adhesion (Minimum) 3,000 psi (Elcometer)

Tensile Strength 7,300 psi (ASTM D 2370)

2.6 ALUMINUM SURFACES

- A. All aluminum in contact with steel or concrete: Sherwin Williams "Macropoxy 646 FC Epoxy B58-600 series or approved equivalent..

2.7 SHOP COATINGS

- A. Shop coatings shall be applied as indicated in the individual equipment and component specifications.
- B. Electric motors, speed reducers, starters, and other self contained or enclosed components shall be shop primed or finished with a high grade, oil resistant enamel suitable for top coating in the field with an alkyd enamel.
- C. All shop coatings shall be compatible with the pain system specified in the Painting Schedule contained at the end of this specification.

2.8 SURFACES NOT TO BE PAINTED

- A. Except as otherwise required or directed, the following surfaces are to be left unpainted:
1. Exposed surfaces of aluminum (aluminum in contact with concrete is to be coated).
 2. Polished or finished stainless steel. Unfinished stainless steel shall be painted.
 3. Nickel or chromium.
 4. Galvanized surfaces, except piping, conduit, electrical conduit, pipe supports, fasteners, hangers, bracing, brackets, and accessories.

5. Rubber and plastics, including fiberglass reinforced plastics.
6. Precast concrete.

2.9 SYSTEM IDENTIFICATION

- A. Above Grade Piping: Provide markers on piping which is either exposed or concealed in accessible spaces. For piping systems, other than drain and vent lines, indicate the fluid conveyed or its abbreviation, either by preprinted marker or stenciled marking, and include arrows to show the direction of flow. Comply with ANSI A13.1 for colors. Locate markers at ends of lines, near major branches and other interruptions including equipment in the line, where lines pass through floor, walls or ceilings or otherwise pass into inaccessible spaces, and at 50' maximum intervals along exposed portion of lines. Marking of short branches and repetitive branches for equipment connections is not required.
- B. Equipment: All equipment shall be identified with a plastic laminated, engraved nameplate which bears the unit mark number as indicated on the drawings (e.g. AC-4). Provide 1/2" high lettering, white on black background. Nameplates shall be permanently secured to the unit.
- C. Valves: Provide valve tags on all valves of each piping system, excluding check valves, valves within equipment, faucets, stops and shut-off valves at fixtures and other repetitive terminal units. Provide brass tags or plastic laminate tags. Prepare and submit a tagged valve schedule, listing each valve by tag number, location and piping service. Mount in glazed frame where directed.

2.10 COLORS

- A. All colors and shades of colors shall be as specifically indicated in the specifications or plans, or, where not specifically indicated, selected from the manufacturer's standard color samples by the Owner.
- B. Electrical conduit shall be painted to match adjacent ceiling or wall surfaces as directed by the Engineer.

PART 3 EXECUTION

3.1 PRELIMINARY EXAMINATION

- A. Notify the Engineer in writing of any uncorrected defects in surfaces to be painted. Do not proceed with the finishing of surfaces in question until any discrepancies are corrected. No work on any surface shall be started, unless the surface has been inspected and approved for painting by the Engineer.

3.2 SURFACE PREPARATION

- A. The Contractor shall prepare the surfaces to be coated as specified under the paint schedule. Any surfaces to be coated which are not listed under the paint schedule

shall be prepared in accordance with the manufacturer's instructions for the material to be applied.

- B. All grease, oil, dirt, and other contaminants which may affect the bond between the coating and the surface shall be removed by a cleaning agent which will leave the surface clean and dry.
- C. Cleaning and painting operations shall be performed in a manner which will prevent dust or other contaminants from getting on freshly painted surfaces.
- D. Surfaces shall be free of cracks, pits, projections, or other imperfections which would prevent the formation of smooth, unbroken paint film, except for concrete block construction where a rough surface is an inherent characteristic.
- E. When applying touch-up paint, or repairing previously painted surfaces, the surfaces to be painted shall be cleaned and sanded or wire brushed in such a manner that the edges of adjacent paint are feathered or otherwise smoothed so that they will not be noticeable when painted. All paint made brittle or otherwise damaged by heat or welding shall be completely removed.
- F. Hardware items such as bolts, screws, washers, springs, and grease fittings need not be cleaned prior to painting if there is no evidence of dirt, corrosion, or foreign material.
- G. All galvanized surfaces shall have a metal conditioner applied prior to the first prime coat.
- H. All surfaces to be finished shall be clean and dry before any materials are applied. Use a moisture meter to determine moisture content as follows. The moisture content shall be less than 18% for wood; 8% for concrete or plaster.
 - 1. Metal Surfaces - Where noted, the surface preparation for steel and other metals refer to the specifications for surface preparation by the latest revision of the Steel Structures Painting Council. All metal work shall be cleaned of grease, oil and dirt by solvent cleaning (SSPC-SP1). Do not use hydrocarbon based solvents for cleaning prior to use of acrylic materials.
 - a. Method SP-2: Surface shall be wire brushed where required to remove loose rust and dirt, etc. (SSPC-SP2)
 - b. Method SP-3: Removal of loose rust, loose mill scale and other detrimental foreign matter to degree specified by power wire brushing, power impact tools or power sanders. (SSPC-SP3)
 - c. Method SP-6: Blast cleaning until at least two-thirds of each element of surface area is free of all visible residues. (SSPC-SP6)
 - d. Method SP-10: Sandblast to near white condition. This method shall remove all rust and scale, but streaks and shadows in the metal will be acceptable. (SSPC-SP10)

2. Wood Surfaces

- a. Method W-1: All unprimed millwork delivered to the jobsite shall be given the specified first coat on all surfaces immediately upon arrival. Give all unprimed woodwork the specified first coat as soon as possible following installation. Prime any wood surface that is to be in contact with concrete, or a caulking material, with the specified first coat material before installation. Unless specified otherwise, all casings and trim, and all woodwork shall be free of oil, dirt, loose fibers, etc., sealed with a sanding sealer recommended by the coating manufacturer, and sanded smooth and dusted thoroughly before application of the priming coat. Give all knots, pitch pockets and sappy areas a preliminary coat of Dutch Boy Knot Sealer, or approved equivalent, prior to application of the prime coat.
3. Galvanized Surfaces
 - a. Method G-1: All galvanized surfaces shall be prepared for painting in strict conformity with the instructions of the manufacturer. All galvanized shall be cleaned per SSPC-SP7.
4. PVC Pipe
 - a. Method V-1: All wax and oil shall be removed from PVC plastic surfaces by wiping with a solvent of the type used for the specified primer.

3.3 PAINT APPLICATION

- A. Apply all finishes evenly, free from sags, runs, crawls, brush marks, skips or other defects. Apply products at the proper consistency and do not thin or otherwise alter them except in accordance with the manufacturer's printed directions. All coats shall be applied in such manner as to produce an even film of uniform thickness completely coating all corners and crevices. All painting shall be done by thoroughly experienced workmen.
- B. Care shall be exercised during spraying to hold the nozzle sufficiently close to the surfaces being painted to avoid excessive evaporation of the volatile constituents and loss of material into the air, or the bridging over of crevices and corners. Spray equipment shall be equipped with mechanical agitators, pressure gauges, and pressure regulators. Nozzles shall be of proper size. Floors, roofs, and other adjacent areas and installations shall be satisfactorily protected by drop cloths or other precautionary measures. All over-spray shall be removed by approved methods or the affected surface repainted. Care shall be exercised to avoid lapping of paint on hardware of other unscheduled surfaces.
- C. Each coat of material shall be thoroughly dry before the application of a succeeding coat. In no case shall paint be applied at a rate of coverage per gallon which is greater than the maximum rate recommended by the manufacturer. Paint films showing sags, checks, blisters, teardrops, or fat edges will not be accepted. Paint containing any of these defects shall be entirely removed and the surface repainted.

- D. Sandpaper enamels and varnishes lightly between coats and dust thoroughly before the application of a succeeding coat.
- E. If the finish coat is to be colored, the prime coat and the intermediate coat shall be tinted to have a slight variation in color from each other and from the finish coat.

3.4 PRIMING

- A. Edges, corners, crevices, welds, and bolts shall be given a brush coat of primer before the specified spot or touch-up painting of metal surfaces. Special attention shall be given to filling all crevices with paint.
- B. Abraded and otherwise damaged portions of shop applied paint shall be repainted. Welded seams and other uncoated surfaces, heads and nuts of field installed bolts, and surfaces where paint has been damaged by heat, shall be given a coat of the specified primer. This patch, spot, or touch-up painting shall be completed, and shall be dry and hard, before additional paint is applied.

3.5 LATEX PAINT

- A. Latex paint shall be applied by brushing or rolling; spraying is not permitted. Latex paint shall not be thinned excessively.

3.6 MIXING AND THINNING

- A. Paint shall be thoroughly mixed each time any is withdrawn from the container. Paint containers shall be kept tightly closed except while paint is being withdrawn.
- B. Unless otherwise authorized, all paint shall be factory mixed to proper consistency and viscosity for hot weather application without thinning. Thinning will be permitted only as necessary to obtain recommended coverage at lower application temperatures. In no case shall the wet film thickness of applied paint be reduced, by addition of paint thinner or otherwise, below that represented by the recommended coverage rate.

3.7 FILM THICKNESS FOR FERROUS METALS

- A. It is intended that the dry film thickness and the continuity of painted ferrous metal surfaces be subject to continual field check by the Engineer. Dry film thickness shall be measured by the Contractor, using an approved Thickness Gauge, at locations selected by Engineer. Testing equipment provided shall be provided by Contractor and kept on site.
- B. Measurement of Dry Coating Thickness shall conform with paint application Standard SSPC-PA2
- C. Thickness and Holiday Checking - Thickness of coatings and paint shall be checked with a non-destructive, magnetic type thickness gauge.
- D. Holiday Checking of all interior coated surfaces shall be tested with an approved holiday detection device. Non-destructive holiday detectors shall not exceed 100 volts nor shall destructive holiday detectors exceed the voltage recommended by

the manufacturer of the coating system. For thicknesses between 10 and 20 mils (0.25mm and 0.50mm) a non-sudsing type wetting agent such as Kodak Photo-Flo, shall be added to the water prior to wetting the detector sponge. All pinholes shall be marked, repaired in accordance with the manufacturer's printed recommendations and re-tested. No pinholes or other irregularities will be permitted in the final coating. Holiday detection devices shall be operated in the presence of the Engineer.

- E. Continuity shall be tested by a low voltage-wet sponge per RPO 188. Contractor shall perform continuity tests as required by the Engineer on surfaces that will be submerged.

3.8 *ATMOSPHERIC CONDITIONS*

- A. Apply all material to dry and properly prepared surfaces when weather conditions are favorable for painting. No materials shall be applied when the temperature of the materials is below 50 degrees F, or when the temperature of the air, surface to be painted or substrate, is below (or likely to fall below) 50 degrees F. Final ruling on the favorability of weather conditions shall be in accordance with the recommendations of the manufacturer and/or the Engineer.
- B. No coating or paint shall be applied to wet or damp surfaces, in rain, snow, fog, or mist, when the steel temperature or surrounding air temperature is less than 5 degrees above the dew point, nor in conditions not recommended by the manufacturer

3.9 *REPAIRING DAMAGED PAINT ON EQUIPMENT*

- A. Painted surfaces on equipment, which have become damaged prior to acceptance by the Owner, shall be repainted with the same or equivalent paint used in the original application.

3.10 *PROTECTION OF SURFACES*

- A. Throughout the work the Contractor shall use drop cloths, masking tapes, and other suitable measures to protect all surfaces from accidental spraying, splattering, or spilling of paint. Contractor shall be liable for and shall correct and repair any damaged condition resulting from its operations or from the operations of all those who are responsible to the Contractor during the time its work is in progress and until the work is accepted. In case bituminous paints are spilled or dropped on any material except metals, the spots shall, after surface cleaning, be spot painted with aluminum paint prior to applying the specified paint. Any exposed concrete or masonry not specified to be painted which is damaged by paint shall be either removed and rebuilt or, where so authorized by the Owner, painted with two coats of masonry paint.

3.11 *CLEANUP*

- A. All cloths and cotton waste which might constitute a fire hazard shall be placed in metal containers or destroyed at the end of each work day. Upon completion of the

City of Los Banos
Idaho Avenue Waterline Replacement

work all staging, scaffolding and containers shall be removed from the site or destroyed in a manner approved by the Engineer.

3.12 PAINTING SCHEDULE

<u>SYSTEM</u>	<u>SURFACE</u>	<u>FINISH</u>			
		<u>SURF. PREP.</u>	<u>PRIME COAT</u>	<u>2ND COAT</u>	<u>3RD COAT</u>
1.	New ferrous metal in submerged or damp environment including all submerged mechanical components.	SP-10	P-1	F-1	F-1
2.	All exterior exposed new structural and miscellaneous steel. All exterior exposed surfaces of new piping, pumps, motors, electrical equipment and other unsubmerged mechanical and structural items.	SP-2 or 3	P-2	F-2	F-2
3.	All surfaces of new structural and miscellaneous steel pipe, pumps, motors and electrical equipment panels exposed inside building.	SP-6	P-2	F-3	F-3
4.	All interior exposed new galvanized metalwork including electrical conduit inside buildings, including fittings, boxes, supports and accessories.	G-1	P-3	F-3	F-3
5.	All exterior exposed new galvanized metalwork including roof flashings and other architectural items.	G-1	P-3	F-2	F-2
6.	Exposed new PVC piping	V-1	F-5	F-5	

City of Los Banos
Idaho Avenue Waterline Replacement

7.	All new buried valves and flanged joints and other buried miscellaneous ferrous piping and metal surfaces (excluding cast iron pipe). All exterior surfaces of new cast iron and steel piping exposed in manholes, wet wells and similar locations, including valves, fittings, flanges, bolts, supports, and accessories. Miscellaneous new castings, including manhole rings and covers and manhole steps. (One coat, if not foundry dipped.)	SP-10	F-4	F-4
8.	Interior wood	P-4	F-2	F-2
9.	Exterior wood	P-4	F-3	F-3
10.	Interior dry wall	P-5	F-6	
11.	Exterior concrete block	P-6	F-7	
12.	Concrete	P-6	F-7	

3.13 *When conflicting painting specifications or requirements are encountered in the contract documents, the more restrictive specifications or requirements shall be required.*

END OF SECTION

SECTION 31 23 17

TRENCHING, BACKFILLING, AND COMPACTING

PART 1 GENERAL

1.1 WORK INCLUDED

- A. This section includes material, testing, and installation for trench excavation, backfilling and compacting.

1.2 RELATED WORK

- A. Section 33 01 00 - Pipe and Fittings

1.3 REFERENCES

- A. ANSI/ASTM C136 – Sieve Analysis of Fine and Coarse Aggregates.
- B. ANSI/ASTM D1557 – Moisture-Density Relations of Soils and Sol-Aggregate Mixture Using 10 lb (4.54 kg) Hammer and 18-inch (457 mm) Drop.
- C. ANSI/ASTM D1556 – Density of Soil and base rock in Place by Sand-Cone Method.
- D. ASTM D 6938 – Density of soil and base rock in place by Nuclear method.
- E. ASTM D 2937 –Density of soil and in place by Tube method.
- F. Section 26 – Aggregate Bases, State Standard Specifications.

1.4 PROTECTION

- A. Protect excavations by shoring, bracing, sheet piling, underpinning, or other methods required to prevent cave-in or loose soil from falling into excavation.
 - 1. Trenches shall have sloping, sheeting, shoring, and bracing conforming with 29CFR1926, Subpart P—Excavations, CAL/OSHA requirements, and the Contract Documents.
- B. Notify Engineer of unexpected subsurface conditions.
- C. Protect bottom of excavations and soil adjacent to and beneath foundations from frost.
- D. When the pipelaying is not in progress, including the noon hours, close the open ends of pipe. Do not allow trench water, animals or foreign material to enter the pipe.

1.5 *QUALITY ASSURANCE*

A. Relative Compaction:

1. All costs for initial compaction tests shall be borne by the Owner. All areas that fail to meet the minimum compaction requirements shall be reworked as required by the Engineer and retested until minimum compaction requirements are obtained.
2. All The cost of any retests, including time for the Engineer, shall be borne by the Contractor at no additional cost to the project. Testing will be required as directed by the Engineer. Test locations shall be determined by the Engineer upon notification from the Contractor that the grade is ready for tests. Contractor shall be present when samples of bedding, select backfill, and backfill materials are gathered for analysis or testing.

B. Compaction tests will be performed for each lift or layer.

C. Tests for compaction shall conform to references listed in Part 1.3 of this section

D. Sample backfill materials per ASTM D 75.

E. Compaction testing will be performed in accordance with Section 19-5.03, State Standard Specifications.

1.6 *SAMPLES*

A. Submittals shall be in accordance with the General and Special Provisions.

1.7 *SUBMITTALS*

A. Submit plans as required for worker protection against caving ground in excavations.

B. Submittals shall be in accordance with the General and Special Provisions.

1.8 *CONTROL AND DIVERSION OF WATER*

A. General – The Contractor shall furnish or procure all materials and labor required for constructing and maintaining all necessary cofferdams, channels, flumes, drains, sumps, and/or other temporary diversion and protective works and shall furnish, install, maintain, and operate all necessary pumping and other equipment for removal of water from the various parts of the work and for maintaining the foundations and other parts of the work free from water.

B. Plan – Prior to beginning any work on the removal of water from trenches, the Contractor shall submit for the Engineer's approval a water control plan showing his proposed method for the removal of water from trenches and other parts of the work.

- C. Contractor can dewater into City sewer system. Contractor will inform the City Engineer if dewatering is required.
- D. Do not drain trench water through the pipeline under construction.

1.9 PROJECT CONDITIONS

- A. Underground utilities may exist at this site. Contractor shall take all necessary precautions to protect said utilities. Notify Engineer of any deviation in utility location from that which is shown on the drawings.
- B. Obtain all required permits and licenses before installing utilities and follow the rules and requirements of the authority having jurisdiction.
- C. Arrange construction sequences to provide the shortest practical time that the trenches will be open to avoid hazard to the public, and to minimize the possibility of trench collapse

PART 2 MATERIALS

2.1 SELECT AND IMPORT MATERIAL IN PIPE AND BEDDING ZONE

- A. Gravel: Pit run, natural stone; free of shale, clay, friable materials and debris; graded in accordance with 1½" x ¾" aggregate grading in Section 90-3, State Standard Specifications.
- B. Pea Gravel: Natural stone; washed, free of clay, shale, organic matter; 1/4-inch minimum to 5/8-inch maximum size.
- C. Sand: Natural river or bank sand; free of silt, clay, loam, friable or soluble materials, and organic matter, graded in accordance with Section 90-3, State Standard Specifications, within the following limits:

Sieve Size	Percent Passing By Weight
No. 4	75 – 100
No. 200	0 - 10

- D. Imported sand shall have a sand equivalent of 30 per ASTM D 2419.

2.2 NATIVE EARTH BACKFILL

- A. Native earth backfill used above the pipe zone shall be fine-grained materials free from roots, debris, and rocks larger than 3 inches.

2.3 SAND-CEMENT SLURRY

- A. Slurry cement backfill used in lieu of compacted soil shall contain not less than 188-pounds of Type II Portland Cement per cubic yard of concrete (2 sack) and shall comply with Section 19 of the State Standard Specifications.

2.4 WATER FOR COMPACTION

- A. Water shall be free of organic materials injurious to the pipe coatings, have a pH of 7.0 to 9.3, maximum chloride concentration of 500 mg/l, and a maximum sulfate concentration of 500 mg/l.

PART 3 EXECUTION

3.1 GENERAL

- A. Excavation, grading and compaction shall conform to the requirements of Section 19 of the State Standard Specifications.

3.2 INSPECTIONS

- A. Verify stockpiled material has been approved for reuse.
- B. Verify areas to be backfilled are free of debris, snow, ice, or water, and surfaces are not frozen.

3.3 PREPARATION

- A. Identify required lines, levels, contours, and datum.

3.4 AC PAVEMENT AND CONCRETE REMOVAL

- A. Cut bituminous and concrete pavements, regardless of the thickness, curbs, gutters and sidewalks prior to excavation of trenches.
 - 1. Width of material removed shall be as shown on the plans.
 - 2. AC pavement and concrete rubble shall not be used for trench backfill.

3.5 EXCAVATION

- A. Excavate the trench to the lines and grades shown on the Drawings for storm sewer, sanitary sewer, water, and other utilities and points of connection, with allowance for pipe thickness, sheeting and shoring if used, and for special bedding.
- B. Paved Areas: Cut existing pavement to full depth to a true line before excavation and maintain the edge suitable for repaving. Pavement removed shall not be used as backfill.

- A. Trenching Guidelines: Excavate the trench to the approximate level of the grade of the utility line to be installed, using adequate trench width and side slopes to safely accommodate worker access.
 - 1. Rocky Trench Bottom: Where ledge rock, hard pan, boulders, or sharp-edged materials are encountered, over excavate a minimum depth of 6 inches below the bottom of the utility exterior wall to permit adequate bedding preparation. The installed utility shall have at least 6 inches of clearance from any rock protrusion.
 - a. Unstable Trench Bottom: Secure approval of depth of over-excavation and stabilization method. For wet trench construction, use approved method of dewatering through diversion, damming and pumping, well points, or underdrain systems. Dispose of removed fluidized materials as approved. Use bedding material to build a suitable foundation to within 6 inches of finished utility grade, prior to bedding with the specified material. Compact layers to 95 percent of maximum density in not greater than 6-inch layers. Do not proceed with utility installation until wet trench and unstable conditions are corrected to the satisfaction of the Engineer.
- B. Remove areas of sub-grade not readily capable of it-situ compaction.
 - 1. Backfill with Bedding or Select Backfill material and compact to density equal to requirements for subsequent backfill.
- C. Correct unauthorized excavation at no cost to Owner.
 - 1. If the trench is excavated below the required grade, refill any part of the trench excavated below the grade.
 - 2. Place the refilling material over the full width of trench in compacted layers not exceeding 8 inches deep to the established grade with allowance for special bedding.
- D. Trench widths in the pipe zone shall be as shown on the drawings. If no details are shown, maximum width shall be 24 inches greater than the pipe outside diameter.
 - 1. Trench width at the top of the trench will not be limited except where width of excavation would undercut adjacent structures and footings. In such case, width of trench shall be such that there is at least 2 feet between the top edge of the trench and the structure or footing.
- E. Hand trim for bell and spigot pipe joints.
- F. Remove lumped soil, boulders and rock.
- G. Excavation shall not interfere with normal 45 degree bearing splay of foundations.

- H. During trench excavation, place the excavated material only within the working area. Do not obstruct roadways or streets. Conform to federal, state, and local codes governing the safe loading of trenches with excavated material.
- I. Foundation stabilization
 - 1. After the required excavation has been completed, the Engineer will inspect the exposed subgrade to determine the need for any additional excavation. It is the intent that additional excavation be conducted in all areas within the influence of the pipeline where unsuitable materials exist at the exposed subgrade. Over excavation shall include the removal of all such unacceptable material that exists directly beneath the pipeline to a width 24 inches greater than the pipe outside diameter and to the depth required.

3.6 *LENGTH OF OPEN TRENCH*

- A. Limit the length of open trench to 300 feet in advance of pipelaying or amount of pipe installed in one working day.
- B. Complete backfilling, temporary or first layer paving, not more than 400 feet in the rear of pipelaying.

3.7 *UNSUITABLE MATERIAL*

- A. Unsuitable material shall be excavated and disposed of in a lawful manner off the project site, all disposal shall be approved by the Engineer prior to initiating the work.

3.8 *DEWATERING*

- A. The Contractor shall keep all excavation free from water. Furnish, install, maintain, and operate all necessary pumping and other equipment for dewatering of excavations. The Contractor shall at all times have on the project sufficient pumping equipment for immediate use, including stand-by pumps for use in case other pumps become inoperable.
- B. The dewatering operation shall be continuous, so that the excavated areas are kept free from water during the construction, until backfill has been placed to a sufficient height to anchor the work against possible floatation.
- C. Dewatering devices shall be adequately filtered to prevent the removal of fines from the soil.
- D. Repair any damage caused by the failure of any part of the protective works. Remove temporary protective works when they are no longer needed for dewatering purposes.
- E. Any drain rock required in the trench bottom to convey water or stabilize wet soil shall be included at no extra cost to the Owner.

- F. Provision of dewatering and dewatering equipment shall be considered part of the project with no additional compensation allowed.

3.9 *BACKFILLING*

- A. Support pipe during placement and compaction of bedding fill.
- B. Backfilling and cleanup work shall be accomplished as sections of pipe or conduit are tested and approved. Vehicular travel through the work site shall be impeded or obstructed as little as possible.
- C. **Compaction:** Use vibratory compactors for sands and gravels (non-cohesive soils). Use mechanical tampers for sand and gravel containing a significant portion of fine-grained materials, such as silt and clay (cohesive soils). Hand tamp around pipe or cable to protect the lines until adequate cushion is attained. Puddling or water flooding for consolidation of backfill or compaction by wheel rolling will not be permitted.
- D. Employ a placement method that will not disturb or damage pipe or utilities.
- E. Maintain optimum moisture content of backfill materials to attain required compaction density.
- F. Compact trench backfill to the specified relative compaction. Compact by using mechanical compaction or hand tamping. Do not use high impact hammer type equipment except where the pipe manufacturer warrants in writing that such use will not damage the pipe.
- G. Compact material placed within 12 inches of the outer surface of the pipe by hand tamping only.
 - 1. Carefully place the material around the pipe so that the pipe barrel is completely supported and that no voids or uncompacted areas are left beneath the pipe.
 - 2. Use particular care in placing material on the underside of the pipe to prevent lateral movement during subsequent backfilling.
- H. After pipe has been bedded, place pipe zone material simultaneously on both sides of the pipe, in maximum 8-inch lifts, keeping the level of backfill the same on each side.
- I. Do not use any axle-driven or tractor-drawn compaction equipment within 5 feet of building walls, foundations, and other structures.
- J. Do not permit free fall of the material until at least 2 feet of cover is provided over the top of the pipe. Do not drop sharp, heavy pieces of material directly onto the pipe or the tamped material around the pipe. Do not operate heavy equipment over the pipe until at least 3 feet of backfill has been placed and compacted over the pipe.

- K. Remove surplus backfill materials from site.
- L. Leave stockpile areas completely free of excess fill materials.

3.10 TOLERANCES

- A. Top Surface of Backfilling: Plus or minus 0.1 foot.

3.11 SAND CEMENT SLURRY, CONCRETE ENCASEMENT AND THRUST BLOCKS

- A. Place in accordance with the Contract drawings.

3.12 COMPACTION REQUIREMENTS

- A. Relative compaction requirements shall be as shown on the Plans:

END OF SECTION

SECTION 32 11 23
AGGREGATE BASE

PART 1 GENERAL

1.1 WORK INCLUDED

- A. Furnish, spread, and compact aggregate base in trench patches, sidewalks, curb and gutter and other paved areas as shown on the Plans.
- B. The work of this section consists of furnishing and placing aggregate base material and/or lean concrete base materials, and filler if required, on the prepared subgrade.

1.2 RELATED WORK

- A. Section 31 23 17 - Trenching Backfilling and Compacting
- B. Section 32 12 16 – Asphalt Concrete Paving

1.3 REFERENCES

- A. Section 10-6 – Watering, State Standard Specifications.
- B. Section 26 – Aggregate Bases, State Standard Specifications.
- C. Section 28-2 - Lean Concrete Base, State Standard Specifications.
- D. ANSI/ASTM C136 – Sieve Analysis of Fine and Coarse Aggregates.
- E. ANSI/ASTM D1557 – Moisture-Density Relations of Soils and Soil-Aggregate Mixture Using 10 lb (4.54 kg) Hammer and 18-inch (457 mm) Drop.
- F. ANSI/ASTM D1556 – Density of Soil and Base Rock in Place by Sand-Cone Method.
- G. ASTM D6938 – Density of Soil and Base Rock in Place by Nuclear Method.
- H. City of Los Banos, Improvement Standards & Specifications

1.4 SUBMITTALS

- A. Submittals shall be in accordance with the General and Special Provisions.
- B. If materials are obtained from a commercial source, submit certification from the supplier certifying that aggregate base course meets the requirements of this section.

- C. Copies of certified weight tickets for each load of aggregate delivered to the project site.

1.5 QUALITY ASSURANCE

A. Relative Compaction:

1. All costs for initial compaction tests shall be borne by the Owner. All areas that fail to meet the minimum compaction requirements shall be reworked as required by the Engineer and retested until minimum compaction requirements are obtained.
2. The cost of any retests, including time for the Engineer, shall be borne by the Contractor at no additional cost to the project. Testing will be required as directed by the Engineer. Test locations shall be determined by the Engineer upon notification from the Contractor that the grade is ready for tests. Contractor shall be present when samples of bedding, select backfill, and backfill materials are gathered for analysis or testing.

B. Compaction tests will be performed for each lift or layer.

C. Tests for compaction shall conform to references listed in Part 1.3 of this section

D. Sample backfill materials per ASTM D75.

E. Compaction testing will be performed in accordance with Section 19-5 of the State Standard Specifications.

1. Compaction testing of areas to be saw cut and replaced shall be one for every 300-LF of adjacent curb and gutter but not less than one for each curb cut area.
2. The Contractor shall not proceed with work over the area being tested until results have been verified by the Engineer. Immediately upon completion of each compaction test, a copy of the results shall be given by the testing laboratory to the Engineer.

F. The percentage composition by weight shall conform to Class 2 aggregate base determined by Test Method No. Calif. 202, modified by Test Method No. Calif. 905 if there is a difference in specific gravity of 0.2 or more between the coarse and fine portion of the aggregate or between blends of different aggregates.

G. Aggregate base shall also conform to the following quality requirements:

<u>Tests</u>	<u>Test Method</u>
R-Value	<u>Calif. No</u> 301
Sand Equivalent	217
Durability Index	229

H. Quality Control shall be under the provisions in the General Conditions.

PART 2 PRODUCTS

2.1 MATERIALS

A. AGGREGATE BASE

1. Class 2 Aggregate Base, $\frac{3}{4}$ -inch maximum; as per Section 26-1.02B, State Standard Specifications.
2. Aggregate for Class 2 aggregate base shall be free from organic material and other deleterious substances

B. LEAN CONCRETE BASE

1. Lean Concrete Base shall conform to the State Standard Specifications, Section 28-4, Lean Concrete Base Rapid Setting.
2. State Standard Specifications Section 28-4.04 shall not apply.

C. WATER

1. As specified in State Standard Specifications.
2. At the time aggregate base is spread, it shall have a moisture content sufficient to obtain the require compaction. Such moisture shall be uniformly distributed throughout the materials.

PART 3 EXECUTION

3.1 SUBGRADE PREPARATION

- A. As specified in State Standard Specifications.

3.2 SPREADING

- A. The aggregate base course material shall be deposited and spread to the required compacted thickness by means that will maintain the uniformity of the mixture. The aggregate base course shall be free from pockets of coarse or fine material.

- B. Deliver aggregate base to the area to be paved as a uniform mixture and spread each layer in one operation.
- C. Aggregate base placed at locations which are inaccessible to the spreading equipment shall be spread in two layers by any means to obtain the specified results.
- D. The aggregate shall not be treated with lime, cement or other chemical materials before the Durability Index test has been performed.
- E. The surface of the finished aggregate base at any point shall not vary more than ± 0.05 -foot from the grade shown.

3.3 *PLACING*

- A. If the required compacted depth of the aggregate base course exceeds 6 inches, place course in two or more layers of approximately equal thickness. The maximum compacted thickness of any one layer shall not exceed 6 inches.

3.4 *MIXING*

- A. Mixing shall be in accordance with one of the methods set forth in State Standard Specifications, Section 28-4.03B.

3.5 *MOISTURE CONTROL*

- A. When spread, aggregate base shall have a moisture content sufficient to obtain the specified compaction.

3.6 *SURFACE FINISHING*

- A. Use a smooth steel wheel roller for the final rolling of top surface base course. Water surface and evenly spread loose stones before final rolling. Make minimum of two complete passes over area to embed stones. Correct soft spots developed during rolling.
- B. Compacted aggregate base course surface shall be smooth and free from waves and other irregularities. Unsatisfactory portions of base course shall be corrected, at no additional expense to the Owner.

3.7 *MATERIAL ACCEPTANCE REQUIREMENTS*

- A. Acceptance will be based on periodic samples and tests taken following mixing and before placing.

3.8 *TOLERANCES*

- A. Surface: The finished surface of the base course will be tested with a 10-foot straightedge or other device. The variation between any two contacts with the surface shall not exceed ± 0.05 feet.

- B. Width: Plan dimension, ± 0.10 feet.
- C. Thickness: Plan dimension, ± 0.05 feet.
- D. Any areas not complying with these tolerances shall be reworked to obtain conformity, at no additional expense to the Owner.

3.9 MAINTENANCE

- A. Maintain base course in a satisfactory condition until surfaced or until final acceptance.

END OF SECTION

SECTION 32 12 16
ASPHALT CONCRETE PAVING

PART 1 GENERAL

1.1 WORK INCLUDED

- A. The work of this section consists of constructing one or more surface courses composed of a mixture of aggregate, filler if required, asphalt material and placed on a prepared base to lines, grades and details, as shown on the plans and covered within these specifications. This section includes asphalt patching for areas where utility lines cross existing paved surfaces, trench resurfacing, saw cutting and resurfacing additional paving widths as required in the contract or under permit requirements.
- B. Mix aggregate and asphalt binder at a central mixing plant. Haul, spread, and compact the mixture for paved areas as shown and as specified.
- C. Upon completion of all paving, finish the entire roadway. Trim and shape, cut and fill slopes to produce smooth surfaces and uniform cross sections. Clean the finished pavement of all dirt and foreign material.
- D. Cross sections of paving shall be as indicated in the Plans.

1.2 RELATED WORK

- A. Section 31 23 17 - Trenching Backfilling and Compacting
- B. Section 32 11 23 – Aggregate Base

1.3 REFERENCES

- A. Section 22 – Finishing Roadway, State Standard Specifications
- B. Section 39 – Asphalt Concrete, State Standard Specifications
- C. Section 92 – Asphalt Binders, State Standard Specifications
- D. Section 94 – Asphaltic Emulsions, State Standard Specifications
- E. Section 96 – Geosynthetics, State Standard Specifications

1.4 SUBMITTALS

- A. Submittals shall be in accordance with the General and Special Provisions.
- B. Certificates:

1. Certification from the supplier that the asphalt concrete is of correct type and meets requirements of this section.
2. Job mix formula shall be submitted with certification that the mix formula meets the requirements of Standard Specification Specifications Section 39, Asphalt Concrete. The job mix formula shall include definite single values for:
 - a. The percent of aggregate passing the specified sieve, based on dry weight of aggregate.
 - b. The percent of bituminous material to be added, based on the total weight of the mix.
 - c. Kind and amount of chemical additives (anti-stripping, hydrated lime, etc.) as established by the design procedure.
 - d. Maximum theoretical density.
 - e. Temperature ranges for the bituminous material at the point of mixing with the aggregates and bituminous mixture at the paving machine.

1.5 QUALITY ASSURANCE

- A. Asphalt concrete supplier to prepare a mix design; to recommend adjustments to the proportions of the mix, as necessary, to conform to the mix design; and to consult with the Contractor and the Engineer during paving as required.
- B. Testing required to, determine compliance for the work of this section shall be performed by an independent testing laboratory, approved by the Engineer and appointed and paid for by the Contractor. The independent testing laboratory shall be used to sample and test asphalt concrete at the job sites. One test shall be taken for each paving period and at least one test every four hours. As a minimum, results of the test shall include items A, B, C and E of the job mix formula submittal.
- C. Density: Acceptable density of the in-place asphalt concrete pavement shall be 95 percent of the optimum values as determined from the mix design formula. Field sampling and density determination shall be made in accordance with AASHTO T230-68, or an accepted nuclear procedure.
- D. Testing shall be performed in such a manner that will least encumber the performance of the work. The Contractor shall cooperate by rerouting equipment or by temporarily closing the immediate work area to be tested.
- E. Contractor shall instruct the testing laboratory to provide the test results to the Engineer immediately in the field and a copy of the written report sent directly to the Engineer.

PART 2 PRODUCTS

2.1 ASPHALTS

- A. Asphalt binder to be mixed with aggregate shall be liquid asphalt PG 64-16, conforming to State Standard Specifications Section 92, Asphalt Binders.
- B. Asphalt Concrete shall be Type A, in accordance with State Standard Specifications 39-2.02.

2.2 AGGREGATE

- A. The combined aggregate grading of the asphalt concrete shall be Type A, 3/4-inch maximum grading, per Section 39-2.02B(4)(b), of the State Standard Specifications.

PART 3 EXECUTION

3.1 GENERAL

- A. The pavement section shall comply with City of Los Banos Standards and as shown on the Plans.
- B. Prior to any paving and surfacing operations, all pipes and conduits shall be installed and properly backfilled as shown.

3.2 STORAGE

- A. Storage of materials shall comply with the requirements of Section 39, State Standard Specifications.

3.3 MIXING

- A. Mixing shall conform to the approved mix design.
- B. The weight of asphalt binder to be mixed with aggregate shall be between 3 percent and 7 percent of the weight of the dry aggregate.

3.4 SUBGRADE

- A. Subgrade shall conform to Section 39-2.01C(3)(b), State Standard Specifications.
- B. Unless otherwise specified, the upper six inches of subgrade beneath the structural section shall be scarified, moisture conditioned as necessary and compacted to at least 95 percent relative density.

3.5 EQUIPMENT

- A. Spreading and compacting equipment shall conform to State Standard Specifications Section 39-2.01C(2), Spreading and Compacting Equipment.

3.6 *PLACING AND COMPACTING*

- A. Placing and compacting shall conform to State Standard Specifications Section 39-2.05(3)(d), Placing and Compacting Hot Mix Asphalt.
- B. Apply mixture only during hours of daylight; when air temperature is 50 degrees F or higher; when surfaces to be paved are dry and free of frost, snow or ice; and when precipitation is not imminent.

3.7 *FINISHING PAVED AREAS*

- A. Finishing roadway and parking areas shall conform to the provisions of State Standard Specifications Section 22, Finishing Roadways.

3.8 *TRENCH RESURFACING*

- A. At areas where asphalt concrete had been removed due to pipeline construction, trench shall be resurfaced with asphalt concrete. Unless otherwise noted, asphalt concrete resurfacing shall match the existing thickness of the asphalt and base course removed.
 - 1. Base course shall be as specified in Section 32 11 23, Aggregate Base, and in this Section.
- B. If an edge of a trench resurfacing occurs within three feet of an existing edge of pavement, lip of gutter or the face of curb, or if no gutter is present, the Contractor shall remove all existing paving to the lip of gutter or curb face and or, edge of existing pavement and resurface with the applicable trench resurfacing section. The limits of removal are minimum requirements.
- C. If during the Contractor's operations pavement is disturbed outside the limits of removal, Contractor shall make the necessary repairs at no additional cost to the Owner.

3.9 *ACCEPTANCE REQUIREMENTS*

- A. Surface Tolerance: The variation between any two contacts with the surface shall not exceed ± 0.015 foot in 10 feet. Correct all humps or depressions exceeding the specified tolerance by removing defective work and replacing it with new material at no additional expense to the Owner.
- B. A uniform compacted thickness shall be obtained for each course equal to or greater than the thickness shown. Individual tests shall not vary by more than ± 0.02 foot.
- C. Width: Plan dimension, ± 0.02 foot.
- D. Thickness: Plan dimension, ± 0.02 foot.

END OF SECTION

SECTION 32 17 23

TRAFFIC SIGNING, STRIPING AND MARKING

PART 1 GENERAL

1.1 WORK INCLUDED

- A. This section includes removal and installation of traffic signs, markers, posts, pavement striping, pavement markings, raised pavement markers, and curb markings.

1.2 REFERENCES

- A. American Society for Testing and Materials (ASTM)
- B. State of California, Business, Transportation, and Housing Agency, Department of Transportation Standard Specifications, 2015 edition and Standard Plans, 2015 edition (State Standard Specifications and State Standard Plans)

1.3 SUBMITTALS

- A. Submittals shall be in accordance with the General and Special Provisions.

PART 2 PRODUCTS

2.1 SIGNS AND ROADSIDE MARKERS

- A. Conform to Section 56 of the State Standard Specifications and Standard Plans.
- B. Signs or material shall conform in size and design to the latest editions of the FHA publication "Standard Highway Signs," the Caltrans' Sign Specification Sheets, and the California Manual on Uniform Traffic Control Devices (California MUTCD) and the Caltrans' Supplement thereto as to color, shape, and style of letters or symbols. Signs shall be of standard size or as noted on the Drawings.
- C. Material:
 - 1. Metal: Base metal shall be sheet aluminum, 0.080 inch thick, Alloy 6061-T6 or 5052-H38 in conformance with ASTM B209.
 - 2. Reflective Sheeting: Reflective sheeting, whether used as legend or background, shall be FHWA FP-85 Type IIA (Super Engineering Grade).
 - 3. The reflective material and screening inks or overlay film shall be graffiti-proof. The method for graffiti proofing shall be F-cal by Nikkalite or equal. Neither the color nor the reflective intensity of the finished sign shall be significantly diminished by the use of graffiti remover.

2.2 STRIPING AND PAVEMENT MARKING

- A. Traffic stripes and pavement markings, including legends, shall be thin-mil thermoplastic (sprayable) as indicated on the Drawings.
- B. Curb markings and median island markings shall be AQMD- or APCD-compliant paint material.
- C. Striping and raised pavement markers shall comply with State Standard Plans A20A, A20B, A20C, and A20D.
- D. Pavement markings shall comply with State Standard Plans A24A, A24B, A24C, A24D, and A24E. Paint
- E. Paint shall be fast or rapid-dry type solvent conforming to Section 84 of the State Standard Specifications and shall meet requirements of San Joaquin Valley Air Pollution Authority. Apply the paint at the rate recommended by the manufacturer.

2.3 THIN-MIL THERMOPLASTIC (SPRAYABLE)

- A. Thin-mil thermoplastic traffic stripes and pavement markings shall conform to Sections 84-1 and 84-2 of the State Standard Specifications.
- B. Pre-mix glass beads within the thermoplastic material and apply immediately after spraying.

PART 3 EXECUTION

3.1 REMOVAL OF EXISTING MARKINGS

- A. Remove existing striping, pavement markings, curb marking, and raised pavement markings superseded by the Drawings. Remove conflicting striping within limit of project.
- B. Removal of stripes and markings shall be by sandblasting. Remove thermoplastic and pavement tape striping by grinding or abrasive blasting.

3.2 TEMPORARY STRIPING

- A. Contractor is responsible for installing temporary stop limit lines and lane lines after completing the paving work and prior to opening the streets to traffic. Temporary traffic striping shall be installed within 24 hours after paving the street.
- B. Temporary limit lines shall be reflective tape designed for traffic application. Minimum width of tape shall be eight inches
- C. Temporary lane lines shall be reflectorized chip seal markers (single for 4-inch line; double for 8-inch line) at 24 feet on center.

- D. No additional payment to the Contractor shall be made for installation of temporary pavement striping.

3.3 FINAL STRIPING

- A. Final stripes and markings, including limit lines, shall be placed within 72 hours after the street has received the final surface course or fog seal and after temporary striping and markings have been removed.
- B. Restripe any existing striping on cross streets that are disturbed by construction.
- C. Apply striping only during daylight hours when the temperature exceeds 55 degrees F, weather conditions are favorable and the pavement surface is clean and dry.

3.4 INSTALLATION OF THIN-MIL THERMOPLASTIC (SPRAYABLE)

- A. Apply thin-mil thermoplastic material for traffic stripes by spray method in single uniform layer at the minimum thickness of 30 mils and not to exceed 45 mils.
- B. Apply thin-mil thermoplastic material to the pavement at a temperature between 350°F and 400°F, unless the manufacturer recommends a different temperature.

3.5 PROTECTION AND ACCEPTANCE

- A. Protect pavement markings until dry or bonded by placing guards or warning devices as necessary and in accordance with MUTCD. In the event any vehicle should cross the wet marking, such marking shall be reapplied and marks, made by the vehicle, removed by the Contractor at no additional expense to the Owner.
- B. Markings shall be accurately placed, and appear clean and uniform day and night. Unsatisfactory markings shall be corrected at no additional expense to the Owner.
- C. The Contractor shall remove and replace at no additional expense to the Owner and to the satisfaction of the Engineer any material which exhibits any of the following deficiencies:
 - 1. Non adherence to paving surface.
 - 2. Material improperly set or tracked.
 - 3. Insufficient film thickness or width of stripe.
 - 4. Insufficient glass bead coverage or retention.
 - 5. Materials spilled or improperly placed.

3.6 APPLYING PAINT FOR TRAFFIC AND PARKING LOT STRIPING AND MARKING

- A. Apply in accordance with Section 84 of the State Standard Specifications.

3.7 *INSTALLING PAVEMENT MARKERS*

- A. After the application of pavement striping and markings, install markers on new paved surfaces and existing surfaces that were damaged by the construction. Install in accordance with Section 84 of the State Standard Specifications.
- B. Use markers that are reflective and match the color or combination of colors of existing markers within the area of work. Install markers along the alignment and match spacing of the existing.

END OF SECTION

SECTION 33 01 00
PIPE AND FITTINGS

PART 1 GENERAL

1.1 WORK INCLUDED

- A. Furnish, install, and test all water, utility, pipe, fittings, and appurtenances as indicated and as specified.
- B. Section 31 23 17 – Trenching, Backfilling, and Compacting

1.2 REFERENCES

- A. California Plumbing Code.
- B. American Water Works Association Standards,

1.3 SUBMITTAL REQUIREMENTS

- A. Submit shop drawings in accordance with the General and Special Provisions.
- B. Submit manufacturer's catalog data. Show manufacturer's model number.
- C. Submit dimensions including wall thickness and materials of construction by reference standard and grade. Submit information on interior and exterior coatings as applicable.

1.4 QUALITY ASSURANCE

- A. All work performed under this section shall meet all recommendations and requirements of AWWA, California Plumbing Code (CPC), NFPA 24, ASTM D2774, and all other applicable national, state, local, standards and regulations.

1.5 MATERIALS

- A. All materials in contact with potable water shall be certified to ANSI/NSF Standard 61.

PART 2 PRODUCTS

2.1 POLYVINYL CHLORIDE WATER PIPE (PVC)

- A. General: PVC shall conform to AWWA C900, DR 14 unless otherwise specified.

- B. Each length of pipe shall be marked with the manufacturer's name, nominal size, pressure classification, and date of manufacture.
- C. Joints: Joints shall be push-on type couplings or integral socket bell PVC pipe unless otherwise shown with rubber gaskets conforming to ASTM D 3139 and ASTM F 477. Integral socket bells of PVC pipe or separate couplings shall meet the same strength requirements as that of the pipe. All component parts of each joint including gaskets and coupling shall be clearly marked for use with the pipe for which they are intended.
- D. Fittings: Fittings shall be of ductile iron conforming to ANSI A21.10 (AWWA C153) with push-on joint bell to fit the particular make of pipe furnished. Fittings shall have a pressure rating at least equivalent to that of the pipe used and shall be cement-mortar lined in accordance with ANSI A21 (AWWA C104).
- E. Fittings: Fittings shall be of ductile iron conforming to ANSI A21.10 (AWWA C 153) for mechanical joints. Dimensional and material requirements for pipe ends, glands, bolts, nuts, and gaskets shall conform to ANSI A 21.11 (AWWA C111). Pipe smaller than 4 inches shall have screwed or grooved joints

2.2 *MARKER TAPE FOR BURIED PIPING*

Per section 33 05 26 Utility Line Marking.

2.3 *TRACER WIRE*

Install No. 10 solid-core copper tracer wire.

2.4 *JOINT RESTRAINT COUPLINGS*

- A. Mechanical joint restraint coupling shall be of the type that utilizes the follower gland, and shall consist of several individual lug bolts with gripping mechanism that prevents the joints from pulling apart. Glands shall be ductile iron conforming to ASTM A536-14, and dimensions shall be compatible to be used with standard mechanical joint fittings for ductile rim pipe. The mechanical restraint joint shall have a minimum working pressure rating equal to that of the pipe with a safety factor of not less than 2. Restrained joints shall have twist off nuts to insure proper installation of restraining grip mechanism. Mechanical joint restrained coupling shall be EBAA, Iron, Inc. MEGALUG; with Mega-Bond coating.; or approved equal. Coating of gland follower body shall be electrostatically applied and heat cured polyester based powder. Wedge assemblies and bolts shall be coated with heat cured fluoropolymer coatings. Restraints shall be designed for the specific type of pipe to be restrained.
- B. Restrained joint fittings shall meet Uni-B-13 for PVC and be FM and UL approved through 12 inch for both ductile iron and PVC.
- C. Restrained joint fittings shall be manufactured by Romac or City approved equal.

2.5 FASTENERS

- A. All fasteners shall include washers under both bolt head and nut unless the use of washers is incompatible with the fitting design.
- B. Unless otherwise noted, all bolts, tie rods, and T-bolts used to secure flanges, fittings, and couplings located underground or submerged in liquid shall be Type 304 or 316 stainless steel per ASTM A320 or ASTM A193. Nuts shall be 304 or 316 stainless steel per ASTM A 194 and washers shall be ASTM F436 Type 3.
- C. Unless otherwise noted, all bolts, tie rods, and T-bolts used to secure flanges, fittings, and couplings located indoors, above grade, and in vaults shall be carbon steel conforming to ASTM A307, Grade B with ASTM A563A nuts and ASTM F436 washers. Bolts, nuts, and washers shall be hot dipped galvanized in accordance with ASTM F2329. Stainless steel meeting the requirements of Paragraph B shall also be acceptable.

PART 3 EXECUTION

3.1 HANDLING AND DISTRIBUTION OF MATERIALS

- A. **Delivery:** Handle pipe carefully to ensure delivery at the project site in sound, undamaged condition. Contractor shall replace damaged pipe at no additional expense to the Owner.
- B. **Storage:** Do not store materials directly on the ground. Adequately support piping to prevent warping. Use protective covers where pipe may be damaged by direct sunlight.
- C. No more than one week's supply of material shall be distributed in advance of pipe laying operations, unless otherwise approved or required.
- D. Before laying, pipe shall be inspected for cracked, broken, or defective pieces. Such pieces shall be rejected. Pipe shall be carefully lowered into the trench to prevent damage. All dirt or other foreign matter shall be removed from inside the pipe before lowering into the trench.

3.2 INSTALLATION OF BURIED PRESSURE PIPING

- A. **General:** Pipe, fittings, and appurtenances shall be installed in accordance with the manufacturer's instructions and in accordance with the following references as appropriate:
 - 1. Ductile Iron Pipe - AWWA C600
 - 2. Polyvinyl Chloride Pipe - AWWA C900.
- B. **Handling:** The pipe shall be protected to prevent entrance of foreign materials during laying operations. When laying is not in progress, open pipe ends shall be

protected with a watertight plug or other approved means to exclude water or foreign material.

C. Alignment:

1. Mains shall be installed to the grades and elevations indicated and shall have a minimum cover of 30-inches from the top of the pipe to existing ground or paved surface unless otherwise indicated.
2. The allowable angle of deflection at any joint shall not exceed the amount recommended by the pipe manufacturer for the particular pipe size used. Deviation of any pipe section from the line and grade indicated shall not exceed 1/2-inch.

D. Joints:

1. Pipe shall be assembled and joined in accordance with the manufacturer's published instructions for the type of pipe and joint used. All portions of the joints shall be thoroughly cleaned before the sections of pipe are assembled. The ends of each pipe shall abut against the next pipe section in such a manner that there shall be no unevenness of any kind along the bottom half of the interior of the pipe. Where mechanical joints are used, the pipe shall be marked in such a manner that it can be determined after installation that the pipe is properly seated.
2. Where flexible couplings are used as expansion joints, the ends of the pipes shall be separated 1-inch to allow for expansion. The welded seam at the end of each coupled steel pipe shall be ground smooth for approximately 12-inches. Couplings shall be centered on pipe ends. Runs of pipe containing flexible couplings shall be properly blocked, anchored or tied to the structure to prevent joints from separating.
3. Mechanical restrained joints shall be installed in accordance with joint manufacturer's instructions and recommendation.

- E. Installation of Marker Tape: Install tape in backfill directly over each pipeline, 24 inches over top of pipe, unless shown otherwise on the Plans. Where utilities are buried in a common trench, identify each line by a separate marker tape. Place tapes directly over the applicable line.

3.3 *THRUST BLOCKS OR MECHANICAL RESTRAINED JOINTS*

- A. Thrust blocks shall be used only where specifically allowed on the drawings or with prior approval by the Engineer.
- B. Place concrete thrust blocks at all tees, elbows, plugs, and other locations where unbalanced forces exist in underground pipe in accordance with details shown. Place blocks between undisturbed ground and fitting to be anchored. Place blocking so that pipe and fittings will be accessible for repairs. Thrust blocks shall be of such size as to give bearing against undisturbed vertical earth banks

sufficient to absorb the thrust from line pressure, allowing a maximum earth bearing pressure of 500 pounds per square foot per foot of depth below natural grade or as shown.

- C. Restrained joint fittings may be used in-lieu of thrust blocks, at the discretion of the Engineer. Contractor shall submit shop drawings showing methods of joint restraint for each type of restrained joint fitting to be used including the length of pipe having restrained push-on joints on all pipes which connect to the restrained fitting.
- D. When it is necessary to restrain push-on joints adjacent to restrained fittings, a harness restraint device shall be used. All harnesses shall have a pressure rating equal to that of the pipe on which it is used. Harness assemblies including tie bolts conform to ASTM A536-80.

3.4 ACCEPTANCE TESTS FOR BURIED PRESSURE PIPING

- A. General.
 - 1. All testing and inspection shall be performed after final backfill and compaction operations are complete. If the Contractor so desires, he may pretest the lines at his own expense, but final testing must be performed after compaction requirements have been approved.
- B. In general, tests shall be conducted in accordance with AWWA C600 and C651 except as otherwise herein specified.
- C. All newly installed sections of buried pressure piping shall be pressure and leakage tested as described herein.
 - 1. For buried pressure pipelines, tests shall be made on two or more valved sections not to exceed 2,500 feet in length. The Contractor shall furnish all necessary equipment, material and labor required.
 - 2. Tests shall be made after the trench has been backfilled and compacted, but not until at least 5 days have elapsed since any thrust blocks in the section have been poured.
 - 3. The pipe shall be slowly filled with water and ensuring all air expelled from section being tested. The line shall stand full of water for at least twenty-four hours prior to testing to allow all air to escape. A test pressure equal to 1.5 times the design pressure, of the pipe measured at the point of lowest elevation pressure, or 100 psi, whichever is greater, shall be applied.
 - 4. The test pressure in the line shall be maintained for a period of 2 hours. Test pressure shall be maintained within 5 psi during the test period. Conduct a leakage test concurrently with the pressure test. Leakage is defined as the volume of water that must be supplied into the newly laid pipeline to maintain pressure within +/- 5 psi of the test pressure after it is filled and purged of air. The water required to maintain test pressure shall

be measured by means of a graduated barrel, drum, or similar device at the pump suction or through a meter.

Allowable leakage at the specified test pressure shall not exceed the amounts allowed by AWWA C600, $L = \frac{SD\sqrt{P}}{148,000}$

Where:

L = Testing allowance in gallon per hour.

S = Length of pipe tested in feet.

D = Nominal diameter of the pipe in inches.

P = Average test pressure during the hydrostatic test, in pounds per sq. inch.

Hydrostatic testing allowance per 1,000 ft. of pipeline in gph.

PSI	4"	6"	8"	10"	12"	14"	16"	18"	20"	24"
200	0.38	0.57	0.76	0.96	1.15	1.34	1.53	1.72	1.91	2.29
175	0.36	0.54	0.72	0.89	1.07	1.25	1.43	1.61	1.79	2.15
150	0.33	0.50	0.66	0.83	0.99	1.16	1.32	1.49	1.66	1.99
125	0.30	0.45	0.60	0.76	0.91	1.06	1.21	1.36	1.51	1.81
100	0.27	0.41	0.54	0.68	0.81	0.95	1.08	1.22	1.35	1.62

- Should testing disclose any visible leaks or leakage greater than that allowed, the defective joints or pipe shall be located, repaired, and re-tested until satisfactory. The cost of any retests, including time for the Engineer, shall be borne by the Contractor at no additional cost to the project.

END OF SECTION

SECTION 33 05 26
UTILITY LINE MARKING

PART 1 GENERAL

1.1 WORK INCLUDED

- A. The work of this section consists of furnishing and installing utility line marking.

1.2 SUBMITTALS

- A. Submittals shall be in accordance with the General and Special Provisions.
- B. Samples: 24-inch strips of tape and 2 markers.
- C. Certification that the materials used in the tape fabrication meet the requirements of this section.

PART 2 PRODUCTS

2.1 MARKING TAPE

- A. Capable of being inductively detected electronically.
- B. Construction: Metallic foil laminated between two layers of impervious plastic film not less than 3 inches wide. Total thickness of tape shall not be less than 0.005 inch (5 mil) plus or minus 10 percent manufacturing tolerances.
 - 1. Film: Inert plastic. Each film layer shall be not less than 0.001-inch-thick (1.0 mil).
 - 2. Foil: Not less than 0.001-inch-thick (1.0 mil).
 - 3. Adhesive: Compatible with foil and film.
- C. Imprint: 3/4-inch or larger bold black letters.
- D. Legend: Identify buried utility line tape with imprint such as "Caution: Sewer Line Below". Repeat identification at approximately 24-inch intervals.

E. Background Color: APWA color code and as specified below:

Color	Utility
Safety Red	Electric
High Visibility Safety Yellow	Gas, Oil, Steam, Dangerous Materials
Safety Alert Orange	Telephone, Communications, Cable Television
Safety Precaution Blue	Water System, Irrigation
Safety Green	Sanitary Sewer, Storm Sewer
Safety Brown	Force Mains and Effluent Lines
Purple	Reclaimed Water

F. Manufacturer: Lineguard, Inc., Wheaton, Illinois; Reef Industries, Inc., Houston, Texas; Thor Enterprises, Inc., Sun Prairie, Wisconsin; or Engineer approved equivalent.

2.2 TRACER WIRE

A. Minimum: No.10, solid, 12 AWG copper wire with Type TW insulation, and shall form a mechanically and electrically continuous line throughout the length of the pipe.

PART 3 EXECUTION

3.1 MARKING TAPE

- A. Install tape in backfill 24 inches above over each buried utility line as shown on the detailed drawings.
- B. Where utilities are buried in a common trench, identify each line by a separate warning tape. Bury tapes side by side directly over the applicable line.

3.2 TRACER WIRE

- A. Wherever PVC or Polyethylene pipe is installed in the ground, a tracer wire shall be installed. Conductors shall be spliced in accordance with Division 16 - Electrical.
 - 1. Tracer wire shall be brought to the surface at all valves, air valves, blow-offs, Fire Hydrants Water Services and other pipeline appurtenances
- B. Tracer Wire: Attachment of the wire to the pipe shall be made with plastic tie-wraps or other approved method.

- C. Contractor shall conduct a satisfactory continuity test prior to Owner acceptance.

END OF SECTION

SECTION 33 12 19

FIRE HYDRANTS

PART 1 GENERAL

1.1 WORK INCLUDED

- A. The work of this section consists of furnishing and installing new fire hydrants, relocating existing hydrants and salvaging existing hydrants. The work of this section also includes appurtenant auxiliary valves and valve boxes.
- B. Furnish, install, and test all hydrants, valves, water piping to main and appurtenances as indicated and as specified.

1.2 RELATED WORK

- A. Section 03 33 15 – Concrete Sidewalk, Curb and Gutter
- B. Section 40 05 00 – Pipe and Fittings
- C. Section 40 05 23 – Valves and Appurtenances
- D. Section 33 13 00 – Disinfection of Water Distribution System

1.3 REFERENCES

- A. Uniform Plumbing Code.
- B. American Water Works Association Standards.
- C. Section 90, "Portland Cement Concrete", State Standard Specification.

1.4 SUBMITTALS

- A. Submittals shall be in accordance with the General and Special Provisions.
- B. Catalog cuts, complete with maintenance data and assembly drawings for valve and hydrant.
- C. Certification from manufacturer that hydrant complies with AWWA C502.

1.5 CLOSEOUT SUBMITTALS

- A. As specified in Section 01 77 00 – Contract Closeout.
- B. Tools: One hydrant wrench, sized to fit caps provided, for every six hydrants furnished.
- C. Spare Parts: One set of break-off parts for every six hydrants.

- D. Auxiliary Valve Extension Handles: Two handles for each size valve.
- E. Manufacturer's operation and maintenance data for fire hydrants and auxiliary valves.

PART 2 PRODUCTS

2.1 HYDRANTS

- A. Hydrants shall comply with AWWA C502 and the following requirements:
 - 1. Manufacturer: Waterous Pacer or AVK 2700
 - 2. Installed per City of Los Banos Standard Detail W-2

2.2 THRUST BLOCKS

- A. Installed per City of Los Banos Standard Detail W-2

PART 3 EXECUTION

3.1 REMOVAL AND SALVAGE OF EXISTING HYDRANTS

- A. Water supply to hydrant shall be shut-off by closing the auxiliary gate valve to hydrant.
- B. Soil around hydrant shall be excavated with care not to disturb existing utility to remain in service and so as not to damage hydrant, auxiliary gate valve, valve box, or other appurtenances.
- C. Hydrant shall be disconnected from service at auxiliary gate valve. A blind flange shall be installed on auxiliary gate valve, for possible future connection. Hydrant shall be removed from excavation, cleaned and stored to prevent damage until reinstalled.
- D. Excavation shall be backfilled, providing proper cover and protection of remaining auxiliary gate valve. Final grading of area shall match existing grade.
- E. Hydrants not reinstalled shall be cleaned from any foreign material and delivered to park maintenance as directed by Engineer.

3.2 RELOCATION OF EXISTING HYDRANTS

- A. Water supply to hydrant shall be shut-off by closing the auxiliary gate valve to hydrant.
- B. Soil around hydrant shall be excavated with care not to disturb existing utility to remain in service and so as not to damage hydrant, auxiliary gate valve, valve box, or other appurtenances.

- C. Hydrant shall be disconnected from service at auxiliary gate valve. A blind flange shall be installed on auxiliary gate valve, for possible future connection. Hydrant shall be removed from excavation, cleaned and stored to prevent damage until reinstalled.
- D. Excavation shall be backfilled, providing proper cover and protection of remaining auxiliary gate valve. Final grading of area shall match existing grade.
- E. Hydrant shall be reinstalled in new location in the same manner as specified for new hydrants.

3.3 *INSTALLATION OF NEW HYDRANTS*

- A. Clean hydrant interiors of all foreign matter before installation. Tighten stuffing boxes and inspect in opened and closed positions to see that all parts are in working condition. Install hydrants with pumper outlet facing the adjacent roadway or parking area, or as shown on the Plans.

3.4 *OPERATIONS CHECK*

- A. After installation, remove a nozzle cap and open the hydrant to flush out dirt and sediment. After flushing, close the hydrant, replace the cap, reopen the hydrant, and inspect for leaks. Close the hydrant, remove the caps, and verify that hose connections fit the hose outlets. Verify that hydrant drains properly. Hydrants not draining properly shall be corrected by Contractor at no additional expense to Owner.

END OF SECTION

SECTION 33 13 00

DISINFECTION OF WATER DISTRIBUTION SYSTEM

PART 1 GENERAL

1.1 WORK INCLUDED

- A. Disinfection of all new potable piping, components, and appurtenances.
- B. This shall include disinfection of all potable water piping.
- C. New facilities shall be kept isolated from the active distribution system using a backflow, double check valve device per ANSI/AWWA C651 - Disinfecting Water Mains.
- D. Before allowing water from the municipal supply system to enter the new potable water system, all its components shall be cleaned and disinfected.
- E. Test and report results. Cost of all testing shall be borne by the Contractor.
- F. Connect new system and existing water distribution mains, after all required test are satisfactory and approved by the Engineer.

1.2 RELATED WORK

- A. Section 33 01 00 – Pipe and Fittings
- B. Section 40 05 23 – Valves and Appurtenances

1.3 REFERENCE

- A. ANSI/AWWA C651 - Disinfecting Water Mains.
- B. ANSI/AWWA C652 – Disinfection of Water Storage Facilities
- C. ANSI/AWWA C654 – Disinfection of Wells

1.4 SUBMITTALS

- A. Submit 5 copies of each compliance report to Engineer. Reports shall include the following information:
 - 1. Disinfection report; accurately record:
 - a. Type and form of disinfectant used.
 - b. Date and time of disinfectant injection start and time of completion.

- c. Test locations.
 - d. Initial and 24 hour disinfectant residuals in parts per million - ppm for each location tested.
 - e. Date and time of flushing start and completion.
 - f. Disinfectant residual after flushing in ppm for each location tested.
 - g. Persons present during the disinfection operation.
2. Bacteriological report; accurately record:
- a. Date issued, project name, and testing laboratory name, address, and telephone number.
 - b. Time and date of water sample collection.
 - c. Name of person collecting samples.
 - d. Test locations.
 - e. Initial and 24 hour disinfectant residuals in ppm for each location tested.
 - f. Coliform bacteria test results for each location tested.
 - g. Certification that water conforms, or fails to conform, to bacterial standards of the California State Water Resources Control Board.
 - h. Bacteriologist's signature.

B. Submittals shall be in accordance with the General and Special Provisions.

1.5 *QUALITY ASSURANCE*

- A. Testing laboratory certified with the State of California for examination of drinking water.
1. Testing laboratory shall be selected by the Contractor and approved by the Owner.
 2. All samples shall be gathered and tested by said Laboratory.
 3. Contractor shall instruct the testing laboratory to provide the test results to the Engineer immediately upon results and a copy of the written report sent directly to the Engineer

PART 2 PRODUCTS

2.1 CHLORINE

- A. All disinfectant chemicals shall be certified to ANSI/NSF Standard 60
- B. Chlorine-bearing compounds:
 - 1. Calcium hypochlorite (comparable to commercial products known as HTH, Perchloron, and Pittchlor).
 - 2. Sodium hypochlorite (known commercially as liquid bleach).

PART 3 EXECUTION

3.1 PREPARATION

- A. Verify that system has been cleaned, inspected, and pressure tested.
- B. If a chlorine-bearing compound is to be used, the calcium hypochlorite or sodium hypochlorite shall be prepared as a water mixture before introduction into the potable water piping system. The powder shall first be made into a paste and then thinned to approximately a 1- percent chlorine solution (10,000 ppm). The preparation of 1- percent chlorine stock solution requires the following proportions of powder to water:

<u>Product</u>	<u>Amount of Compound</u>	<u>Quantity of Water (Gals)</u>
High-test Calcium Hypochlorite (65 to 70 percent Cl)	1 lb.	7.50
Sodium Hypochlorite (5.25 percent Cl)	1 gal.	4.25

3.2 APPLICATION

- A. Provide and attach equipment required to execute work of this Section. This may include:
 - 1. A solution-feed chlorination device.
 - 2. A device to regulate rate of flow and provide effective diffusion of the gas into the water within the pipe being tested. Chlorinating devices for feeding solutions of the chlorine gas or the gas itself into the water shall provide means for preventing the backflow of water into the chlorine cylinder.

- B. Preliminary Flushing: Before disinfection, the system with outlets open shall be flushed thoroughly with water. Flushing shall be done after the pressure test has been made. Flushing shall develop a velocity in pipes of at least 2.5 fps.
- C. Point of Application: The preferred point of application of the chlorinating agent is at the beginning of the pipeline extension of any valved section, and through a corporation stop inserted by the Contractor (except in new distribution systems) in the top of the newly laid pipe. The water injector for delivering the chlorine-bearing water into the pipe shall be supplied from a tap on the pressure side of the gate valve controlling the flow into the pipeline extension.
- D. Retention Period: Treated water shall be retained for at least 24 hours.
- E. Chlorinating Valves and Hydrants: In the process of chlorinating newly laid pipe, all valves or other appurtenances shall be operated while the pipeline is filled with the chlorinating agent.
- F. Circulate and flush repeatedly until specified cleanliness is achieved. Before being placed in service, all new mains and repaired portions of, or extensions to, existing mains shall be chlorinated so that a chlorine residual of not less than 25 mg/l free available chlorine remains in the water after 24 hours standing in the pipe.

3.3 TESTS

- A. Samples shall be tested in accordance with ANSI/AWWA C651, C652, and C654.
 - 1. If disinfection fails to produce satisfactory test results, the new pipes and facilities may be re-flushed and retested. If samples taken after re-flushing also fail to produce satisfactory results, sections represented by those results shall again be disinfected and retested. The cost of any retests, including time for the Engineer, shall be borne by the Contractor at no additional cost to the project.

END OF SECTION

SECTION 40 05 23
VALVES AND APPURTENANCES

PART 1 GENERAL

1.1 WORK INCLUDED

- A. This section includes materials, testing, and installation of manually operated valves and check valves including gate, butterfly, ball, hose bibbs, globe, check, solenoid, mud valves, vacuum breakers and flap valves.

1.2 RELATED WORK

- A. Section 33 01 00 – Pipe & Fittings

1.3 REFERENCES

- A. American Society for Testing and Materials (ASTM)
- B. American Water Works Association (AWWA)
- C. City of Los Banos Design Standards

1.4 SUBMITTALS

- A. Submittals shall be in accordance with the General and Special Provisions.
- B. Submit manufacturer's catalog data and detail construction sheets showing all valve parts. Describe each part by material of construction, specification (such as AISI, ASTM, SAE, or CDA), and grade or type.
- C. Show valve dimensions including laying lengths. Show port sizes. Show dimensions and orientation of valve actuators, as installed on the valves. Show location of internal stops for gear actuators. State differential pressure and fluid velocity used to size actuators. Show valve linings and coatings. Submit manufacturer's catalog data and descriptive literature.
- D. Submit six copies of a report verifying that the valve interior linings and exterior coatings have been tested for holidays and lining thickness. Describe test results and repair procedures for each valve. Do not ship valves to project site until the reports have been returned by the Owner's Representative and marked "Resubmittal not required."

PART 2 PRODUCTS

2.1 GENERAL

- A. All valves installed in potable water applications shall conform to California AB 1953 no-lead regulations and ANSI/NSF Standard 61.
- B. Install valves complete with operating extension stems and wrenches required for operation.
- C. Valves shall have the name of the manufacturer and the size of the valve cast or molded onto the valve body or bonnet or shown on a permanently attached plate.

2.2 CAST IRON VALVE BOXES AND RISERS

- A. Valve boxes shall be a traffic rated valve box and lid rated for H-20 traffic loads. The minimum inside diameter of the concrete box shall be 10-3/8 inches. The overall depth of the concrete box shall be a minimum of 12 inches. The valve box lid shall be cast iron.
 - 1. Valve cover lids must be labeled "WATER".
 - 2. Valve box shall be Christy Concrete Products – G05TBOX "Traffic Valve Box" and G05CT "Cast Iron" lid or City approved equal.
 - 3. Materials to be used for extensions below valve body to valve operating nut shall be 8-inch PVC pipe conforming to AWWA C900.

2.3 VALVES

- A. Gate Valves:
 - 1. All valves shown adjacent to fittings shall have one mechanical joint and one flange joint. The flange joint will bolt to the fitting.
 - 2. All gate valves shall be rubber seated, tight-closing type conforming to AWWA Standard C509. Valves shall be left open and be equipped with a 2-inch AWWA operating nut and stainless steel stem and shall be Clow Model 2639 or City approved equal.

2.4 RESTRAINED JOINTS

- A. Restrained flange adapters and mechanical joint restraint shall be made of ductile iron conforming to ASTM A536 and have flange bolt circles compatible with ANSI/AWWA C110/A21.10.
- B. The restrained flange adapter or mechanical joint restraint shall consist of a plurality of individual actuated gripping wedges to maximize restraint capabilities. Torque limiting actuating screws shall be used to ensure proper initial set of gripping wedges.

- C. The restrained flange adapter shall be capable of deflection during assembly or allow lengths of pipe to be field cut at a minimum of 0.6 inch gap between the end of the pipe and the mating flange without affecting the integrity of the seal.
- D. The restrained flange adapter and mechanical joint restraint coating shall consist of a minimum of two coats of liquid thermoset epoxy coating and heat cure to follow each coat.
- E. Restrained flange adapter manufacturer and model; EBBA, Inc. Series 2100 Magaflange, or equal,
- F. Restrained joint adapter manufacturer and model; EBBA, Inc. Series 1100 Magaflange, or equal,

2.5 VALVE SHIPMENT AND STORAGE

- A. Provide flanged openings with metal closures at least 3/16-inch thick, with elastomer gaskets and at least four full-diameter bolts. Install closures at the place of valve manufacture prior to shipping. For studded openings, use all the nuts needed for the intended service to secure closures. Alternatively, ship flanged valves 3 inches and smaller in separate sealed cartons or boxes.
- B. Provide threaded openings with steel caps or solid-shank steel plugs. Do not use nonmetallic (such as plastic) plugs or caps. Install caps or plugs at the place of valve manufacture prior to shipping. Alternatively, ship valves having threaded openings or end connections in separate sealed cartons or boxes.
- C. Store resilient seated valves in sealed polyethylene plastic enclosures with a minimum of one package of desiccant inside. Store resilient seated valves in the open or unseated position. Valves with adjustable packing glands shall have the packing gland loosened prior to storage. Inspect valves at least once per week, replace desiccant if required and repair damaged storage enclosures. Do not store valves with resilient seats near electric motors or other electrical equipment.
- D. Inspect valves on receipt for damage in shipment and conformance with quantity and description on the shipping notice and order. Unload valves carefully to the ground without dropping. Use forklifts or slings under skids. Do not lift valves with slings or chain around operating shaft, actuator, or through waterway. Lift valves with eyebolts or rods through flange holes or chain hooks at ends of valve parts.
- E. Protect the valve and actuators from weather and the accumulation of dirt, rocks, and debris. Do not expose rubber seats to sunlight or ozone for more than 30 days. Also, see the manufacturer's specific storage instructions.
- F. Make sure flange faces, joint sealing surfaces, body seats, and disc seats are clean. Check the bolting attaching the actuator to the valve for loosening in transit and handling. If loose, tighten firmly. Open and close valves having manual or power actuators to make sure the valve operates properly and that stops or limit switches are correctly set so that the valve seats fully. Close valve before installing.

2.6 *INSTALLING VALVES - GENERAL*

- A. Remove covers over flanged openings and plugs from threaded openings, after valves have been placed at the point to which the valves will be connected to the adjacent piping. Do not remove valves from storage cartons or boxes until they are ready to be installed.
- B. Handle valves carefully when positioning, avoiding contact or impact with other equipment, vault or building walls, or trench walls.
- C. Clean valve interiors and adjacent piping of foreign material prior to making up valve to pipe joint connection. Prepare pipe ends and install valves in accordance with the pipe manufacturer's instructions for the joint used. Do not deflect pipe-valve joint. Do not use a valve as a jack to pull pipe into alignment. The installation procedure shall not result in bending of the valve/pipe connection with pipe loading.
- D. Make sure valve ends and seats are clean. Check exposed bolting for loosening in transit and handling and tighten to manufacturer's recommendations. Open and close the valve to make sure it operates properly and that stops or limit switches are correctly set so that the vane, ball, gate, needle, diaphragm, disc, plug, or other seating element seats fully. Close the valve before installing. Check coatings for damage and repair. Handle valves carefully when positioning, avoiding contact or impact with other equipment or structures
- E. Prior to assembly, coat threaded portions of stainless steel bolts and nuts with lubricant.

2.7 *INSTALLING BURIED VALVES*

- A. Connect the valve, coat the flanges and place and compact the backfill to the height of the valve stem.
- B. Connect the valve, coat the flanges, apply polyethylene encasement, and place and compact the backfill to the height of the valve stem.
- C. Place block pads under the riser pipe to maintain the valve box vertical during backfilling and repaving and to prevent the riser pipe from contacting the valve bonnet.
- D. Secure the riser pipe with backfill and compact. Install the valve box and pour the concrete collar. In pavement areas pour the collar to 2 inches below the finished pavement grade to allow asphalt concrete to be placed over the collar. In non-paved areas, place the collar to the top of the valve box.

2.8 *FIELD COATING BURIED VALVES*

- A. Coat flanges of buried valves and the flanges of the adjacent piping, and the bolts and nuts of flanges and mechanical joints, per Section 09 90 00, System No. 7.

- B. Wrap buried metal valves 6 inches and in two layers of polyethylene conforming to AWWA C105, 8 mils in thickness each. Pass the two sheets of polyethylene under the valve and the coated flanges or joints with the connecting pipe and draw the sheets around the valve body, the valve bonnet, and the connecting pipe. Secure the sheets with plastic adhesive tape about the valve stem below the operating nut and about the barrel of the connecting pipe to prevent the entrance of soil. Fold overlaps twice and tape. Backfill the valve with care to avoid damaging the polyethylene.

2.9 ASSEMBLING JOINTS

- A. Bolt holes of flanged valves shall straddle the horizontal and vertical centerlines of the pipe run to which the valves are attached. Clean flanges by wire brushing before installing flanged valves. Clean flange bolts and nuts by wire brushing, lubricate threads with oil and graphite, and tighten nuts uniformly and progressively. If flanges leak under pressure testing, loosen or remove the nuts and bolts, reseal or replace the gasket, reinstall or retighten the bolts and nuts, and retest the joints. Joints shall be watertight.
- B. Clean threaded joints by wire brushing or swabbing. Apply Teflon joint compound or Teflon tape to pipe threads before installing threaded valves. Joints shall be watertight.

2.10 INSTALLING EXTENSION STEM GUIDE BRACKETS

- A. Install at 6 to 8-foot centers. Provide at least two support brackets for stems longer than 10 feet, with one support near the bottom of the stem and one near the top.

2.11 VALVE FIELD TESTING

- A. Test valves for leakage at the same time that the connecting pipelines are hydrostatically tested. See Section 33 01 00 for pressure testing requirements. Protect or isolate any parts of valves, actuators, or control and instrumentation systems whose pressure rating is less than the pressure test. Valves shall show zero leakage. Repair or replace any leaking valves and retest.
- B. Operate manual valves through three full cycles of opening and closing. Valves shall operate from full open to full close without sticking or binding. Do not backfill buried valves until after verifying that valves operate from full open to full closed. If valves stick or bind, or do not operate from full open to full closed, repair or replace the valve and repeat the tests.

END OF SECTION