

CITY OF LOS BANOS

May 26, 2011

**ADDENDUM NO. 1 TO CONTRACT DOCUMENTS
FOR PLACE ROAD AND SAN LUIS STREET
STORM DRAIN AND DETENTION BASIN**

1. The City of Los Banos Contract Documents entitled, "Place Road and San Luis Street Storm Drain and Detention Basin" are hereby modified to effect the following changes:
 - a. On Drawing Sheet No. 28 change the Watertronics Booster Pump Model No. to CLTBV-2-15-460-3-203-60. Also change the Model No. in Paragraph 3.01.H.1 on Page 6 of Section 32 84 21 of the Specifications.
 - b. Add the following General Note to Drawing Sheet No. 40:

"GENERAL CONTRACTOR SHALL PROVIDE TO OWNER A CERTIFICATION BY A CERTIFIED PLAYGROUND SAFETY INSPECTOR THAT THE PLAYGROUND EQUIPMENT MEETS STANDARDS FOR SAFETY AS DEFINED BY THE NATIONAL RECREATION AND PARKS ASSOCIATION."
 - c. The Owner will pay any Rule 16 CPUC tariffs associated with providing electric service for the project.
 - d. As a minimum, provide 6-foot high temporary chain link fencing between the work site and the Los Banos Junior High School and the Child Development Center as shown on the attached figure. (Figure 1)
 - e. The 4-inch flowmeter shown on Drawing C-114 will be furnished by the Owner.
 - f. Paragraph 3.10 Backfill in Section 33 42 20 should be revised to read as follows: "Perform backfill in accordance with ACI 346-01, paragraph 3.2.3.4 except where modified in Section 31 23 33."
 - g. Paragraph 3.11 Compaction in Section 33 42 20 should be revised to read as follows: "Compaction shall be in accordance with Section 31 23 33."
 - h. Paragraph 3.12 Field Quality Control in Section 33 42 20 should be revised to read as follows: "Field quality control shall be in accordance with Section 31 23 33."
 - i. Paragraph A of 1.05 DISPOSAL OF EXCESS MATERIALS in Section 31 23 00 shall be revised to read as follows:

"Excess site excavated or wasted material shall be disposed of at an Owner furnished site shown in the attached figure. (Figure 2) The Owner will remove a portion of the chain link fence surrounding the site to allow equipment to ingress and egress the site. The Owner will stake the perimeter of the area where the

material shall be stockpiled. (Approximately 700 feet long and 250 feet wide.) The stockpiled material shall be constructed with 3 horizontal:1 vertical side slopes and a flat/level top. The material shall be compacted to 85% relative compaction.”

- j. Add the following as Paragraph C of Paragraph 1.04 STORM WATER DISCHARGE in Section 01 35 43:

“The Owner furnished disposal site for excavated or wasted material is a landfill site. The Storm Water Pollution Prevention Plan prepared for this project shall be in conformance with the landfill Storm Water Pollution Prevention Plan or NPDES permit.”

- k. On Page 5 of Section 00 41 13 of the Specifications remove “D. Disclosure of Ownership form (attached).” From Article 7 – Attachments to this Bid.

- l. Insert the attached Appendix A and Appendix B at the end of Section 00 41 13.

- 2. If you have given your copy of the CONTRACT DOCUMENTS to someone else, please forward this Addendum also.
- 3. Bids shall be submitted in accordance with this Addendum. Sign and return this Addendum with your BID.

AECOM

Firm Name: _____

By: _____

Title: _____


Date: _____

By:  _____
Gary W. Rogers, Project Engineer

RACQUET CLUB DRIVE

LOS BANOS JUNIOR HIGH SCHOOL

TEMPORARY 6-FOOT
CHAINLINK FENCING



SAN LUIS STREET

MILLER LANE



DWG: \\US\B51\FP001\Area\Projects\CLE\60188586-San_Luis_Place_SDI_400-Technical\406-Civil\001\CAD\Plan_Sc\ADDENDUM-EXHIBIT.DWG Layout Name: Layout1 - Plotted by: Mereno, David Date: 5/26/2011 - 3:21 PM
 XREFS: 1004770PO - C-60-AWG-ANSI-B - XREF-123-10 IMAGES: CARX-SIGN.JPG -

AECOM

AECOM USA, Inc.
 1120 W. I St.
 LOS BANOS, CA. 93635, SUITE "C"
 T 209-826-5155 F 209-826-3307
 www.aecom.com

CITY OF LOS BANOS
SAN LUIS AND PLACE ROAD - STORMDRAIN PIPELINE AND BASIN
TEMPORARY 6-FOOT CHAINLINK FENCING


AECOM PROJECT NO.
60188586

FIGURE
1

DISPOSAL SITE
FOR EXCESS
WASTED MATERIAL



BASIN
SITE



DWG: \\USERS\F0001\464\Projects\CLB\60188586-San_Luis_Place_SUD\00-Technical\06-Civil\001\CAD\Plan_San_Luis_ADDENDUM-EXHIBIT-2.DWG Date: 5/26/2011 - 3:21 PM
 Layout Name: Layout1 Plotted by: Moreno, David
 MACSS: CARY-SIGN-PC User: rml1@ae.com

AECOM USA, Inc.
 1120 W. I St.
 LOS BANOS, CA 93635, SUITE "C"
 T 209-826-5155 F 209-826-3307
 www.aecom.com

CITY OF LOS BANOS
SAN LUIS AND PLACE ROAD - STORMDRAIN PIPELINE AND BASIN
DISPOSAL SITE LOCATION

AECOM
 PROJECT NO.
 60188586

FIGURE
 2

